



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside</i>	D&A PROJECT NO.: <i>2020525.4A</i>	DATE: <i>11-26-2020</i>
PROJECT: <i>Bradwin Rehab.</i>	INSPECTOR: <i>Tony Mann 1397630</i>	
CONTRACTOR: <i>Westside</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>SMR Concrete Detroit</i>	PROJECT ENGINEER: <i>City of Detroit</i>	
WEATHER: A.M. <i>sunny</i> P.M.	TIME ARRIVED: <i>8:30</i> SCHEDULED ARRIVAL TIME: <i>9:00</i> TIME LEFT SITE: <i>9:45</i>	
AGGREGATE CORRECTION FACTOR:		

Pour Description: *patching side walk in various locations of Forest*

Mix Design: *Detm* Quantity Placed (yd³): *5* Lot Number: _____ Sublot: _____
Grade of Concrete: *91* Batch Quantity (yd³): *5* Pour Start: *9:10* Pour End: *9:40*

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
<i>2352</i>	<i>818012</i>	<i>8:34</i>	<i>9:10</i>	<i>9:40</i>	<i>11</i>	<i>55</i>	<i>68</i>	<i>5.5</i>	<i>146.4</i>	<i>9711</i>	<i>4</i>

REMARKS

