

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138169 DATE 07/10/20	
DRIVER INSTRUCTION: SHERWOOD SOUTH OFF 7 MILE / WEST OF VAN DYKE --- 5 INCH SLUMP ---						MAP PAGE: DT4201E7		TIME: 7:47	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	MARK MALIK	4826	33.01	11.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM COOL		11.00 1.00	yd /yd	MDOT P1 S35 MR TEMPERATURE CONTROLLED					
MDOT 1155 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	H-24				
FLY ASH:					COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)		
COARSE AGG	L6AA-PIN	6AAL PORT INLAND		71-003			CHECK CASH CREDIT		
INTERM AGG	2NS-SMR	2NS - SPRING MILL RECLAMATIO		47-003					
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4826	MAMALIK	user	14138169	14138169	7:47	7/10/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				D	137481

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	18540 lb	-0.20%			
2NS-SMR	1350 lb	16370 lb	15300 lb	-0.45%	3.50% M	62 gl	
CMT1-LAA	342 lb	3782 lb	3750 lb	-0.32%			
CMGS-LA	184 lb	2024 lb	2015 lb	-0.44%			
WAT1	28.4 gl	250.1 gl	250.0 gl	-0.05%		250.0 gl	
OAE-BA	5.28 oz	101.28 oz	100.50 oz	-0.75%			
OMRLI-PR	31.58 oz	347.18 oz	348.00 oz	0.24%			

Actual	Num Batches: 1						
Load	42719 lb	Design W/C: 0.451	Water/Cement: 0.452 T	Design	312.4 gl	Actual	312.0 gl To Add: 0.4 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	0.0 gl / yd		

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089
PHONE: (586) 775-7200

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138180 DATE: 07/10/20	
DRIVER INSTRUCTION: SHERWOOD SOUTH OFF 7 MILE / WEST OF VAN DYKE --- 5 INCH SLUMP ---						MAP PAGE: DT4201E6		TIME: 9:22	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	MIKE FORTNER	4840	33.01	22.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM COOL		11.00 1.00	yd /yd	MDOT P1 S35 MR TEMPERATURE CONTROLLED					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:		2NS - SPRING HILL RECLAMATIO		47-003	<i>Kelany D. [Signature]</i>				
FINE AGG:	2NS-SMR				COLLECTED (circle one)				
					CHECK CASH CREDIT				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4840	MIFORTNER	user	14138180	14138180	9:22	7/10/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				D	137492

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19540 lb	-0.20%			
2NS-SMR	1350 lb	15370 lb	15320 lb	-0.32%	3.50% M	62 gl	
CMT1-LAA	342 lb	3762 lb	3745 lb	-0.45%			
CMGS-LA	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	250.1 gl	250.0 gl	-0.05%		250.0 gl	
OAE-BA	5.28 oz	107.04 oz	107.50 oz	0.43%			
OMRLI-PR	31.56 oz	347.16 oz	348.00 oz	0.24%			

Actual	Num Batches: 1						
Load	42740 lb	Design W/C: 0.451	Water/Cement: 0.452 T	Design	312.4 gl	Actual	312.1 gl To Add: 0.3 gl
Slump:	5.00 in	Water In Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	0.0 gl / yd		

Arrive - 12:30

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138196 DATE: 07/10/20	
DRIVER INSTRUCTION: SHERWOOD SOUTH OFF 7 MILE / WEST OF VAN DYKE --- 5 INCH SLUMP ---						MAP PAGE: DT4201E6		TIME: 12:00	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	JOHN CASTRO	2444	33.01	33.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM COOL		11.00 1.00	yd /yd	MDOT P1 S35 MR TEMPERATURE CONTROLLED					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GBBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF		ALPENA S. CHICAGO	MDOT PLANT NO. M-24	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AAL PORT INLAND 2NS - SPRING MILL RECLAMATIO		71-003 47-003	COMPANY REPRESENTATIVE (signature) <i>Kelany Thompson</i>		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket ☐ Before Discharge Completed				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
2444	JOCASTRO	user	14138196	14138196	12:00 7/10/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
11.00 yd	P1-SM				D 137508

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19540 lb	-0.20%			
2NS-SMR	1350 lb	15370 lb	15340 lb	-0.19%	3.50% M	62 gl	
CMT1-LAA	342 lb	3762 lb	3745 lb	-0.45%			
CMGS-LA	184 lb	2024 lb	2030 lb	0.30%			
WAT1	28.4 gl	250.1 gl	249.0 gl	-0.45%		249.0 gl	
OAE-BA	5.28 oz	107.04 oz	107.00 oz	-0.04%			
OMRLI-PR	31.58 oz	347.16 oz	348.00 oz	0.24%			

Actual	Num Batches: 1							
Load	42781 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	312.4 gl	Actual	311.2 gl	To Add: 1.2 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	0.0 gl / yd			



CONCRETE FIELD TEST REPORT

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PH-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138319 DATE: 07/14/20	
DRIVER INSTRUCTION: SHERWOOD SOUTH OFF 7 MILE / WEST OF VAN DYKE --- 5 INCH SLUMP ---						MAP PAGE: DT4201E6		TIME: 8:32	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1407	DARRIN SHAFFER	4902	33.01	11.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 935 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:									
COARSE AGG	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelany Tompkins</i> X				
INTERM AGG									
FINE AGG:	2NS-SMR	2NS - SPRING HILL RECLAMATIO		47-003					
						COLLECTED (circle one)			
						CHECK CASH CREDIT			
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4902	DASHAFER	user	14138319	14138319	8:32	7/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				D	137631

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15518 lb	15460 lb	-0.38%	4.50% M	80 gl	
CMT1-LAA	342 lb	3762 lb	3745 lb	-0.45%			
CMGS-LA	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	204.8 gl	205.0 gl	0.09%		205.0 gl	
OAE-BA	5.28 oz	109.93 oz	109.50 oz	-0.39%			
OMRLI-PR	31.56 oz	347.16 oz	348.00 oz	0.24%			

Actual	Num Batches: 1						
Load	42544 lb	Design W/C: 0.451	Water/Cement: 0.452 T	Design	312.4 gl	Actual	284.8 gl To Add: 27.6 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-2.5 gl / yd		

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138338 DATE: 07/14/20	
DRIVER INSTRUCTION: CONANT SOUTH OFF DAVISON / WEST ON CARPENTER / WEST OF MOUND --- 5 INCH SLUMP ---						MAP PAGE: DT4273C2		TIME: 10:37	
RD. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1407	TODD CLARK	4813	33.01	22.00	5.00 in	6.50	14	
ITEM NAME		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
<i>Dwight Henry</i>									
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GBBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:					COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)		
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	<i>Kelley D. [Signature]</i>		CHECK CASH CREDIT		
INTERM AGG:	2NS-SMR	2NS - SPRING MILL RECLAMATIO		47-003					
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4813	TOCLARK	user	14138338	14138338	10:37	7/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				D	137650

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	-0.10%			
2NS-SMR	1350 lb	15518 lb	15480 lb	-0.38%	4.50% M	80 gl	
CMT1-LAA	342 lb	3782 lb	3755 lb	-0.19%			
CMGS-LA	184 lb	2024 lb	2015 lb	-0.44%			
WAT1	28.4 gl	204.8 gl	205.0 gl	0.09%		205.0 gl	
OAE-BA	5.28 oz	109.93 oz	109.50 oz	-0.39%			
OMRLI-PR	31.58 oz	347.18 oz	348.00 oz	0.24%			

Actual	Num Batches: 1						
Load	42529 lb	Design W/C: 0.451	Water/Cement: 0.452 T	Design	312.4 gl	Actual	284.8 gl To Add: 27.6 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-2.5 gl / yd		

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089
PHONE: (586) 775-7200

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138355 DATE: 07/14/20	
DRIVER INSTRUCTION: CONANT SOUTH OFF DAVISON / WEST ON CARPENTER / WEST OF MOUND --- 5 INCH SLUMP ---						MAP PAGE: DT427383		TIME: 12:46	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1407	DARRIN SHAFFER	4902	33.01	33.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
MDOT 1158 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.		COLLECTED (circle one) CHECK CASH CREDIT	
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:						<i>Kelley J. Smith</i>			
FINE AGG:	2NS-SMR	2NS - SPRING HILL RECLAMATIO		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
4902	DASHAFER	user	14138355	14138355	12:46 7/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
11.00 yd	P1-SM				D 137667

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	18580 lb	18620 lb	0.20%			
2NS-SMR	1350 lb	15518 lb	15480 lb	-0.38%	4.50% M	80 gl	
CMT1-LAA	342 lb	3762 lb	3745 lb	-0.45%			
CMGS-LA	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	204.8 gl	206.0 gl	0.58%		206.0 gl	
0AE-BA	5.26 oz	109.93 oz	110.00 oz	0.06%			
OMRLI-PR	31.58 oz	347.16 oz	348.00 oz	0.24%			

Actual	Num Batches: 1						
Load	42593 lb	Design W/C: 0.451	Water/Cement: 0.452 T	Design	312.4 gl	Actual	285.8 gl To Add: 28.6 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-2.5 gl / yd		

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089
PHONE: (586) 775-7200

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138360 DATE: 07/14/20	
DRIVER INSTRUCTION: CONANT SOUTH OFF DAVISON / WEST ON CARPENTER / WEST OF MOUND --- 5 INCH SLUMP ---						MAP PAGE: DT4273B3		TIME: 14:11	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1407	MICHAEL VINEYAR	4810	44.00	44.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 MR					
<i>[Signature]</i>									
MDOT 1188 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.		COLLECTED (circle one) CHECK CASH CREDIT	
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:	2NS-SMR	2NS - SPRING MILL RECLAMATION		47-003	<i>[Signature]</i>				
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
4810	MIVINEYAR	user	14138360	14138360	14:11 7/14/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
11.00 yd	P1-SM			D	137672

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19540 lb	-0.20%			
2NS-SMR	1350 lb	15518 lb	15500 lb	-0.12%	4.50% M	80 gl	
CMT1-LAA	342 lb	3762 lb	3745 lb	-0.45%			
CMGS-LA	184 lb	2024 lb	2015 lb	-0.44%			
WAT1	28.4 gl	204.8 gl	206.0 gl	0.58%		206.0 gl	
0AE-BA	5.28 oz	109.93 oz	110.50 oz	0.51%			
0MR1-PR	31.58 oz	347.16 oz	344.00 oz	-0.91%			

Actual	Num Batches: 1						
Load	42547 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	312.4 gl	Actual 288.0 gl To Add: 28.4 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-2.5 gl / yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>07-14-20</u>
PROJECT: <u>Detroit PM 7018</u>	INSPECTOR: <u>M. Booye</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>Mecoig</u> <u>materials, Warren</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u> Sunny</u> P.M.	TIME ARRIVED: <u>8:30</u> SCHEDULED ARRIVAL TIME: <u>8:30</u> TIME LEFT SITE: <u>11:00am</u>	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: North-West corner of Sherwood and Nevada
St E.

Mix Design: P1-SM Quantity Placed (yd³): 33.0 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 33.0 Pour Start: 9:20 Pour End: —

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4902	14138319	8:32	9:20	9:50	5 3/4	75	81	6.8	1424	1.005	4 DCI

REMARKS

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089
PHONE: (586) 775-7200

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138408 DATE: 07/15/20	
DRIVER INSTRUCTION: CONANT SOUTH OFF DAVISON / WEST ON CARPENTER AT MORAN ST / WEST OF MOUND --- 5 INCH SLUMP ---						MAP PAGE: DT4273B3		TIME: 9:22	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1412	JAMES SHAFFER	4410	33.01	11.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00	yd	MDOT P1 S35 HR					
MDOT 1155 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i> COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:	2NS-SMR	2NS - SPRING MILL RECLAMATIO		47-003					
FINE AGG:									
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4410	JASHAFER	user	14138408	14138408	9:22	7/15/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SM				D	137720

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19540 lb	-0.20%			
2NS-SMR	1350 lb	15444 lb	15400 lb	-0.28%	4.00% M	71 gl	
CMT1-LAA	342 lb	3762 lb	3750 lb	-0.32%			
CMGS-LA	184 lb	2024 lb	2025 lb	0.05%			
WAT1	28.4 gl	241.2 gl	241.0 gl	-0.08%		241.0 gl	
OAE-BA	5.26 oz	109.93 oz	110.50 oz	0.51%			
OMRLI-PR	31.58 oz	347.16 oz	344.00 oz	-0.91%			

Actual	Num Batches: 1								
Load	42755 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	312.4 gl	Actual	312.0 gl	To Add: 0.4 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	0.0 gl /	yd	

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138426 DATE 07/15/20	
DRIVER INSTRUCTION: CONANT SOUTH OFF DAVISON / WEST ON CARPENTER AT MORAN ST / WEST OF MOUND --- 5 INCH SLUMP ---						MAP PAGE: DT4273C2		TIME: 11:56	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1412	CHARLES MORRIS	4808	20.01	20.00	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM COOL		9.00 20.00	yd /yd	MDOT P1 S35 MR TEMPERATURE CONTROLLED					
MDOT 1155 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGFBS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:					COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)		
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	<i>Kelley J. Morrison</i>		CHECK CASH CREDIT		
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS - SPRING HILL RECLAMATIO		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4808	CHMORRISON	user		14138426	14138426	11:56	7/15/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
9.00 yd	P1-SM				D	137738	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	16020 lb	16000 lb	-0.12%			
2NS-SMR	1350 lb	12638 lb	12580 lb	-0.44%	4.00% M	58 gl	
CMT1-LAA	342 lb	3078 lb	3075 lb	-0.10%			
CMGS-LA	184 lb	1656 lb	1655 lb	-0.06%			
WAT1	28.4 gl	197.4 gl	197.0 gl	-0.18%		197.0 gl	
OAE-BA	5.28 oz	89.95 oz	90.00 oz	0.06%			
OMRLI-PR	31.58 oz	284.04 oz	284.00 oz	-0.01%			

Actual	Num Batches: 1						
Load	34977 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	255.6 gl	Actual	255.0 gl To Add: 0.6 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl /	yd

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138444 DATE: 07/15/20	
DRIVER INSTRUCTION: CONANT SOUTH OFF DAVIDSON / WEST ON CARPENTER AT MORAN ST / WEST OF MOUND --- 5 INCH SLUMP ---							MAP PAGE: DT4273C2	TIME: 14:01	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1412	JAMES SHAFFER	4410	24.50	24.50	5.00 in	6.50	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM COOL		4.50 4.00	yd /yd	MDOT P1 S35 HR TEMPERATURE CONTROLLED					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGB-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-24				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i>				
INTERM AGG:	2NS-SMR	2NS - SPRING HILL RECLAMATIO		47-003					
FINE AGG:					COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket ☐ Before Discharge Completed				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4410	JASHAFER	user	14138444	14138444	14:01	7/15/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
4.50 yd	P1-SM				D	137756

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	8010 lb	8000 lb	-0.12%			
2NS-SMR	1350 lb	6318 lb	6300 lb	-0.28%	4.00% M	29 gl	
CMT1-LAA	342 lb	1539 lb	1530 lb	-0.58%			
CMGS-LA	184 lb	828 lb	830 lb	0.24%			
WAT1	28.4 gl	91.9 gl	92.0 gl	0.08%		92.0 gl	
OAE-BA	5.28 oz	44.97 oz	45.50 oz	1.17%			
OMRLI-PR	31.58 oz	142.02 oz	140.00 oz	-1.42%			

Actual	Num Batches:	1									
Load	17439 lb	Design W/C:	0.451	Water/Cement:	0.452 T	Design	127.8 gl	Actual	121.0 gl	To Add:	6.8 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.5 gl / yd				



DRIESEN & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>07-15-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>M. Boudrye</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>MCCOIG</u> <u>materials, Warren</u>	PROJECT ENGINEER: <u>CITY OF Detroit</u>	
WEATHER: <u>(A.M.) Sunny</u> P.M.	TIME ARRIVED: <u>9:00</u> SCHEDULED ARRIVAL TIME: <u>10:00</u> TIME LEFT SITE: <u>011:30</u>	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: North-West corner of Carpenter St
and Gallagher St. Hamtramck

Mix Design: P1-Sm Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 10:05 Pour End: 10:50

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4410	14138408	9:22	10:05	10:50	6 1/4	82	83	7.0	139.2	1.033	4401

REMARKS

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209

PHONE: (734) 357-2124

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>W. GRAND BLVD LB SIDEWALK #1</i>				TICKET CODE: 2203932 DATE: 07/20/20	
DRIVER INSTRUCTION: W.GRAND RIVER AND LINWOOD NORTH OF GRAND RIVER EAST OF DEXTER**** NO CITY SLIP!!!!						MAP PAGE: DT4344D2		TIME: 10:28	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	207	WILLIE WEST	2403	33.01	11.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.		GRADE OF CONC.
GGGFS:									
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one) CHECK CASH CREDIT
INTERM AGG:							<i>Joseph Yahi</i>		
FINE AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 2403	Driver WIWEST	User user	Disp Ticket Num 2203932	Ticket ID 2203932	Time 10:28	Date 7/20/20
Load Size 11.00 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225636

Material	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
Batch:	1 ----	Start: 10:28:16	End: 10:30:05	Time (hh:mm:ss): 00 : 01	Time (hh:mm:ss): 00 : 49				
L6AA-PIN	1810 lb	1810		19910 lb	19880 lb	-0.15%			
2NS-WLB	1230 lb	1230		14004 lb	13920 lb	-0.60%	3.50%	56 gl	
CMT1-CRHM	564.0 lb	564.0		6204.0 lb	6180.0 lb	-0.39%			
WAT1	30.5 gl	30.5		256.3 gl	257.2 gl	0.35%		257.2 gl	-2.0 gl
OAE-BA	5.64 oz	5.64		65.14 oz	65.00 oz	-0.22%			105.00 %
OMRLI-PR	39 oz	39		434 oz	436 oz	0.40%			

Actual	Num Batches: 1								
Load	42157 lb	Design W/C:	0.451	Water/Cement:	0.453 A	Design	335.5 gl	Actual	313.6 gl To Add: 21.9 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-2.0 gl / yd		

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 W. GRAND BLVD E.B. SIDOROVIC 				TICKET CODE: 2203949 DATE: 07/20/20	
DRIVER INSTRUCTION: W.GRAND RIVER AND LINWOOD NORTH OF GRAND RIVER EAST OF DEXTER**** NO CITY SLIP!!!!							MAP PAGE: DT4344C2	TIME: 12:10	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	207	KEITH O'NEIL	2441	33.01	22.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETH		11.00	yd	CITY OF DETROIT P1 HR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.		GRADE OF CONC.	
GGGFS:									
FLY ASH:						COMPANY REPRESENTATIVE (signature)			
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003	 COLLECTED (circle one) CHECK CASH CREDIT			
INTERM AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE _____			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 2441	Driver KEONEIL	User user	Disp Ticket Num 2203949	Ticket ID 2203949	Time 12:10	Date 7/20/20
Load Size 11.00 yd	Mix Code P1-DETH	Returned	Qty	Mix Age	Seq 2W	Load ID 225653


Material	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
Batch:	1	Start	End	12:14:19	Time (hh:mm:ss):	00 : 03	: 55		
L6AA-PIN	1810 lb	1810		19910 lb	19760 lb	-0.75%			
2NS-WLB	1230 lb	1230		14004 lb	13920 lb	-0.80%	3.50%	56 gl	
CMT1-CRHM	584.0 lb	584.0		6204.0 lb	6180.0 lb	-0.39%			
WAT1	30.5 gl	30.5		256.3 gl	254.0 gl	-0.87%		254.0 gl	-2.0 gl
OAE-BA	5.64 oz	5.64		85.14 oz	84.00 oz	-1.75%			105.00 %
OMRLI-PR	39 oz	39		434 oz	432 oz	-0.53%			

Actual	Num Batches: 1		
Load 42011 lb	Design W/C: 0.451	Water/Cement: 0.453	A
Slump: 5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:
		335.5 gl	Actual 310.5 gl To Add: 25.0 gl
		-2.0 gl / yd	

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)


(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3</i> <i>W. GRAND BLVD</i> <i>EB SIDEWALK</i> 				TICKET CODE: 2203975 DATE: 07/20/20	
DRIVER INSTRUCTION: ON GRAND BLVD BTW W GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!							MAP PAGE: DT4344C2	TIME: 14:06	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	207	FRANKLIN SAXTC	3705	33.01	33.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETH		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.	GRADE OF CONC.	
GGGFS:									
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature) 		
INTERM AGG:									
FINE AGG:		2NS-WLB	2NS - WATERLAND DURMEISTER 8		81-093		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 3705	Driver FRSAXTON	User user	Disp Ticket Num 2203975	Ticket ID 2203975	Time 14:06	Date 7/20/20
Load Size 11.00 yd	Mix Code P1-DETH	Returned	Qty	Mix Age	Seq 2W	Load ID 225679

Material Batch:	Design Qty	Start	SSD	Adj.T	Required	Batched	Time (hh:mm:ss)	% Var	% Moisture	Actual Wat	Trim
L6AA-PIN	1810 lb	14:08:27	1810	End:	14:10:40	19910 lb	19880 lb	-0.15%			
2NS-WLB	1230 lb		1230		14037 lb	14000 lb		-0.27%	3.75%	61 gl	
CMT1-CRHM	564.0 lb		564.0		6204.0 lb	6180.0 lb		-0.39%			
WAT1	30.5 gl		30.5		255.0 gl	254.3 gl		-0.27%		254.3 gl	-1.8 gl
OAE-BA	5.64 oz		5.64		65.14 oz	85.00 oz		-0.22%			105.00 %
OMRL-PR	39 oz		39		434 oz	432 oz		-0.53%			

Actual Load	42213 lb	Design W/C:	0.451	Water/Cement:	0.453	A	Design	335.5 gl	Actual	314.9 gl	To Add:	20.6 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl	/ Load	Trim Water:	-1.8 gl	/ yd			



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>7-20-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Eric Morris #01396263</u>	
CONTRACTOR: <u>West side concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u> </u>	
CONCRETE SUPPLIER & CITY: <u>Mccoig materials - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>clear</u> P.M.	TIME ARRIVED: <u>11:00</u> SCHEDULED ARRIVAL TIME: <u>11:00</u> TIME LEFT SITE: <u>11:45</u>	
AGGREGATE CORRECTION FACTOR:		


Pour Description: Sidewalk on W Grand Blvd East of Dexter ave

Mix Design: P1-SM Quantity Placed (yd³): 11 Lot Number: Sublot:
Grade of Concrete: P1 Batch Quantity (yd³): 11 Pour Start: 11:00 Pour End: 11:31

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2403	0203932	10:28	11:00	11:31	4 1/2	77	84	6.1	141.8	1.00	4/8, 1

REMARKS



**DRIESING &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>2020525.1A</u>	DATE: <u>7-21-2020</u>
PROJECT: <u>Detroit I-75 - 7015</u>	INSPECTOR: <u>Refuck Drumm</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>Michigan - Detroit</u>	PROJECT ENGINEER:	
WEATHER: <u>Clear</u> A.M. <u>70</u> P.M.	TIME ARRIVED: <u>7:30</u> SCHEDULED ARRIVAL TIME: <u>7:30</u> TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: S.bound - 40' x 40' x 10' of Detroit Northwestern HS - S side of W Grand B/V

Mix Design: PL-1070 Quantity Placed (yd³): 1 Lot Number: Sublot:
Grade of Concrete: 3 Batch Quantity (yd³): 22.01 Pour Start: Pour End:

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
711	300001	7:38	8:10	8:15	14	70	13	.6	146	2.955	4 (2'1)

REMARKS

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 EB W. GRAND BLVD SIDE WALK (Signature)</i>				TICKET CODE: 2204001 DATE: 07/21/20	
DRIVER INSTRUCTION: ON W GRAND BLVD BTW GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!						MAP PAGE: DT4344D2		TIME: 7:28	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	203	ROD HAZELY	3711	33.01	11.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.		GRADE OF CONC.
GGGFS:							COMPANY REPRESENTATIVE (signature)		
FLY ASH:							COLLECTED (circle one) CHECK CASH CREDIT		
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003				
INTERM AGG:									
FINE AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER-B		81-093				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 3711	Driver ROHAZELY	User user	Disp Ticket Num 2204001	Ticket ID 2204001	Time 7:28	Date 7/21/20
Load Size 11.00 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225705

Material Batch:	Design Qty	SSD	Adj. T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
L6AA-PIN	1810 lb	1810		19910 lb	19880 lb	-0.15%			
2NS-WLB	1230 lb	1230		14037 lb	14000 lb	-0.27%	3.75%	61 gl	
CMT1-CRHM	564.0 lb	564.0		6204.0 lb	6180.0 lb	-0.39%			
WAT1	30.5 gl	30.5		252.2 gl	252.8 gl	0.25%		252.8 gl	-2.0 gl
OAE-BA	5.64 oz	5.64		65.14 oz	65.00 oz	-0.22%			105.00 %
OMRLI-PR	39 oz	39		434 oz	432 oz	-0.53%			

Actual Load	42201 lb	Design W/C:	0.451	Water/Cement:	0.453	A	Design	335.5 gl	Actual	313.5 gl	To Add:	22.0 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl	/ Load	Trim Water:	-2.0 gl	/ yd			

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2</i> <i>W. GRAND BLVD</i> <i>EB SIDEWALK</i> <i>PD</i>				TICKET CODE: 2204009 DATE: 07/21/20	
DRIVER INSTRUCTION: ON W GRAND BLVD BTW GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!							MAP PAGE: DT4344D2	TIME: 8:30	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	203	KYLE CHEESMAN	3716	33.01	22.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.		GRADE OF CONC.	
GGGFS:									
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one) CHECK CASH CREDIT	
INTERM AGG:						<i>X Joseph Yahi</i>			
FINE AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.						UNLOAD PROMPTLY: Excess time will be charged to the buyer.			

Truck 3716	Driver KYCHEESMAN	User user	Disp Ticket Num 2204009	Ticket ID 2204009	Time 8:30	Date 7/21/20
Load Size 11.00 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225713

Material Batch:	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
	1	Start: 8:30:01	End: 8:31:47		Time (hh:mm:ss): 00 : 01		: 46		
L6AA-PIN	1810 lb	1810		19910 lb	19840 lb	-0.35%			
2NS-WLB	1230 lb	1230		14037 lb	13960 lb	-0.55%	3.75%	60 gl	
CMT1-CRHM	564.0 lb	564.0		6204.0 lb	6180.0 lb	-0.39%			
WAT1	30.5 gl	30.5		252.2 gl	253.6 gl	0.54%		253.6 gl	-2.0 gl
OAE-BA	5.64 oz	5.64		65.14 oz	65.00 oz	-0.22%			105.00 %
OMRLI-PR	39 oz	39		434 oz	436 oz	0.40%			

Actual Load	42127 lb	Design W/C:	0.451	Water/Cement:	0.453	A	Design	335.5 gl	Actual	314.0 gl	To Add:	21.5 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl	/ Load	Trim Water:	-2.0 gl	/ yd	Note: Manual feed occurred		

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 W. GRAND BLVD EB SIDEWALK ②				TICKET CODE: 2204019 DATE: 07/21/20	
DRIVER INSTRUCTION: ON W GRAND BLVD BTW GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!						MAP PAGE: DT4344C2		TIME: 9:53	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	203	JOE GOLDING	4837	33.01	33.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
PI-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA	Detroit	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:									
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	71-003	COMPANY REPRESENTATIVE (signature) Joseph Yahi			COLLECTED (circle one) CHECK CASH CREDIT		
INTERM AGG:									
FINE AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER 8	81-093						
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 4837	Driver JOGOLDING	User user	Disp Ticket Num 2204019	Ticket ID 2204019	Time 9:53	Date 7/21/20			
Load Size 11.00 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225722			
Material Batch:	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
	1	Start: 9:53:29	End: 9:55:15		Time (hh:mm:ss): 00 : 01 : 46				
L6AA-PIN	1810 lb	1810		19910 lb	19880 lb	-0.15%			
2NS-WLB	1230 lb	1230		14004 lb	13960 lb	-0.31%	3.50%	57 gl	
CMT1-CRHM	564.0 lb	564.0		6204.0 lb	6180.0 lb	-0.39%			
WAT1	30.5 gl	30.5	-23.0	233.3 gl	232.5 gl	-0.34%		232.5 gl	-2.0 gl
OAE-BA	5.64 oz	5.64		65.14 oz	65.00 oz	-0.22%			105.00 %
OMRLI-PR	39 oz	39		434 oz	436 oz	0.40%			
Actual	Num Batches: 1								
Load	41991 lb	Design W/C: 0.451	Water/Cement: 0.453	A	Design	335.5 gl	Actual	289.0 gl	To Add: 46.5 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: -23.0 gl	/ Load	Trim Water:	-2.0 gl	/ yd		

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 W. GRAND BLVD 				TICKET CODE: 2204097 DATE: 07/22/20	
DRIVER INSTRUCTION: ON W GRAND BLVD BTW GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!							MAP PAGE: DT4344C2	TIME: 7:31	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	226	TIM NESS	3726	33.01	11.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		11.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-WLB	6AA - PORT INLAND 2NS - WATERLAND BURMEISTER 8		71-003 81-093	COMPANY REPRESENTATIVE (signature) X Joseph Yahi			COLLECTED (circle one) CHECK CASH CREDIT	
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 3726	Driver TINESS	User user	Disp Ticket Num 2204097	Ticket ID 2204097	Time 7:31	Date 7/22/20			
Load Size 11.00 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225801			
Material Batch:	Design Qty	SSD Start:	Adj.T End:	Required	Batched Time (hh:mm:ss):	% Var : 01 : 45	%Moisture	Actual Wat	Trim
L6AA-PIN	1810 lb	1810		19910 lb	19920 lb	0.05%			
2NS-WLB	1230 lb	1230		14037 lb	13960 lb	-0.55%	3.75%	60 gl	
CMT1-CRHM	564.0 lb	564.0		6204.0 lb	6230.0 lb	0.42%			
WAT1	30.5 gl	30.5		255.0 gl	255.0 gl	0.01%		255.0 gl	-1.8 gl
OAE-BA	5.64 oz	5.64		65.14 oz	65.00 oz	-0.22%			105.00 %
OMRLI-PR	39 oz	39		434 oz	436 oz	0.40%			
Actual	Num Batches: 1								
Load	42269 lb	Design W/C: 0.451	Water/Cement: 0.449	A	Design 335.5 gl	Actual 315.5 gl	To Add: 20.0 gl		
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl	/ Load	Trim Water: -1.8 gl	/ yd	Note: Manual feed occurred		

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 W-GRAND BLVD 				TICKET CODE: 2204110 DATE: 07/22/20	
DRIVER INSTRUCTION: ON W GRAND BLVD BTW GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!							MAP PAGE: DT4344C2	TIME: 8:44	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	226	ROBERT ROBINSON	4838	33.01	20.00	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		9.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.	GRADE OF CONC.			
GGFS:					COMPANY REPRESENTATIVE (signature) Joseph Yahi				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003					
INTERM AGG:					COLLECTED (circle one) CHECK CASH CREDIT				
FINE AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 4838	Driver ROROBINSON	User user	Disp 2204110	Ticket Num 2204110	Ticket ID 2204110	Time 8:44	Date 7/22/20
Load Size 9.00 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225814	
Material Batch:	Design Qty	SSD Start:	Adj.T End:	Required	Batched Time (hh:mm:ss):	% Var	%Moisture
L6AA-PIN	1810 lb	1810		16290 lb	16280 lb	-0.06%	
2NS-WLB	1230 lb	1230		11457 lb	11360 lb	-0.85%	3.50%
CMT1-CRHM	564.0 lb	564.0		5076.0 lb	5070.0 lb	-0.12%	
WAT1	30.5 gl	30.5	-20.0	194.2 gl	194.8 gl	0.35%	194.8 gl
OAE-BA	5.64 oz	5.64		53.30 oz	53.00 oz	-0.56%	
OMRLI-PR	39 oz	39		355 oz	352 oz	-0.93%	
Actual		Num Batches: 1					
Load	34361 lb	Design W/C: 0.451	Water/Cement: 0.452	A	Design 274.5 gl	Actual 240.9 gl	To Add: 33.6 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: -20.0	gl / Load	Trim Water: -1.5	gl / yd	

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: 449792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 W-GRAND BLVD <i>(Signature)</i>				TICKET CODE: 2204119 DATE: 07/22/20	
DRIVER INSTRUCTION: ON W GRAND BLVD BTW GRAND RIVER AND LINWOOD **** NO CITY SLIP!!!!						MAP PAGE: DT4344C2		TIME: 10:03	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	226	RANDY REGISTER	4836	33.01	27.50	5.00 in	6.00	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		7.50	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit		MDOT PLANT NO.		GRADE OF CONC.
GGGFS:									
FLY ASH:							COMPANY REPRESENTATIVE (signature)		
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		<i>(Signature)</i> COLLECTED (circle one)		CHECK CASH CREDIT
INTERM AGG:									
FINE AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck 4836	Driver RAREGISTER	User user	Disp Ticket Num 2204119	Ticket ID 2204119	Time 10:03	Date 7/22/20			
Load Size 7.50 yd	Mix Code P1-DETM	Returned	Qty	Mix Age	Seq 2W	Load ID 225823			
Material Batch:	Design Qty	SSD Start:	Adj.T End:	Required	Batched Time (hh:mm:ss):	% Var : 00 : 01 : 38	%Moisture	Actual Wat	Trim
L6AA-PIN	1810 lb	1810		13575 lb	13520 lb	-0.41%			
2NS-WLB	1230 lb	1230		9594 lb	9520 lb	-0.77%	4.00%	44 gl	
CMT1-CRHM	564.0 lb	564.0		4230.0 lb	4210.0 lb	-0.47%			
WAT1	30.5 gl	30.5		169.2 gl	169.9 gl	0.43%		169.9 gl	-2.0 gl
OAE-BA	5.64 oz	5.64		44.42 oz	44.00 oz	-0.93%			105.00 %
OMRLI-PR	39 oz	39		296 oz	296 oz	-0.03%			
Actual	Num Batches: 1								
Load	28689 lb	Design W/C: 0.451	Water/Cement: 0.453	A	Design	228.8 gl	Actual	213.8 gl	To Add: 15.0 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl	/ Load	Trim Water:	-2.0 gl / yd			



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>
PROJECT: <u>Detroit PW-7018</u>
CONTRACTOR: <u>Westside Concrete</u>
CONCRETE SUPPLIER & CITY: <u>McCoy - Springwell St - Detroit</u>
WEATHER: A.M. <u>72° Cloudy</u> P.M.
AGGREGATE CORRECTION FACTOR: <u>1.2</u>

D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>7-22-20</u>
INSPECTOR: <u>Jackie Richards</u> #01362857	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER:	
TIME ARRIVED: <u>7:50</u> SCHEDULED ARRIVAL TIME: <u>8:00</u> TIME LEFT SITE: <u>9:20</u>	

Pour Description: Sidewalks on W. Grand blvd
going Eastbound - btwn Grandriver & Linwood Ave

Mix Design: P1-DEYM Quantity Placed (yd³): 11.0 Lot Number: — Sublot: —

Grade of Concrete: P1 Batch Quantity (yd³): 11.0 Pour Start: 8:30 Pour End: 9:20

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
3726	2204097	7:31	8:30	9:20	4 1/2"	72°	83°	6.2	139.6	1.019	001-4

REMARKS

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: #1 V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 14138816 DATE: 07/23/20	
DRIVER INSTRUCTION: ON SHERWOOD AT THE CORNER OF NEVADA WEST OF VAN DYKE						MAP PAGE: DT4201E7		TIME: 13:25	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1416	CHARLES MORRIS	4808	15.50	8.00	5.00 in	6.00	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		8.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGFBS; FLY ASH:	CNT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
					M-24				
COARSE AGG	L6AA-PIN	6AAL PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley D. Dmishowski</i>				
INTERM AGG									
FINE AGG:	2NS-SMR	2NS - SPRING HILL RECLAMATIO		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE X			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4808	CHMORRISON	user	14138816	14138816	13:25	7/23/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.00 yd	P1-DETM				D	138133

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	14480 lb	14480 lb	-0.14%	4.00% M	47 gl	189.0 gl
2NS-SMR	1230 lb	10234 lb	10280 lb	0.45%			
CMT1-LAA	584 lb	4512 lb	4520 lb	0.18%			
WAT1	30.5 gl	188.8 gl	189.0 gl	0.09%			
QAE-BA	5.84 oz	69.94 oz	69.60 oz	-0.62%			
OMRI-PR	39.48 oz	315.84 oz	316.00 oz	0.05%			

Actual		Num Batches: 1					
Load	30861 lb	Design W/C:	0.451	Water/Cement:	0.451	T	
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.0 gl / yd

Design 244.0 gl Actual 236.4 gl To Add: 7.6 gl

MCCOIG MATERIALS
23055 Groesbeck Hwy. Warren, MI 48089

PHONE: (586) 775-7200

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)


- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368 MI				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 (1455)				TICKET CODE: 14138823 DATE: 07/23/20	
DRIVER INSTRUCTION: ON SHERWOOD AT THE CORNER OF NEVADA WEST OF VAN DYKE						MAP PAGE: DT4201E6 TIME: 14:27			
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	1416	MARK MALIK	4826	16.00	16.00	5.00 in	6.00	14	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM		8.00	yd	CITY OF DETROIT P1 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:				M-24					
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AAL PORT INLAND	71-003	COMPANY REPRESENTATIVE (signature) 		COLLECTED (circle one) CHECK CASH CREDIT			
INTERM AGG:	2NS-SMR	2NS - SPRING MILL RECLAMATIO	47-003						
FINE AGG:									
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket	Num	Ticket ID	Time	Date
4826	MAMALIK	user	14138823			14138823	14:27	7/23/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID		
8.00 yd	P1-DETM				D	138140		

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	14480 lb	14480 lb	-0.14%			
2NS-SMR	1230 lb	10234 lb	10240 lb	0.06%	4.00% M	47 gl	
CMT1-LAA	584 lb	4512 lb	4495 lb	-0.38%			
WAT1	30.5 gl	188.8 gl	188.0 gl	-0.44%		188.0 gl	
0AE-BA	5.84 oz	69.94 oz	70.50 oz	0.81%			
OMRLI-PR	39.48 oz	315.84 oz	316.00 oz	0.05%			

Actual	Num Batches: 1						
Load	30788 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	244.0 gl	Actual 235.2 gl To Add: 8.8 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-1.0 gl / yd	



DRISENGA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>1020525.4A</u>	DATE: <u>7-23-2020</u>
PROJECT: <u>Detroit PW-7018</u>	INSPECTOR: <u>ZACH 130W</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>PROJIE MATHEWS, Warren</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. P.M. <u>10:11/5.m/</u>	TIME ARRIVED: <u>11:30.m</u> SCHEDULED ARRIVAL TIME: <u>1:30</u> TIME LEFT SITE: <u>4:00</u>	
AGGREGATE CORRECTION FACTOR: <u>.2</u>		

Pour Description: Curb and gutter/s below along Sherwood St at intersections, Sherwood St and E Woodward St / Sherwood St and E Woodward St.

Mix Design: P1-Detm Quantity Placed (yd³): _____ Lot Number: 1 Sublot: 1

Grade of Concrete: P1 Batch Quantity (yd³): 80 yds Pour Start: 2:25 Pour End: N/A

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
1808	14138816	1:25	2:25	2:40	3 1/2	79	88	5.9	147.250	989	2014041

REMARKS

- Mix contains MC - Informed Westside of retesting
NO 2A truck due to time limit, but pour
continue

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231320 DATE: 07/27/20	
DRIVER INSTRUCTION: CARPENTER AT THE SERVICE DR WEST OFF JOSEPH CAMPAU							MAP PAGE: DT4273A3	TIME: 9:26	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	123	MARK GROVE	2435	33.01	10.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 535 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Releng</i>				
INTERM AGG:					COLLECTED (circle one)				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2435	MAGROVE	user1	1231320	1231320	9:26	7/27/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	319211

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17820 lb	0.11%			
2NS-SMR	1350 lb	14040 lb	14000 lb	-0.28%	4.00% M	65 gl	
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-LA	184 lb	1840 lb	1860 lb	1.09%			
WAT1	28.4 gl	209.3 gl	210.0 gl	0.34%		210.0 gl	
OAE-BA	5 oz	121 oz	121 oz	0.02%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	38880 lb	Design W/C: 0.451	Water/Cement: 0.448	T	Design	284.0 gl	Actual	274.5 gl To Add: 9.5 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-1.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231343 DATE: 07/27/20	
DRIVER INSTRUCTION: CARPENTER AT THE SERVICE DR WEST OFF JOSEPH CAMPAU							MAP PAGE: DT4273A3	TIME: 11:48	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	123	ANTHONY OGLESBY	4800	33.01	16.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		6.00	yd	MDOT P1 535 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley J. [Signature]</i>				
INTERM AGG:		2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
FINE AGG:	2NS-SMR								
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	☒			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket	Num	Ticket ID	Time	Date
4800	ANOGLESBY	user1	1231343		1231343	11:48	7/27/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
6.00 yd	P1-SW				W2	319234	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	10680 lb	10680 lb	0.00%			
2NS-SMR	1350 lb	8424 lb	8400 lb	-0.28%	4.00% M	39 gl	
CMT1-LAA	342 lb	2052 lb	2050 lb	-0.10%			
CMGS-LA	184 lb	1104 lb	1100 lb	-0.36%			
WAT1	28.4 gl	125.6 gl	125.0 gl	-0.46%		125.0 gl	
OAE-BA	5 oz	76 oz	76 oz	-0.32%			
OWRA-PR	16 oz	95 oz	94 oz	-0.72%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	23284 lb	Design W/C:	0.451	Water/Cement:	0.451 T	Design	170.4 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Actual	163.7 gl
						To Add:	6.7 gl
						Trim Water:	-1.0 gl / yd

MCCOIG MATERIALS

1441 Springwells Ct. Detroit, MI 48209

PHONE: (734) 357-2124

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS			TICKET CODE: 2204420 DATE: 07/27/20	
DRIVER INSTRUCTION: FORREST AND TRUMBULL WEST OF THE LODGE SOUTH OF WARREN							MAP PAGE: DT4345A3	TIME: 14:57
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:
	123	DELAND GORDON	2440	26.00	26.00	3.00 in	6.50	2
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:
P1-SW		10.00	yd	MDOT P1 S35 WRA				
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.								
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		Detroit				
FLY ASH:				S. Chicago				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)			
INTERM AGG:					COLLECTED (circle one)			
FINE AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093	CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☒				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.		
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X		
						CUSTOMER SIGNATURE		
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.								
UNLOAD PROMPTLY: Excess time will be charged to the buyer.								

Truck 2440	Driver DEGORDON	User user	Disp Ticket Num 2204420	Ticket ID 2204420	Time 14:57	Date 7/27/20			
Load Size 10.00 yd	Mix Code P1-SW	Returned	Qty	Mix Age	Seq 3D	Load ID 226125			
Material Batch:	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
	1	Start: 14:57:55	End: 15:03:17	15:03:17	Time (hh:mm:ss): 00 : 05	00 : 22			
L6AA-PIN	1780 lb	1780		17800 lb	17680 lb	-0.67%			
2NS-WLB	1350 lb	1350		13905 lb	13840 lb	-0.47%	3.00%	48 gl	
CMT1-CRHM	342.0 lb	342.0		3420.0 lb	3410.0 lb	-0.29%			
CMGS-LA	184.0 lb	184.0		1840.0 lb	1840.0 lb				
WAT1	28.5 gl	28.5		211.1 gl	211.1 gl	0.04%		211.1 gl	-2.5 gl
0AE-BA	5.26 oz	5.26		84.16 oz	84.00 oz	-0.19%			160.00 %
OWRA-PR	15.78 oz	15.78		157.80 oz	156.00 oz	-1.14%			
Actual Num Batches: 1									
Load	38547 lb	Design W/C: 0.452	Water/Cement: 0.453	A	Design	285.0 gl	Actual	259.4 gl	To Add: 25.6 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl	/ Load	Trim Water:	-2.5 gl	/	yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>205052804</u>	DATE: <u>7-27-2016</u>
PROJECT: <u>Deloitte 2nd 7018</u>	INSPECTOR: <u>ALT # 01071546</u> <u>Dan Snyder</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>M-Co. 9</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>8:01 Sunny</u> P.M.	TIME ARRIVED: <u>9:15</u> SCHEDULED ARRIVAL TIME: <u>10:00am</u> TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2%</u>		

Pour Description: curb and gutter on Corporate St between Chrysler Service Drive & Lumber King Service

Mix Design: D-5W Quantity Placed (yd³): 3.12 Lot Number: Sublot:

Grade of Concrete: F1 Batch Quantity (yd³): 12 Pour Start: 9:30 Pour End: 10:25

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2035	173-320	9:16	9:20	9:25	3	82	85	6.5%			400

REMARKS

MCCOIG MATERIALS

1441 Springwells Ct. Detroit, MI 48209

PHONE: (734) 357-2124

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS			TICKET CODE: 2204480 DATE: 07/28/20	
DRIVER INSTRUCTION: FORREST AND TRUMBULL WEST OF THE LODGE, EAST OF ROSA PARKS							MAP PAGE: DT4345A3	TIME: 10:35
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:
	115	STEWART BURCHA	4820	33.01	11.00	5.00 in	6.50	2
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:
P1-SM-B2		11.00	yd	MDOT P1 S35 MR				
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.								
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		Detroit	MDOT PLANT NO.	GRADE OF CONC.		
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago				
FLY ASH:					COMPANY REPRESENTATIVE (signature)			
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COLLECTED (circle one) CHECK CASH CREDIT			
INTERM AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER B		81-093				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☒			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.		
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X <i>W. K. S. B.</i> CUSTOMER SIGNATURE		
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.								
UNLOAD PROMPTLY: Excess time will be charged to the buyer.								

Truck 4820	Driver STBURCHAM	User user	Disp Ticket Num 2204480	Ticket ID 2204480	Time 10:35	Date 7/28/20
Load Size 11.00 yd	Mix Code P1-SM-B2	Returned	Qty	Mix Age	Seq 2W	Load ID 226185

Material Batch:	Design Qty	SSD	Adj. T	Required	Batched	% Var	% Moisture	Actual Wat	Trim
	1	Start: 10:35:20	End:	10:37:42	Time (hh:mm:ss): 00 : 02 : 22				
L6AA-PIN	1780 lb	1780		19580 lb	19520 lb	-0.31%			
2NS-WLB	1350 lb	1350		15258 lb	15200 lb	-0.38%	2.75%	49 gl	
CMT1-CRHM	342.0 lb	342.0		3762.0 lb	3770.0 lb	0.21%			
CMGS-LA	184.0 lb	184.0		2024.0 lb	2040.0 lb	> 0.79%			
WAT1	28.4 gl	28.4		254.8 gl	253.6 gl	-0.47%		253.6 gl	-8 gl
OAE-BA	5.26 oz	5.26		75.22 oz	75.00 oz	-0.29%			130.00 %
OMRLI-PR	26 oz	26		289 oz	288 oz	-0.45%			

Actual Num Batches: 1

Load	42669 lb	Design W/C: 0.451	Water/Cement: 0.449	A	Design	312.4 gl	Actual	302.3 gl	To Add:	10.1 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl	/ Load	Trim Water:	-0.8 gl	/ yd			

MCCOIG MATERIALS

1441 Springwells Ct. Detroit, MI 48209

PHONE: (734) 357-2124

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS			TICKET CODE: 2204500 DATE: 07/28/20	
DRIVER INSTRUCTION: FORREST AND TRUMBULL WEST OF THE LODGE, EAST OF ROSA PARKS							MAP PAGE: DT4345A3	TIME: 12:30
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:
	115	RANDY REGISTER	4836	33.01	22.00	5.00 in	6.50	2
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:
P1-SM-B2		11.00	yd	MDOT P1 S35 MR				
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.								
CEMENT:	CMT1-CRHM	CEMENT T1 CRH - MISSISSAUGA		MDOT PLANT NO.	GRADE OF CONC.			
GGFBS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		Detroit				
FLY ASH:				S. Chicago				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)			
INTERM AGG:					COLLECTED (circle one)			
FINE AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER B		81-093	CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.		
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X		
						CUSTOMER SIGNATURE		
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.								
UNLOAD PROMPTLY: Excess time will be charged to the buyer.								

Truck 4836	Driver RAREGISTER	User user	Disp Ticket Num 2204500	Ticket ID 2204500	Time 12:30	Date 7/28/20
Load Size 11.00 yd	Mix Code P1-SM-B2	Returned	Qty	Mix Age	Seq 2W	Load ID 226205

Material Batch:	Design Qty	Start	SSD	Adj. T	Required	Batched	% Var	% Moisture	Actual Wat	Trim
L6AA-PIN	1780 lb	12:30:44	1780		19580 lb	19480 lb	-0.51%			
2NS-WLB	1350 lb		1350		15258 lb	15160 lb	-0.64%	2.75%	49 gl	
CMT1-CRHM	342.0 lb		342.0		3762.0 lb	3750.0 lb	-0.32%			
CMGS-LA	184.0 lb		184.0		2024.0 lb	2020.0 lb	-0.20%			
WAT1	28.4 gl		28.4		254.8 gl	254.3 gl	-0.19%		254.3 gl	-8 gl
0AE-BA	5.26 oz		5.26		75.22 oz	75.00 oz	-0.29%			130.00 %
OMRLI-PR	26 oz		26		289 oz	288 oz	-0.45%			

Actual Load	42555 lb	Design W/C:	0.451	Water/Cement:	0.452	A	Design	312.4 gl	Actual	302.9 gl	To Add:	9.5 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load		Trim Water:	-0.8 gl / yd				

MCCOIG MATERIALS

1441 Springwells Ct. Detroit, MI 48209

PHONE: (734) 357-2124

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

- 1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS			TICKET CODE: 2204527 DATE: 07/28/20	
DRIVER INSTRUCTION: FORREST AND TRUMBULL WEST OF THE LODGE, EAST OF ROSA PARKS							MAP PAGE: DT4345A3	TIME: 14:49
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:
	115	KYLE CHEESMAN	4822	33.01	33.00	5.00 in	6.50	2
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:
P1-SM-B2		11.00	yd	MDOT P1 535 MR				
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.								
CEMENT: GGBF: FLY ASH:	CMT1-CRHM CMGS-LA	CEMENT T1 CRH - MISSISSAUGA LAFARGE NORTH AMERICA GGBF		Detroit S. Chicago	MDOT PLANT NO.	GRADE OF CONC.		
COARSE AGG: INTERM AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)			COLLECTED (circle one)
FINE AGG:	2NS-WLB	2NS - WATERLAND BURMEISTER 8		81-093	X <i>Joseph Yahi</i>			CHECK CASH CREDIT
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.		
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X		
						CUSTOMER SIGNATURE		
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.								
UNLOAD PROMPTLY: Excess time will be charged to the buyer.								

Truck 4822	Driver KYCHEESMAN	User user	Disp Ticket Num 2204527	Ticket ID 2204527	Time 14:49	Date 7/28/20
Load Size 11.00 yd	Mix Code P1-SM-B2	Returned	Qty	Mix Age	Seq 2W	Load ID 226233

Material Batch:	Design Qty	Start:	SSD	Adj.T	Required	Batched	% Var	%Moisture	Actual Wat	Trim
L6AA-PIN	1780 lb	14:49:27	1780	End:	14:51:47	19580 lb	00 : 02			
2NS-WLB	1350 lb		1350			15221 lb	00 : 20	2.50%	44 gl	
CMT1-CRHM	342.0 lb		342.0			3762.0 lb		-0.32%		
CMGS-LA	184.0 lb		184.0			2024.0 lb		-0.20%		
WAT1	28.4 gl		28.4			259.2 gl		-0.33%	258.4 gl	-8 gl
0AE-BA	5.26 oz		5.26			75.22 oz		1.04%		130.00 %
0MR1-PR	26 oz		26			289 oz		-0.45%		

Actual Load	42589 lb	Design W/C:	0.451	Water/Cement:	0.452	A	Design	312.4 gl	Actual	302.6 gl	To Add:	9.9 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load		Trim Water:	-0.8 gl / yd				

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 2204536 DATE: 07/28/20	
DRIVER INSTRUCTION: FORREST AND TRUMBULL WEST OF THE LODGE, EAST OF ROSA PARKS							MAP PAGE: DT4345A3	TIME: 16:06	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	RANDALL GARVIN	3720	41.00	41.00	5.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM-B2		8.00	yd	MDOT P1 S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-CRHM CMGS-LA	CEMENT T1 CRH - MISSISSAUGA LAFARGE NORTH AMERICA GGBF		Detroit S. Chicago	MDOT PLANT NO. GRADE OF CONC.	COMPANY REPRESENTATIVE (signature) COLLECTED (circle one) CHECK CASH CREDIT			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-WLB	6AA - PORT INLAND 2NS - WATERLAND BURMEISTER 8		71-003 81-093	X <i>Joseph Yahi</i>				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP: 5	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT: 4:20	ARRIVE AT JOB: 4:35	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 3720	Driver RAGARVIN	User user	Disp 2204536	Ticket Num 2204536	Ticket ID 2204536	Time 16:06	Date 7/28/20
Load Size 8.00 yd	Mix Code P1-SM-B2	Returned	Qty	Mix Age	Seq 3D	Load ID 226242	
Material Batch:	Design Qty	SSD	Adj.T	Required	Batched	% Var	%Moisture
	1	Start: 16:06:58	End: 16:12:50	16:12:50	Time (hh:mm:ss): 00 : 05	00 : 52	
L6AA-PIN	1780 lb	1780		14240 lb	14160 lb	-0.56%	
2NS-WLB	1350 lb	1350		11070 lb	11000 lb	-0.63%	2.50%
CMT1-CRHM	342.0 lb	342.0		2736.0 lb	2740.0 lb	0.15%	
CMGS-LA	184.0 lb	184.0		1472.0 lb	1470.0 lb	-0.14%	
WAT1	28.4 gl	28.4		188.5 gl	188.6 gl	0.05%	188.6 gl
OAE-BA	5.26 oz	5.26		54.70 oz	55.00 oz	0.54%	
OMRLI-PR	26 oz	26		210 oz	212 oz	0.76%	
Actual	Num Batches: 1						
Load	30961 lb	Design W/C: 0.451	Water/Cement: 0.450	A	Design 227.2 gl	Actual 220.8 gl	To Add: 6.4 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl	/ Load	Trim Water: -0.8 gl	/ yd	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside Concrete</i>	D&A PROJECT NO.: <i>2020525.4A</i>	DATE: <i>7-28-20</i>
PROJECT: <i>Detroit PW-7018</i>	INSPECTOR: <i>Joe Kennedy 11265433</i>	
CONTRACTOR: <i>Westside Concrete</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>Mecig - Detroit</i>	PROJECT ENGINEER:	
WEATHER: A.M. <i>cloudy 85°</i> P.M.	TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE: <i>12:20pm</i>	
AGGREGATE CORRECTION FACTOR:		

Pour Description: *Various Submittal Locations on Westside Forest Ave.*

Mix Design: *P1-SM-62* Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____

Grade of Concrete: *F1* Batch Quantity (yd³): *33* Pour Start: _____ Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
<i>4820</i>	<i>204480</i>	<i>10:35</i>	<i>11:00</i>		<i>9 1/2</i>	<i>83</i>	<i>84</i>	<i>6.5</i>			<i>4/c</i>

REMARKS

All cylinders M.P.W.

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231688 DATE: 07/30/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF						MAP PAGE: DT4273A3		TIME: 7:25	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	126	STANFORD PENN	2352	33.01	11.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i>				
INTERM AGG:		2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) ☐				
FINE AGG:	2NS-SMR				CHECK CASH CREDIT ☒				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
2352	STPENN	user1	1231688	1231688	1231688	7:25	7/30/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-SW				W2	319584	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15258 lb	15220 lb	-0.25%	2.75% M	49 gl	
CMT1-LAA	342 lb	3762 lb	3780 lb	0.48%			
CMGS-LA	184 lb	2024 lb	2050 lb	1.28%			
WAT1	28.4 gl	241.5 gl	241.0 gl	-0.19%		241.0 gl	
OAE-BA	5 oz	139 oz	139 oz	-0.26%			
OWRA-PR	16 oz	174 oz	174 oz	0.24%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	42661 lb	Design W/C:	0.451	Water/Cement:	0.447 T	Design	312.4 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Actual	289.8 gl
						To Add:	22.6 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231707 DATE: 07/30/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273B3	TIME: 9:11	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	126	MARTY STARIN	4818	33.01	22.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) 				
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
					X				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4818	MASTARIN	user1	1231707	1231707	9:11	7/30/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SW				W2	319603

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15258 lb	15280 lb	0.14%	2.75% M	49 gl	
CMT1-LAA	342 lb	3762 lb	3780 lb	0.48%			
CMGS-LA	184 lb	2024 lb	2030 lb	0.30%			
WAT1	28.4 gl	263.5 gl	263.0 gl	-0.18%		263.0 gl	
OAE-BA	5 oz	142 oz	142 oz	0.17%			
OWRA-PR	16 oz	174 oz	173 oz	-0.33%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	42884 lb	Design W/C:	0.451	Water/Cement:	0.449	T	Design 312.4 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	Actual 312.0 gl To Add: 0.4 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231718 DATE: 07/30/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273B3	TIME: 10:40	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	126	STANFORD PENN	2352	33.01	33.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) 				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) X				
FINE AGG:					CHECK CASH CREDIT X				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2352	STPENN	user1	1231718	1231718	10:40	7/30/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SW				W2	319615

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15258 lb	15240 lb	-0.12%	2.75% M	49 gl	
CMT1-LAA	342 lb	3762 lb	3750 lb	-0.32%			
CMGS-LA	184 lb	2024 lb	2020 lb	-0.20%			
WAT1	28.4 gl	263.5 gl	263.0 gl	-0.18%		263.0 gl	
OAE-BA	5 oz	142 oz	142 oz	0.17%			
OWRA-PR	16 oz	174 oz	172 oz	-0.91%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	42804 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	312.4 gl	Actual 311.9 gl To Add: 0.5 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231752 DATE: 07/30/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OFF NORTHBOUND I-75 SERVICE DR NORTH OF CANIFF							MAP PAGE: DT4273B3	TIME: 13:43	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	126	MIKE JOHNSON	2402	43.00	43.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:					COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket	Num	Ticket ID	Time	Date
2402	MIJOHNSON	user1	1231752		1231752	13:43	7/30/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
10.00 yd	P1-SW				W2	319649	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13871 lb	13820 lb	-0.37%	2.75% M		44 gl
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
WAT1	28.4 gl	239.5 gl	240.0 gl	0.20%			240.0 gl
0AE-BA	5 oz	129 oz	128 oz	-0.68%			
0WRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	38901 lb	Design W/C: 0.451	Water/Cement: 0.451	A	Design	284.0 gl	Actual	284.3 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.0 gl / yd	To Add: 0.0 gl

UNLOAD PROMPTLY: Excess time will be charged to the buyer.



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside Concrete</i>	D&A PROJECT NO.: <i>2020525.4A</i>	DATE: <i>7-30-20</i>
PROJECT: <i>Detroit PW-7018</i>	INSPECTOR: <i>Joe Kennedy C1265983</i>	
CONTRACTOR: <i>Westside Concrete</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>McCoy Detroit</i>	PROJECT ENGINEER:	
WEATHER: A.M. <i>Sunny 71°F</i> P.M.	TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE: <i>8:45am</i>	
AGGREGATE CORRECTION FACTOR: <i>.2%</i>		

Pour Description: *Various curb locations on E.D. Carpenter*

Mix Design: *P1-SW* Quantity Placed (yd³): Lot Number: Sublot:

Grade of Concrete: *P1* Batch Quantity (yd³): Pour Start: *8:00am* Pour End:

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2352	12316886	7:25	8:00		2	71	54	5.5	1435	.9m	4/10

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231834 DATE: 07/31/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OF JOSEPH CAMPAU						MAP PAGE: DT4273C2		TIME: 11:15	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	138	STEVE JOHNSON	2600	10.00	10.00	1.50 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
					X	COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
						X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2600	STJOHNSON	user1	1231834	1231834	11:15	7/31/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319731

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	16800 lb	0.00%			
2NS-SMR	1490 lb	15273 lb	15220 lb	-0.34%	2.50% M	44 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
WAT1	26.5 gl	220.4 gl	220.0 gl	-0.16%		220.0 gl	
OAE-BA	5 oz	305 oz	306 oz	0.14%			
OWRA-PR	16 oz	158 oz	157 oz	-0.51%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	39125 lb	Design W/C: 0.420	Water/Cement: 0.422	T	Design	265.0 gl	Actual	264.5 gl To Add: 0.5 gl
Slump:	1.50 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	0.0 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1231869 DATE: 07/31/20	
DRIVER INSTRUCTION: EASTBOUND CARPENTER EAST OF JOSEPH CAMPAU						MAP PAGE: DT4273C3		TIME: 14:36	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	138	STEVE JOHNSON	2600	20.00	20.00	1.50 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SSFW		10.00	yd	MDOT P1 S35 SLIP FORM WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		71-003	COMPANY REPRESENTATIVE (signature) <i>Relay Thompson</i>				
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
					X	COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
					CUSTOMER SIGNATURE				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
2600	STJOHNSON	user1	1231869	1231869	14:36 7/31/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SSFW				W2	319766

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1680 lb	16800 lb	16800 lb	0.00%			
2NS-SMR	1490 lb	15273 lb	15200 lb	-0.47%	2.50% M	44 gl	
CMT1-LAA	342 lb	3420 lb	3450 lb	+ 0.88%			
CMGS-LA	184 lb	1840 lb	1840 lb	0.00%			
WAT1	26.5 gl	240.4 gl	240.0 gl	-0.15%		240.0 gl	
OAE-BA	5 oz	305 oz	305 oz	-0.03%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
HWATER	% #	gl	gl				

Actual Load	39322 lb	Design W/C:	0.420	Water/Cement:	0.449	A	Design	265.0 gl	Actual	284.4 gl	To Add:	0.0 gl
Slump:	1.50 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	2.0	gl / yd			

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

Actual	Num Batches: 1								
Load	42776 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	312.4 gl	Actual	312.3 gl	To Add: 0.1 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0	gl / Load	Trim Water:	0.0	gl / yd		



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>20200204A</u>	DATE: <u>7-31-20</u>
PROJECT: <u>Detroit PW-7018</u>	INSPECTOR: <u>Joe Kennedy CD#3928</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u>PW-7018</u>	
CONCRETE SUPPLIER & CITY: <u>McCaig - Detroit</u>	PROJECT ENGINEER:	
WEATHER: A.M. <u>Cloudy</u> P.M.	TIME ARRIVED: <u>9:00am</u> SCHEDULED ARRIVAL TIME: <u>7:00am</u> TIME LEFT SITE: <u>10:00am</u>	
AGGREGATE CORRECTION FACTOR: <u>.26</u>		

Pour Description: Various curb & sidewalk locations on Casspois St

Mix Design: P/SW Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____

Grade of Concrete: P1 Batch Quantity (yd³): _____ Pour Start: 9:50 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4612	123456	9:16	9:50		2		81	7.0			40C

REMARKS

