

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 TIREMAN ADA 1438				TICKET CODE: 1239994 DATE: 11/02/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF SOUTHFIELD							MAP PAGE: DT4341D3	TIME: 13:57	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	JOE CHAPP	2442	25.00	25.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SH		9.00	yd	MDOT P1 S35 WRA					
WS		9.00	yd	WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certify the concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF	S. CHICAGO	M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature)					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	75-005	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. WESTSIDE CONCRETE CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.						UNLOAD PROMPTLY: Excess time will be charged to the buyer.			

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2442	JOCHAPP	user1	1239994	1239994	13:57	11/2/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
9.00 yd	P1-SW				W2	327922

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	16020 lb	16020 lb	0.00%			
2NS-SMR	1350 lb	12836 lb	12800 lb	-0.28%	4.00% M	58 gl	
CMT1-LAA	342 lb	3078 lb	3070 lb	-0.26%			
CMGS-LA	184 lb	1658 lb	1680 lb	1.45%			
OWRA-PR	16 oz	142 oz	141 oz	-0.72%			
WAT1	28.4 gl	47.1 gl	47.0 gl	-0.19%		47.0 gl	
QAE-BA	5 oz	121 oz	121 oz	-0.18%			
HWATER	75 %	141 gl	141 gl	-0.19%		141 gl	

Actual	Num Batches: 1						
Load	34955 lb	Design W/C: 0.451	Water/Cement: 0.449 T	Design	255.6 gl	Actual	248.1 gl To Add: 9.5 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 TIREMAN ADE 1203 				TICKET CODE: 1239958 DATE: 11/02/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF SOUTHFIELD ---- CITY SLIP ----						MAP PAGE: TIME: 11:28			
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	BILL SEARS	4812	33.01	16.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		8.00 8.00	yd yd	MDOT P1 S35 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF	S. CHICAGO	M-11					
FLY ASH:									
COARSE AGG	L6AA-PIN	6AA - PORT INLAND	75-005	COMPANY REPRESENTATIVE (signature) X		COLLECTED (circle one) CHECK CASH CREDIT			
INTERM AGG	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
FINE AGG:									
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE _____			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4812	BISEARS	user1	1239958	1239958	11:28	11/2/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.00 yd	P1-SW				W2	327885

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11232 lb	11180 lb	-0.48%	4.00% M	52 gl	
CMT1-LAA	342 lb	2736 lb	2740 lb	0.15%			
CMGS-LA	184 lb	1472 lb	1480 lb	0.54%			
0WRA-PR	16 oz	126 oz	126 oz	-0.19%			
WAT1	28.4 gl	41.9 gl	42.0 gl	0.34%		42.0 gl	
QAE-BA	5 oz	107 oz	107 oz	-0.28%			
HWATER	75 %	128 gl	125 gl	-0.48%		125 gl	

Actual	Num Batches: 1						
Load	31048 lb	Design W/C: 0.451	Water/Cement: 0.449	T	Design	227.2 gl	Actual 218.5 gl To Add: 8.7 gl
Slump:	3.00 in	Water In Truck: 0.0 gl	Adjust Water: 0.0 gl	/ Load	Trim Water:	-1.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 TIREMAN ADA 6921				TICKET CODE 1239913 DATE 11/02/20	
DRIVER INSTRUCTION: ON TIREMAN WEST OF SOUTHFIELD ---- CITY SLIP ----							MAP PAGE TIME 8:35		
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	115	LORENZO HARRIS	2339	33.01	8.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		8.00 8.00	yd yd	MDOT P1 535 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GBFS:	CMGS-LA	LAFARGE NORTH AMERICA GBF	S. CHICAGO	M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature) Kelsey Tarabochi COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	75-005						
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
DRIVERS COMMENTS:									
				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2339	LOHARRIS	user1	1239913	1239913	8:35	11/2/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.00 yd	P1-SW				W2	327838

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11232 lb	11200 lb	-0.28%	4.00% M	52 gl	
CMT1-LAA	342 lb	2736 lb	2730 lb	-0.22%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
OWRA-PR	16 oz	126 oz	128 oz	-0.19%			
WAT1	28.4 gl	41.9 gl	42.0 gl	0.34%		42.0 gl	
OAE-BA	5 oz	99 oz	99 oz	0.11%			
HWATER	75 % #	126 gl	126 gl	0.34%		126 gl	

Actual		Num Batches: 1					
Load	31056 lb	Design W/C:	0.451	Water/Cement:	0.451 T	Design	227.2 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Actual	219.6 gl
						To Add:	7.6 gl
						Trim Water:	-1.0 gl / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240085 DATE: 11/03/20	
DRIVER INSTRUCTION: ON TIREMAN WEST OF EVERGREEN AT BURT						MAP PAGE: D7434103		TIME: 13:14	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	109	MARK GROVE	4824	33.01	28.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		10.00 10.00	yd yd	MDOT P1 S35 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) <i>Relay</i>				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
FINE AGG:					X				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
						X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4824	MAGROVE	user1	1240085	1240085	13:14	11/3/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	328015

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	14040 lb	13980 lb	-0.43%	4.00% M	64 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	51.7 gl	52.0 gl	0.58%		52.0 gl	
0AE-BA	5 oz	113 oz	113 oz	-0.08%			
HWATER	75 %	155 gl	155 gl	-0.06%		155 gl	

Actual		Num Batches: 1					
Load	38764 lb	Design W/C:	0.451	Water/Cement:	0.452	T	Design 284.0 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Actual 271.4 gl To Add: 12.8 gl
						Trim Water:	-1.3 gl / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240060 DATE: 11/03/20	
DRIVER INSTRUCTION: ON TIREMAN WEST OF EVERGREEN AT BURT						MAP PAGE: DT4341D3		TIME: 10:20	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	109	LARRY MOUNT	4815	33.01	18.00	3.00 in	6.50	1	
ITEM NAME: P1-SW WS		QUANTITY: 8.00 8.00	UOM: yd yd	DESCRIPTION: MDT P1 S35 WRA WINTER SERVICE CHARGES			UNIT PRICE:	EXTENDED:	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF	ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.				
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION	75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Relief J. [Signature]</i>			COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☒					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4815	LAMOUNT	user1	1240060	1240060	10:20	11/3/20

Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.00 yd	P1-SW				W2	327989

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14300 lb	0.42%			
2NS-SMR	1350 lb	11232 lb	11240 lb	0.07%	4.00% M	52 gl	
CMT1-LAA	342 lb	2736 lb	2730 lb	-0.22%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
OWRA-PR	16 oz	126 oz	126 oz	-0.19%			
WAT1	28.4 gl	40.4 gl	40.0 gl	-0.89%		40.0 gl	
OAE-BA	5 oz	90 oz	91 oz	0.03%			
HWATER	75 % #	121 gl	121 gl	-0.06%		121 gl	

Actual	Num Batches: 1							
Load	31097 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	227.2 gl	Actual	212.8 gl To Add: 14.4 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.8 gl / yd	

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240043 DATE: 11/03/20	
DRIVER INSTRUCTION: ON TIREMAN WEST OF EVERGREEN AT BURT								MAP PAGE: DT4341D3	TIME: 8:31
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	109	STANFORD PENN	6634	33.01	10.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		10.00 10.00	yd yd	MDOT P1 S35 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF		ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.		COLLECTED (circle one) CHECK CASH CREDIT	
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Kelley J. Matthews</i> X				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	14040 lb	14000 lb	-0.28%	4.00% M		65 gl
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	51.7 gl	51.0 gl	-1.35%			51.0 gl
OAE-BA	5 oz	103 oz	103 oz	0.42%			
HWATER	75 #	155 gl	155 gl	-0.06%			155 gl

Actual Load	38785 lb	Design W/C:	0.451	Water/Cement:	0.451	T	Design	284.0 gl	Actual	270.5 gl	To Add:	13.5 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	-1.3	gl / yd			



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Michigan Dept. of Transportation</u>
PROJECT: <u>2011-2012</u>
CONTRACTOR: <u>W/S & Co. Concrete</u>
CONCRETE SUPPLIER & CITY: <u>Mixing - Detroit</u>
WEATHER: <u>Clear</u> A.M. P.M.
AGGREGATE CORRECTION FACTOR: <u>0.0</u>

D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>11-3-2020</u>
INSPECTOR: <u>Patrick Drumm</u>	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: <u>Carol Detroit</u>	
TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE:	

Pour Description: 6" x 8" square slab on grade for driveway

Mix Design: P1-SU Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 33 Pour Start: 7:10 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
1034	102413	7:31	7:40	8:31	3	67.0	63	5.7	141.2	1.006	4 DCI

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240187 DATE: 11/04/20	
DRIVER INSTRUCTION: TIREMAN JUST WEST OF EVERGREEN ---- NO CITY SLIP ----						MAP PAGE: DT4341D3		TIME: 13:55	
P.O. NO.:	ORDER NO.: 106	DRIVER NAME: KEN LUCAS	TRUCK NO.: 4814	QTY. ORDERED: 33.01	QTY. DELIVERED: 20.00	DESIGN SLUMP: 3.00 in	DESIGNED AIR: 6.50	PLANT NO.: 1	
ITEM NAME: P1-SW WS		QUANTITY: 10.00 10.00	UOM: yd yd	DESCRIPTION: MDOT P1 S35 WRA WINTER SERVICE CHARGES			UNIT PRICE:	EXTENDED:	
Rejected - 2 test failed because of low Air Temp Concrete on site pass time allowed.									
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF	ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.				
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION	75-005 47-003	COMPANY REPRESENTATIVE (signature) 		COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4814	KELUCAS	user1	1240187	1240187	13:55	11/4/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	328119

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	14040 lb	13980 lb	-0.43%	4.00% M	64 gl	
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-LA	184 lb	1840 lb	1840 lb	0.00%			
OWRA-PR	16 oz	158 oz	157 oz	-0.51%			
WAT1	28.4 gl	53.6 gl	54.0 gl	0.80%		54.0 gl	
OAE-BA	5 oz	137 oz	137 oz	-0.19%			
HWATER	75 % #	161 gl	161 gl	0.18%		161 gl	

Actual		Num Batches: 1					
Load	38853 lb	Design W/C:	0.451	Water/Cement:	0.451 T	Design	284.0 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Actual	279.4 gl
						To Add:	4.6 gl
						Trim Water:	-0.5 gl / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240165 DATE: 11/04/20	
DRIVER INSTRUCTION: TIREMAN JUST WEST OF EVERGREEN ---- NO CITY SLIP ----						MAP PAGE: DT4341D3		TIME: 12:17	
P.O. NO.:	ORDER NO.: 106	DRIVER NAME: MIKE JOHNSON	TRUCK NO.: 2402	QTY. ORDERED: 33.01	QTY. DELIVERED: 10.00	DESIGN SLUMP: 3.00 in	DESIGNED AIR: 6.50	PLANT NO.: 1	
ITEM NAME: P1-SW WS		QUANTITY: 10.00 10.00	UOM: yd yd	DESCRIPTION: MDOT P1 S35 WRA WINTER SERVICE CHARGES			UNIT PRICE:	EXTENDED:	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF		ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Relay</i>		COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	☒			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2402	MIJOHNSON	user1	1240165	1240165	12:17	11/4/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	328098

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	14040 lb	13980 lb	-0.43%	4.00% M	64 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-LA	184 lb	1840 lb	1840 lb	0.00%			
OWRA-PR	16 oz	158 oz	157 oz	-0.51%			
WAT1	28.4 gl	52.3 gl	52.0 gl	-0.62%		52.0 gl	
0AE-BA	5 oz	137 oz	137 oz	-0.19%			
HWATER	75 % #	157 gl	157 gl	0.02%		157 gl	

Actual		Num Batches: 1							
Load	38792 lb	Design W/C:	0.451	Water/Cement:	0.451	T	Design	284.0 gl	Actual 273.4 gl To Add: 10.6 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	-1.0 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240147 DATE: 11/04/20	
DRIVER INSTRUCTION: TIREMAN JUST WEST OF EVERGREEN ---- NO CITY SLIP ----						MAP PAGE: DT4342B3		TIME: 10:34	
P.O. NO.:	ORDER NO.: 106	DRIVER NAME: WILLIE WEST	TRUCK NO.: 2403	QTY. ORDERED: 33.01	QTY. DELIVERED: 10.00	DESIGN SLUMP: 3.00 in	DESIGNED AIR: 6.50	PLANT NO.: 1	
ITEM NAME: P1-SW WS		QUANTITY: 10.00 10.00	UOM: yd yd	DESCRIPTION: MDOT P1 S35 WRA WINTER SERVICE CHARGES			UNIT PRICE:	EXTENDED:	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGGFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF	ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.				
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION	75-005 47-003	COMPANY REPRESENTATIVE (signature)  X		COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 2403	Driver WIWEST	User user1	Disp Ticket Num 1240147	Ticket ID 1240147	Time Date 10:34 11/4/20
Load Size 10.00 yd	Mix Code P1-SW	Returned	Qty	Mix Age W2	Seq 328080

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	14040 lb	14040 lb	0.00%	4.00% M	65 gl	
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	52.3 gl	52.0 gl	-0.62%		52.0 gl	
OAE-BA	5 oz	113 oz	113 oz	-0.08%			
HWATER	75 % #	157 gl	157 gl	0.02%		157 gl	

Actual		Num Batches: 1							
Load	38851 lb	Design W/C:	0.451	Water/Cement:	0.451	T	Design	284.0 gl	Actual 273.7 gl To Add: 10.3 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	-1.0 gl / yd	



**DRISENGA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete Co.</u>
PROJECT: <u>PW-7018 City of Detroit Major Roads</u>
CONTRACTOR: <u>West Side Concrete Co.</u>
CONCRETE SUPPLIER & CITY: <u>McCoy materials, Detroit</u>
WEATHER: A.M. <u>Sunny</u> P.M.
AGGREGATE CORRECTION FACTOR: <u>0.20</u>

D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>11-4-20</u>
INSPECTOR: <u>McKenna Boyer</u>	
CONTROL SECTION/MDOT JOB NO.:	
PROJECT ENGINEER: <u>City of Detroit</u>	
TIME ARRIVED: <u>10:20</u>	
SCHEDULED ARRIVAL TIME: <u>11:00</u>	
TIME LEFT SITE: <u>14:30</u>	

Pour Description: Side walk / curb South-West corner of Trenchant and Stout St.

Mix Design: P1-SW Quantity Placed (yd³): 33.01 Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 13:27 Pour End: 14:20

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2402	1240165	12:17	1:27	14:20	3 1/2	68	70	6.2	144.4	0.983	4/0/1

REMARKS

The mix was low on air and it was re-tested again, it was low again the second time. However, the 100% truck was finally re-tested because it was over time.

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240304 DATE: 11/05/20	
DRIVER INSTRUCTION: TIEMAN & EVERGEEEN							MAP PAGE: DT4341D3	TIME: 14:02	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	104	TAMIKO LEE	2350	33.01	30.00	2.50 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		10.00 10.00	yd yd	MDOT P1 535 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) <i>Relay</i>				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) ☒				
FINE AGG:					CHECK CASH CREDIT ☒				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2350	TALEE	user1	1240304	1240304	14:02	11/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	328237

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13973 lb	13920 lb	-0.38%	3.50% M		56 gl
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	52.5 gl	52.0 gl	-0.90%		52.0 gl	
OAE-BA	5 oz	139 oz	140 oz	0.08%			
HWATER	75 % #	157 gl	157 gl	-0.26%		157 gl	

Actual	Num Batches: 1						
Load	38733 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	284.0 gl	Actual	265.4 gl To Add: 18.6 gl
Slump:	2.50 in #	Water in Truck:	0.0 gl Adjust Water:	0.0 gl / Load	Trim Water:	-1.8 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240280 DATE: 11/05/20	
DRIVER INSTRUCTION: TIERMAN & EVERGEEEN						MAP PAGE: DT4341E3		TIME: 11:51	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	104	DARYLL MACDONALD	2434	33.01	20.00	2.50 in	6.50	1	
ITEM NAME: P1-SW WS		QUANTITY: 10.00 10.00	UOM: yd yd	DESCRIPTION: MDOT P1 S35 WRA WINTER SERVICE CHARGES			UNIT PRICE:	EXTENDED:	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF		ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG INTERM AGG FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Relief</i>		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
CUSTOMER SIGNATURE									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2434	DAMACDONAI	user1	1240280	1240280	11:51	11/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	328213

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13973 lb	13960 lb	-0.09%	3.50% M	57 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
0WRA-PR	16 oz	158 oz	159 oz	0.76%			
WAT1	28.4 gl	53.1 gl	53.0 gl	-0.18%		53.0 gl	
0AE-BA	5 oz	139 oz	139 oz	-0.28%			
HWATER	75 %	159 gl	159 gl	-0.18%		159 gl	

Actual Load		38788 lb		Design		284.0 gl		Actual		268.6 gl		To Add:		15.4 gl	
Slump:		2.50 in		Adjust Water:		0.0 gl / Load		Trim Water:		-1.5 gl / yd					

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1240242 DATE: 11/05/20	
DRIVER INSTRUCTION: TIEMAN & EVERGEEEN						MAP PAGE: DT4342B3		TIME: 8:23	
P.O. NO.:	ORDER NO.: 104	DRIVER NAME: ANTHONY WALKER	TRUCK NO.: 2352	QTY. ORDERED: 33.01	QTY. DELIVERED: 10.00	DESIGN SLUMP: 2.50 in	DESIGNED AIR: 6.50	PLANT NO.: 1	
ITEM NAME: P1-SW WS		QUANTITY: 10.00 10.00	UOM: yd yd	DESCRIPTION: MDOT P1 S35 WRA WINTER SERVICE CHARGES			UNIT PRICE:	EXTENDED:	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF		ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONC.		COLLECTED (circle one) CHECK CASH CREDIT	
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Relay</i> X				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket	Num	Ticket ID	Time	Date
2352	ANWALKER	user1	1240242			1240242	8:23	11/5/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID		
10.00 yd	P1-SW				W2	328174		

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13973 lb	13940 lb	-0.23%	3.50% M	56 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-LA	184 lb	1840 lb	1840 lb	0.00%			
OWRA-PR	16 oz	158 oz	159 oz	0.76%			
WAT1	28.4 gl	54.3 gl	54.0 gl	-0.63%		54.0 gl	
OAE-BA	5 oz	139 oz	140 oz	0.44%			
HWATER	75 % #	163 gl	163 gl	-0.02%		163 gl	

Actual	Num Batches: 1							
Load	38820 lb	Design W/C: 0.451	Water/Cement: 0.451	T	Design	284.0 gl	Actual	273.5 gl To Add: 10.5 gl
Slump:	2.50 in	#	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.0 gl / yd	



DRIESEN & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>11-5-2020</u>
PROJECT: <u>PW-7018</u>	INSPECTOR: <u>Jon Morris</u> <u>01293676</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.: <u>PW 7018</u>	
CONCRETE SUPPLIER & CITY: <u>McCaig Materials - 7 Mile</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>cloudy</u> P.M. <u>-</u>	TIME ARRIVED: <u>8:30AM</u> SCHEDULED ARRIVAL TIME: <u>8:30AM</u> TIME LEFT SITE: <u>10:45</u>	
AGGREGATE CORRECTION FACTOR: <u>.21</u>		

Pour Description: Curb & gutter + ADA Ramps + side walk multiple locations on fireman Ave from Stout to Ashton

Mix Design: pl-sw Quantity Placed (yd³): 33 Lot Number: _____ Sublot: _____
Grade of Concrete: pl Batch Quantity (yd³): 33 Pour Start: 9:20AM Pour End: 10:30

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2352	1240242	8:23	9:20	9:35	2in	59	65	5.8	140.4	1.002	4061

REMARKS

Mix pl-sw contained OAE-BA and OWRA-PR Admixtures

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 TIEMAN ADD'S 1400 WRS				TICKET CODE: 1240411 DATE: 11/06/20	
DRIVER INSTRUCTION: TIEMAN & EVERGREEN							MAP PAGE: DT4272B4	TIME: 13:26	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	125	JONATHAN STURD	4817	32.00	32.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		11.00 11.00	yd yd	MDOT P1 S35 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGBF		ALPENA S. CHICAGO	MDOT PLANT NO. M-11	GRADE OF CONG.			
COARSE AGG INTERM AGG FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) 		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.						UNLOAD PROMPTLY: Excess time will be charged to the buyer.			

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4817	JOSTURDIVA	user1	1240411	1240411	1240411	13:26	11/6/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
11.00 yd	P1-SW				W2	328344	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15370 lb	15300 lb	-0.45%	3.50% M	62 gl	
CMT1-LAA	342 lb	3782 lb	3750 lb	-0.32%			
CMGS-LA	184 lb	2024 lb	2000 lb	-1.18%			
OWRA-PR	18 oz	174 oz	174 oz	0.24%			
WAT1	28.4 gl	61.2 gl	61.0 gl	-0.25%		61.0 gl	
QAE-BA	5 oz	153 oz	154 oz	0.44%			
HWATER	75 % #	183 gl	184 gl	0.29%		184 gl	

Actual		Num Batches: 1					
Load	42695 lb	Design W/C:	0.451	Water/Cement:	0.453	T	
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	
		Design	312.4 gl	Actual	307.0 gl	To Add:	5.4 gl
					-0.5 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 TIERMAN DDA 0910 HRS 				TICKET CODE: 1240350 DATE: 11/06/20	
DRIVER INSTRUCTION: TIERMAN & EVERGEEEN						MAP PAGE: DT4341E3		TIME: 8:29	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	125	ANTHONY TAYLOR	2352	33.01	10.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW WS		10.00 10.00	yd yd	MDOT P1 S35 WRA WINTER SERVICE CHARGES					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) 		COLLECTED (circle one) ☐		
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:					X			☐ CHECK ☐ CASH ☐ CREDIT	
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2352	ANTAYLOR	user1	1240350	1240350	8:29	11/6/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	328283

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%	3.50% M		
2NS-SMR	1350 lb	13873 lb	13840 lb	-0.23%		58 gl	
CMT1-LAA	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-LA	184 lb	1840 lb	1820 lb	< -1.09%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	55.6 gl	56.0 gl	0.73%		56.0 gl	
OAE-BA	5 oz	139 oz	140 oz	0.08%			
HWATER	75 %	167 gl	168 gl	-0.47%		166 gl	

Actual	Num Batches: 1							
Load	38841 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	284.0 gl	Actual	278.5 gl To Add: 5.5 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-0.5 gl / yd		



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete Co.</u>	D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>11-6-2020</u>
PROJECT: <u>PW-7018 City of Detroit</u>	INSPECTOR: <u>McKehwon P. Bocrive</u>	
CONTRACTOR: <u>West Side Concrete Co.</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoig Materials Detroit</u>	PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
WEATHER: (A.M.) <u>Sunny</u> P.M.	TIME ARRIVED: <u>8:20</u> SCHEDULED ARRIVAL TIME: <u>9:00</u> TIME LEFT SITE: <u>11:05</u>	
AGGREGATE CORRECTION FACTOR: <u>0.70</u>		


Pour Description: Curband Side walk South-west and South-east corner of Tiremanot/Warwick St

Mix Design: P1-Sw Quantity Placed (yd³): 33.01 Lot Number: Sublot:
Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 9:25 Pour End: 10:45

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2352	1240350	8:29	9:25	11:10	3 1/4	52	67	7.0	142.0	1.012	4 PC1

REMARKS



1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 TIREMAN WEST OF SOUTHFIELD #2 TIREMAN ADD'S 1305 ALS 				TICKET CODE 817153 DATE: 11/09/20	
DRIVER INSTRUCTION: TIREMAN WEST OF SOUTHFIELD								MAP PAGE: 01A1	TIME: 12:32
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	169	DEFAULT, DEFAL	4816	33.01	20.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 535 WRA					
1015		1.00	EA	ENVIRONMENTAL SURCHARGE					
1030		10.00	PY	WINTER CHARGE					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF	S. CHICAGO	M-11					
FLY ASH:									
COARSE AGG:	L6AA-P1N	6AA - PORT INLAND	75-005	COMPANY REPRESENTATIVE (signature)					
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003	COLLECTED (circle one)					
				X	CHECK CASH CREDIT				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4816	0	user1	817153		817153	12:32	11/9/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
10.00 CY	P1-SW				W2	328533	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13973 lb	13920 lb	-0.38%	3.50% M		56 gl
CMT1-LAA	342 lb	3420 lb	3430 lb	0.29%			
CMGS-LA	184 lb	1840 lb	1830 lb	-0.54%			
WAT1	28.4 gl	232.4 gl	232.0 gl	-0.16%			232.0 gl
QAE-BA	5 oz	133 oz	133 oz	0.00%			
QWRA-PR	16 oz	158 oz	158 oz	0.00%			

Actual	Num Batches: 1									
Load	36934 lb	Design W/C: 0.451	Water/Cement: 0.458	A	Design	284.0 gl	Actual	288.4 gl	To Add:	0.0 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	0.5 gl / CY				



SRM CONCRETE
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133
(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 TIREMAN WEST OF SOUTHFIELD			#1 TIREMAN 4PO'S 0905 hrs 		TICKET CODE: 817103 DATE: 11/09/20	
DRIVER INSTRUCTION: TIREMAN WEST OF SOUTHFIELD							MAP PAGE: 01A1		TIME: 8:19	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:		
	169	DEFAULT, DEFAL	2435	33.01	10.00	3.00 in	6.50	1		
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:		
P1-SH 1015 1030		10.00 1.00 10.00	yd EA PY	MDOT P1 S35 WRA ENVIRONMENTAL SURCHARGE WINTER CHARGE						
MDOT 1158 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.										
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:	CMSS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11					
FLY ASH:										
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)			
INTERM AGG:										
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	X		CHECK CASH CREDIT			
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.				
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X				
						CUSTOMER SIGNATURE				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.										
UNLOAD PROMPTLY: Excess time will be charged to the buyer.										

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2435	0	user1	817103	817103	8:19	11/9/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 CY	P1-SW				W2	328483

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17880 lb	0.34%			
2NS-SMR	1350 lb	13973 lb	13920 lb	-0.38%	3.50% M	56 gl	
CMT1-LAA	342 lb	3420 lb	3420 lb	0.00%			
CMGS-LA	184 lb	1840 lb	1820 lb	-1.08%			
WAT1	28.4 gl	227.4 gl	227.0 gl	-0.17%		227.0 gl	
QAE-BA	5 oz	133 oz	133 oz	0.38%			
OWRA-PR	16 oz	158 oz	158 oz	0.00%			

Actual	Num Batches: 1							
Load	38933 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	284.0 gl	Actual	283.4 gl
Slump:	3.00 in	Water In Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trkm Water:	To Add:	0.6 gl



DRIESEN & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>WestSide</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>11-9-2020</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Jon Morris 01293676</u>	
CONTRACTOR: <u>WestSide</u>	CONTROL SECTION/MDOT JOB NO.: <u>Detroit 7018</u>	
CONCRETE SUPPLIER & CITY: <u>SEM concrete - 1 Mile</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>Sunny</u> P.M. <u> </u>	TIME ARRIVED: <u>8:30 AM</u> SCHEDULED ARRIVAL TIME: <u>8:30 AM</u> TIME LEFT SITE: <u>10:15 AM</u>	
AGGREGATE CORRECTION FACTOR: <u>2</u>		

Pour Description: curb + gutter + curb Radius + sidewalk on Tireman Ave multiple locations From Ashton Ave to Evergreen Rd

Mix Design: pl-SW Quantity Placed (yd³): 33 Lot Number: Sublot:
Grade of Concrete: 01 Batch Quantity (yd³): 33 Pour Start: 9:15 AM Pour End: 10:30 AM

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2135	817105	8:19	9:15	9:35	22	57	66	5.5	143.6	1.004	4QCI

REMARKS

Mix pl-SW contained OAE-BA and OURA-PA



SRM CONCRETE
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133
(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 TIREMAN WEST OF SOUTHFIELD				TICKET CODE: 817264 DATE: 11/10/20	
DRIVER INSTRUCTION: TIREMAN WEST OF SOUTHFIELD							MAP PAGE: 01A1	TIME: 11:07	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	169	DEFAULT, DEFAU	6634	11.00	11.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		3.00	yd	MDOT P1 S35 WRA					
1015		1.00	EA	ENVIRONMENTAL SURCHARGE					
SHRT		1.00	EA	SHORT LOAD					
1030		3.00	PY	WINTER CHARGE					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GBFS:	CMGS-LA	LAFARGE NORTH AMERICA GBF	S. CHICAGO	M-11					
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	75-005	COMPANY REPRESENTATIVE (signature)					
INTERM AGG:				X					
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003	COLLECTED (circle one)					
				CHECK CASH CREDIT					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
6634	0	user1		817264	817264	11:07	11/10/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
3.00 CY	P1-SW				W2	328644	

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	5340 lb	5340 lb	0.00%			
2NS-SMR	1350 lb	4182 lb	4200 lb	0.20%	3.50% M	17 gl	
CMT1-LAA	342 lb	1028 lb	1030 lb	0.39%			
CMGS-LA	184 lb	552 lb	530 lb	-3.99%			
WAT1	28.4 gl	23.2 gl	23.0 gl	-0.92%		23.0 gl	
OAE-BA	5 oz	42 oz	42 oz	-1.51%			
OWRA-PR	16 oz	47 oz	47 oz	-0.84%			

Actual	Num Batches:	1					
Load	11297 lb	Design W/C:	0.451	Water/Cement:	0.456 T	Design	85.2 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	-45.0 gl / Load	Trim Water:	0.0 gl / CY
						Actual	40.0 gl To Add: 45.2 gl



500 E. Seven Mile Rd. Detroit, MI 48203

PHONE: (313) 368-1133

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 TIREMAN WEST OF SOUTHFIELD				TICKET CODE: 817233 DATE: 11/10/20	
DRIVER INSTRUCTION: TIREMAN WEST OF SOUTHFIELD							MAP PAGE: 01A1	TIME: 8:21	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	169	OGLESBY, ANTHONY	4800	33.01	8.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		8.00	yd	MDOT P1 535 WRA					
1015		1.00	EA	ENVIRONMENTAL SURCHARGE					
1030		8.00	PY	WINTER CHARGE					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF	S. CHICAGO	M-11					
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	75-005	COMPANY REPRESENTATIVE (signature)			COLLECTED (circle one)		
INTERM AGG:				Relief					
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003	X			CHECK CASH CREDIT		
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket	Num	Ticket	ID	Time	Date	
4800	8447	user1	817233			817233		8:21	11/10/20	
Load	Size	Mix	Code	Returned	Qty	Mix	Age	Seq	Load	ID
8.00	CY	P1-SW						W2	328613	

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14300 lb	0.42%			
2NS-SMR	1350 lb	11178 lb	11140 lb	-0.34%	3.50% M		45 gl
CMT1-LAA	342 lb	2736 lb	2730 lb	-0.22%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
WAT1	28.4 gl	185.9 gl	186.0 gl	0.05%		186.0 gl	
0AE-BA	5 oz	112 oz	112 oz	-0.32%			
0WRA-PR	16 oz	126 oz	127 oz	0.47%			

Actual		Num Batches:		1								
Load	31207 lb	Design W/C:	0.451	Water/Cement:	0.459	A	Design	227.2 gl	Actual	231.1 gl	To Add:	0.0 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	0.5	gl / CY			



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>	D&A PROJECT NO.: <u>20205254A</u>	DATE: <u>11-10-20</u>
PROJECT: <u>PW-7018 CITY OF DETROIT MAJOR ROADS</u>	INSPECTOR: <u>McKerwan Boagwe</u>	
CONTRACTOR: <u>West Side Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCaigman Detroit</u>	PROJECT ENGINEER: <u>CITY OF DETROIT</u>	
WEATHER: A.M. <u>mo & 11 cloud</u> P.M.	TIME ARRIVED: <u>830</u>	
AGGREGATE CORRECTION FACTOR: <u>0.20</u>	SCHEDULED ARRIVAL TIME: <u>900</u>	
	TIME LEFT SITE: <u>10:30</u>	

Pour Description: Side walk curb and Adm Ramp South-West
and South-East corner of Tireman St / Penrod St

Mix Design: P1Sw Quantity Placed (yd³): 33.01 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 33.01 Pour Start: 9:05 Pour End: 10:30

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4800	817233	8:21	9:05	10:30	4 3/4	65	67	7.1	1420	1017	40c1

REMARKS



SRM CONCRETE
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 FORREST AND TRUMBULL				TICKET CODE: 817833 DATE 11/18/20	
DRIVER INSTRUCTION: ON FOREST EAST OF TRUMBULL ----- NO CITY SLIP NEEDED -----							MAP PAGE: 01A1	TIME: 12:33	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	176	MURFF, CHRISTO	2446	11.10	11.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETH 1015 1030		11.00 1.00 11.00	yd EA PY	CITY OF DETROIT P1 MR ENVIRONMENTAL SURCHARGE WINTER CHARGE					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CNT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONG.			
GGGFS:					M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:	2NS-SMR	2NS SPRING HILL RECLAMATION		47-003					
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2446	8446	user1	817833	817833	12:33	11/18/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 CY	P1-DETM				W2	329213

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	19910 lb	19900 lb	-0.05%	4.00% M	65 gl	
2NS-SMR	1230 lb	14071 lb	14020 lb	-0.36%			
CMT1-LAA	564 lb	6204 lb	6180 lb	-0.39%			
WAT1	30.5 gl	.0 gl	.0 gl				
OMRLI-PR	40 oz	435 oz	436 oz	0.35%			
QAE-PR	5.60 oz	123.20 oz	122.00 oz	-0.97%			
HWATER	100 %	257 gl	257 gl	0.04%		257 gl	

Actual	Num Batches: 1						
Load	42280 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	335.5 gl	Actual 321.6 gl To Add: 13.9 gl
Slump:	5.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.3 gl / CY	



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West side concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>11-18-20</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Eric Morris #01396263</u>	
CONTRACTOR: <u>West side concrete</u>	CONTROL SECTION/MDOT JOB NO.: _____	
CONCRETE SUPPLIER & CITY: <u>McCaig materials - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. _____ P.M. <u>clear</u>	TIME ARRIVED: <u>12:00</u> SCHEDULED ARRIVAL TIME: <u>12:30</u> TIME LEFT SITE: _____	
AGGREGATE CORRECTION FACTOR: <u>0.2%</u>		

Pour Description: Side walk + ADA Ramps on Forest ave at Lincoln st
curb

Mix Design: P1-PTM Quantity Placed (yd³): 11 Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 11 Pour Start: 1:00 Pour End: 1:45

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2446	817833	12:33	1:00	1:45	5 1/2	29	66	7.6	1428	.995	40.1

REMARKS



SRM CONCRETE
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 WYOMING #2 WYOMING DRIVE FOREST ADA'S 1320 WRS (90)				TICKET CODE: 817943 DATE: 11/19/20		
DRIVER INSTRUCTION: ON WYOMING SOUTH OF 8 MILE RD---- CITY SLIP -----							MAP PAGE: 01A1		TIME: 12:55	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:		
	176	PENN, STANFORD	6634	33.01	19.00	5.00 in	6.00	1		
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:		
P1-DETM 1015 1030		9.00 1.00 9.00	yd EA PY	CITY OF DETROIT P1 MR ENVIRONMENTAL SURCHARGE WINTER CHARGE						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.										
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO.	GRADE OF CONC.					
GGGFS:				M-11						
FLY ASH:				COMPANY REPRESENTATIVE (signature)						
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	75-005	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT						
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003							
FINE AGG:										
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐						
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.				
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X				
						CUSTOMER SIGNATURE				
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.										

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
6634	8448	user1	817943	817943	12:55 11/19/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
9.00 CY	P1-DETM			W2	329322

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1810 lb	18290 lb	16280 lb	-0.06%	4.00% M		
2NS-SMR	1230 lb	11513 lb	11460 lb	-0.46%		53 gl	
CMT1-LAA	584 lb	5076 lb	5070 lb	-0.12%			
WAT1	30.5 gl	42.5 gl	43.0 gl	1.21%		43.0 gl	
OMRLI-PR	40 oz	356 oz	352 oz	-0.98%			
QAE-PR	5.60 oz	100.80 oz	100.00 oz	-0.79%			
HWATER	80 % #	170 gl	170 gl	0.03%		170 gl	

Actual	Num Batches: 1						
Load	34816 lb	Design W/C: 0.451	Water/Cement: 0.452 T	Design	274.5 gl	Actual	285.8 gl To Add: 8.7 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.0 gl / CY



SRM CONCRETE
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 FORREST AND TRUMBULL				TICKET CODE: 817908 DATE: 11/19/20	
DRIVER INSTRUCTION: ON FORREST EAST OF TRUMBULL-----							MAP PAGE: 01A1	TIME: 9:23	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	176	WEST JR, WILLI	2403	33.01	10.00	5.00 in	6.00	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-DETM 1015 1030		10.00 1.00 10.00	yd EA PY	CITY OF DETROIT P1 MR ENVIRONMENTAL SURCHARGE WINTER CHARGE					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA	ALPENA	MDOT PLANT NO. M-11	GRADE OF CONC.				
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION	75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Rekey Thompson</i>		COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AT:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2403	8455	user1	817908	817908	9:23	11/19/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 CY	P1-DETM				W2	329287

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
LBAA-PIN	1810 lb	18100 lb	18100 lb	0.00%			
2NS-SMR	1230 lb	12792 lb	12760 lb	-0.25%	4.00% M	59 gl	
CMT1-LAA	564 lb	5840 lb	5620 lb	-0.35%			
WAT1	30.5 gl	45.2 gl	45.0 gl	-0.46%		45.0 gl	
OMRLI-PR	40 oz	395 oz	398 oz	0.25%			
OAE-PR	5.60 oz	112.00 oz	112.00 oz	0.00%			
HWATER	80 %	181 gl	181 gl	0.00%		181 gl	

Actual	Num Batches: 1						
Load	38398 lb	Design W/C: 0.451	Water/Cement: 0.453	T	Design	305.0 gl	Actual 284.8 gl To Add: 20.2 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-2.0 gl / CY



DRIESEN & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside Concrete</i>	D&A PROJECT NO.: <i>2020525.4A</i>	DATE: <i>11-19-20</i>
PROJECT: <i>detroit - pw</i>	INSPECTOR: <i>Sae Kennedy 01268983</i>	
CONTRACTOR: <i>Westside Concrete</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>SRM Concrete Detroit</i>	PROJECT ENGINEER:	
WEATHER: A.M. <i>44°F/51°F</i> P.M.	TIME ARRIVED: <i>8:30am</i> SCHEDULED ARRIVAL TIME: <i>8:30am</i> TIME LEFT SITE: <i>10:30am</i>	
AGGREGATE CORRECTION FACTOR: <i>12%</i>		

Pour Description: *Various curb & sidewalk locations on Forest Ave*

Mix Design: *P1-detroit* Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: *P1* Batch Quantity (yd³): _____ Pour Start: *9:50am* Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2403	617908	9:23	9:50		4	51	64	6.0	143.1	1.6m	4or

REMARKS

Mix contains air



SRM CONCRETE
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 83276 WESTSIDE CONCRETE CO.				SHIP TO: 2 FOREST AND TRUMBULL				TICKET CODE: 818012 DATE: 11/20/20									
DRIVER INSTRUCTION: ON FOREST EAST OF TRUMBULL *****							MAP PAGE: 01A1		TIME: 8:34								
PO. NO.:		ORDER NO.:		DRIVER NAME:		TRUCK NO.:		QTY. ORDERED:		QTY. DELIVERED:		DESIGN SLUMP:		DESIGNED AIR:		PLANT NO.:	
		176		WALKER, ANTHON		2352		5.00		5.00		5.00 in		6.00		1	
ITEM NAME:			QUANTITY:		UOM:		DESCRIPTION:					UNIT PRICE:		EXTENDED:			
P1-DETH 1015 SHRT 1030			5.00		yd		CITY OF DETROIT P1 MR ENVIRONMENTAL SURCHARGE SHORT LOAD WINTER CHARGE										
			1.00		EA												
			1.00		EA												
			5.00		PY												
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.																	
CEMENT:		CMT1-LAA		CEMENT T1 LAFARGE ALPENA				ALPENA		MDOT PLANT NO.		GRADE OF CONC.		COLLECTED (circle one) CHECK CASH CREDIT			
GGGFS:										H-11							
FLY ASH:																	
COARSE AGG:		L6AA-PIN		6AA - PORT INLAND				75-005		COMPANY REPRESENTATIVE (signature)							
INTERM AGG:																	
FINE AGG:		2NS-SMR		2NS SPRING MILL RECLAMATION				47-003		X							
DRIVERS COMMENTS:										Customer Requested Ticket Before Discharge Completed ☐							
INITIAL SLUMP:		WATER ADDED:		REQUESTED BY:		FINAL SLUMP:		TESTED AIR:		REVOLUTIONS:		I've read and agreed to the terms on the back side of this delivery ticket.					
LEAVE PLANT:		ARRIVE AT JOB:		START POUR:		FINISH POUR:		LEAVE JOB:		ARRIVE PLANT:		X					
												CUSTOMER SIGNATURE					
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.																	

Truck	Driver	User	Disp Ticket	Num	Ticket ID	Time	Date
2352	8453	user1	818012		818012	8:34	11/20/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
5.00 CY	P1-DETM				W2	329390	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
LSAA-PIN	1810 lb	9050 lb	9040 lb	-0.11%	4.00% M		
2NS-SMR	1230 lb	6396 lb	6420 lb	0.38%		30 gl	
CMT1-LAA	564 lb	2820 lb	2830 lb	0.35%			
WAT1	30.5 gl	23.4 gl	23.0 gl	-1.52%		23.0 gl	
OMRLI-PR	40 oz	198 oz	196 oz	-0.78%			
QAE-PR	5.60 oz	56.00 oz	55.00 oz	-1.79%			
HWATER	80 %	93 gl	93 gl	-0.45%		93 gl	

Actual	Num Batches:	1					
Load	19274 lb	Design W/C:	0.451	Water/Cement:	0.450 T	Design	152.5 gl
Skump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Actual	145.6 gl
						To Add:	6.9 gl
						Trim Water:	-1.3 gl / CY



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <i>Westside</i>	D&A PROJECT NO.: <i>2020525-9A</i>	DATE: <i>11-26-2020</i>
PROJECT: <i>Radisson Rehab.</i>	INSPECTOR: <i>Tony Mann 1247630</i>	
CONTRACTOR: <i>Westside</i>	CONTROL SECTION/MDOT JOB NO.: <i>PW-7018</i>	
CONCRETE SUPPLIER & CITY: <i>SMR Concrete Detroit</i>	PROJECT ENGINEER: <i>City of Detroit</i>	
WEATHER: A.M. <i>Sunny</i> P.M.	TIME ARRIVED: <i>8:30</i> SCHEDULED ARRIVAL TIME: <i>9:00</i> TIME LEFT SITE: <i>9:15</i>	
AGGREGATE CORRECTION FACTOR:		

Pour Description: *patching side walk in various locations of Forest*

Mix Design: *Detm* Quantity Placed (yd³): *5* Lot Number: Sublot:
Grade of Concrete: *91* Batch Quantity (yd³): *5* Pour Start: *9:10* Pour End: *9:11*

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2352	818010	8:34	9:00	9:40	4	55	68	5.5	146.4	1711	4

REMARKS