

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1238486 DATE: 10/15/20	
DRIVER INSTRUCTION: CARPENTER AND NB I 75 SERVICE DR // NORTH OF CANIFF							MAP PAGE: DT4273A3	TIME: 14:48	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	WILLIE WEST	2403	30.00	30.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-AGM	CRH CEMENT MISSISSAUGA		MISSISSAUGA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-AGD	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) <i>Reber J. Thompson</i> COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2403	WIWEST	user1	1238486	1238486	14:48	10/15/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	326404

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13838 lb	13780 lb	-0.42%	2.50% M	40 gl	
CMT1-AGM	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-AGD	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	228.6 gl	229.0 gl	0.19%		229.0 gl	
OAE-BA	5 oz	110 oz	110 oz	-0.42%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	38748 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	284.0 gl	Actual 269.3 gl To Add: 14.7 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-1.5 gl / yd	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI, 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1238459 DATE 10/15/20	
DRIVER INSTRUCTION: CARPENTER AND NB I 75 SERVICE DR // NORTH OF CANIFF							MAP PAGE: DT4273A3	TIME: 12:06	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	DARYLL MACDONA	4824	33.01	20.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-5W		10.00	yd	MDOT P1 535 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-AGM	CRH CEMENT MISSISSAUGA	MISSISSAUGA	MDOT PLANT NO.	GRADE OF CONC.				
GBBFS:	CMGS-AGD	SLAG CEMENT ST MARYS CEMENT	DETROIT	M-11					
FLY ASH:				COMPANY REPRESENTATIVE (signature)					
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND	75-005	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT					
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION	47-003						
FINE AGG:									
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed. ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE _____			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4824	DAMACDONAI	user1	1238459	1238459	12:06	10/15/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	326377

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13838 lb	13780 lb	-0.42%	2.50% M	40 gl	
CMT1-AGM	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-AGD	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	157 oz	-0.51%			
WAT1	28.4 gl	228.6 gl	229.0 gl	0.19%		229.0 gl	
OAE-BA	5 oz	110 oz	111 oz	0.49%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	38748 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	284.0 gl	Actual 269.3 gl To Add: 14.7 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-1.5 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1238414 DATE: 10/15/20	
DRIVER INSTRUCTION: CARPENTER AND NB I 75 SERVICE DR // NORTH OF CANIFF							MAP PAGE:	TIME: 7:28	
P.O. NO.:	ORDER NO.: 107	DRIVER NAME: LARRY MOUNT	TRUCK NO.: 4815	QTY. ORDERED: 33.01	QTY. DELIVERED: 10.00	DESIGN SLUMP: 3.00 in	DESIGNED AIR: 6.50	PLANT NO.: 1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH:	CMT1-AGM CMGS-AGD	CRH CEMENT MISSISSAUGA SLAG CEMENT ST MARYS CEMENT		MISSISSAUGA DETROIT	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Kelley Frankowski</i>		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
4815	LAMOUNT	user1	1238414	1238414	7:28	10/15/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	326338

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13838 lb	13800 lb	-0.27%	2.50% M	40 gl	
CMT1-AGM	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-AGD	184 lb	1840 lb	1830 lb	-0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	228.6 gl	228.0 gl	-0.24%		228.0 gl	
OAE-BA	5 oz	110 oz	111 oz	0.04%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1			
Load	38759 lb	Design W/C:	0.451	Water/Cement:	0.452 T
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load
		Design	284.0 gl	Actual	268.3 gl
				To Add:	15.7 gl
				Trim Water:	-1.5 gl / yd



**DRISENGA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside</u>	D&A PROJECT NO.: <u>20205254A</u>	DATE: <u>10-15-10</u>
PROJECT: <u>Detroit PWS 7018</u>	INSPECTOR: <u>Jacelin Richards</u>	# <u>01367857</u>
CONTRACTOR: <u>Westside</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoy 7 mi.</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>59° Cloudy</u> P.M.	TIME ARRIVED: <u>7:45</u> SCHEDULED ARRIVAL TIME: <u>8:00</u> TIME LEFT SITE: <u>8:35</u>	
AGGREGATE CORRECTION FACTOR: <u>2</u>		

Pour Description: sidewalks + curb on Carpenter going NE from F-75

Mix Design: P1 SW Quantity Placed (yd³): 100 Lot Number: — Sublot: —
Grade of Concrete: P1 Batch Quantity (yd³): 100 Pour Start: 8:05 Pour End: 8:35

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
4815	1238414	7:28	8:05		3"	59	66	62	140.8	1.019	WC-4

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: #3 CARPENTER ADA's 1500 HRS V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1238573 DATE: 10/16/20	
DRIVER INSTRUCTION: ON CARPENTER BETWEEN NB I-75 SERVICE DRIVE & CONANT							MAP PAGE: DT4273B3	TIME: 14:37	
RD. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	MIKE JOHNSON	1462	33.00	33.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1186 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-AGM	CRH CEMENT MISSISSAUGA		MISSISSAUGA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-AGD	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature)				
INTERM AGG:				47-003	<i>Relezy D. [Signature]</i>				
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION			COLLECTED (circle one)				
					CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			
						X			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
1462	MIJOHNSON	user1	1238573	1238573	14:37	10/16/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SW				W2	326491

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1760 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15180 lb	-0.40%	2.50% M	44 gl	
CMT1-AGM	342 lb	3762 lb	3750 lb	-0.32%			
CMGS-AGD	184 lb	2024 lb	2010 lb	-0.69%			
OWRA-PR	16 oz	174 oz	172 oz	-0.91%			
WAT1	26.4 gl	254.2 gl	254.0 gl	-0.06%		254.0 gl	
QAE-BA	5 oz	122 oz	122 oz	0.00%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	42638 lb	Design W/C:	0.451	Water/Cement:	0.453	T	
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.3 gl / yd
		Design	312.4 gl	Actual	298.3 gl	To Add:	14.1 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-701B MAJOR ROADS VARIOUS LOCATIONS #2 CARPENTER ADD 1215 HAS				TICKET CODE: 1238546 DATE: 10/16/20	
DRIVER INSTRUCTION: ON CARPENTER BETWEEN NB I-75 SERVICE DRIVE & CONANT							MAP PAGE: DT4273B3	TIME: 11:50	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	JOE CHAPP	2442	33.01	22.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-AGM	CRH CEMENT MISSISSAUGA		MISSISSAUGA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-AGD	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:					COMPANY REPRESENTATIVE (signature)				
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	Kelsey J. [Signature] COLLECTED (circle one)				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
FINE AGG:					CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	WESTSIDE CONCRETE CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2442	JOCHAPP	user1	1238546	1238546	11:50	10/16/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SW				W2	326464

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15180 lb	-0.27%	2.50% M	44 gi	
CMT1-AGM	342 lb	3762 lb	3750 lb	-0.32%			
CMGS-AGD	184 lb	2024 lb	2020 lb	-0.20%			
OWRA-PR	18 oz	174 oz	174 oz	0.24%			
WAT1	28.4 gi	204.2 gi	204.0 gi	-0.08%		204.0 gi	
OAE-BA	5 oz	122 oz	121 oz	-0.42%			
HWATER	% #	gi	gi				

Actual		Num Batches: 1					
Load	42251 lb	Design W/C:	0.451	Water/Cement:	0.452 T	Design	312.4 gi
Slump:	3.00 in	Water In Truck:	0.0 gi	Adjust Water:	-50.0 gi / Load	Actual	248.4 gi
						To Add:	64.0 gi
						Trim Water:	-1.3 gi / yd

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 CARPENTER</i> <i>ADA</i> <i>0053 HRS</i>				TICKET CODE: 1238518 DATE: 10/16/20	
DRIVER INSTRUCTION: ON CARPENTER BETWEEN NB I-75 SERVICE DRIVE & CONANT							MAP PAGE: .	TIME: 8:25	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	107	JAMAIN KIDD	2438	33.01	11.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		11.00	yd	MDOT P1 535 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-AGM	CRH CEMENT MISSISSAUGA		MISSISSAUGA	MDOT PLANT NO.	GRADE OF CONC.			
GGGFS:	CMGS-AGD	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) <i>Rehany J. Jankowski</i> COLLECTED (circle one) CHECK CASH CREDIT				
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE X			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2438	JAKIDD	user1	1238518	1238518	8:25	10/16/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
11.00 yd	P1-SW				W2	326436

Material	Design Qty	Required	Batched	% Var%	Moisture	Actual	Wat
L6AA-PIN	1780 lb	19580 lb	19580 lb	0.00%			
2NS-SMR	1350 lb	15221 lb	15180 lb	-0.27%	2.50% M	44 gl	
CMT1-AGM	342 lb	3762 lb	3780 lb	0.48%			
CMGS-AGD	184 lb	2024 lb	2020 lb	-0.20%			
OWRA-PR	16 oz	174 oz	173 oz	-0.33%			
WAT1	28.4 gl	251.4 gl	251.0 gl	-0.16%		251.0 gl	
OAE-BA	5 oz	122 oz	122 oz	0.00%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	42873 lb	Design W/C:	0.451	Water/Cement:	0.450	T	
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.5 gl / yd
		Design	312.4 gl	Actual	295.4 gl	To Add:	17.0 gl



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: Westside Concrete	D&A PROJECT NO.: 2020525.4A	DATE: 10/16/20
PROJECT: PW-7018 City of Detroit Major Roads	INSPECTOR: Matthew Mager	
CONTRACTOR: Westside Concrete	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: McGraw Materials - Detroit	PROJECT ENGINEER: City of Detroit	
WEATHER: A.M. Sunny P.M.	TIME ARRIVED: 9:15 am SCHEDULED ARRIVAL TIME: 9:15 am TIME LEFT SITE: 10:20 am	
AGGREGATE CORRECTION FACTOR: 0.29%		

Pour Description: Curb, gutter, and sidewalk sections at the intersection of
Carpenter St and Klinger St

Mix Design: P1-SW Quantity Placed (yd³): 11 Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 11 Pour Start: 9:15 Pour End: 10:20

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2438	1238518	8:25	9:15	10:20	1	39	60	4.2	—	—	—
2438	1238518	8:25	9:35	10:20	3.5	39	62	5.7	145.2	.489	4 CCI

REMARKS

★ See Corrective Action



**DRIESEN &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CORRECTIVE ACTION FORM

CONTRACTOR: Westside Concrete	D&A PROJECT NO.: 2020525.4A	DATE: 10/16/20
PROJECT: PU-7018 City of Detroit Major Roads	QUALITY CONTROL TECHNICIAN: Matthew Magee	
PROJECT ENGINEER: City of Detroit	CONTROL SECTION/MDOT JOB NO.: _____	

DESCRIPTION OF REASON FOR CORRECTIVE ACTION:

Truck 2438 was tested with an air content of 4.2% which is outside of specification limits

PROPOSED CORRECTIVE ACTION:

Notified the inspector and foreman, and instructed the driver to add water to the mix

CORRECTIVE ACTION TAKEN & ACCEPTED:

Driver added 15 gallons of water and mix was retested with an air content of 5.7%. Concrete placement resumed

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

Actual		Num Batches:	1										
Load	38787 lb	Design W/C:	0.451	Water/Cement:	0.451	T	Design	284.0 gl	Actual	263.7 gl	To Add:	20.3 gl	
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0	gl / Load	Trim Water:	-2.0	gl / yd				

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS				TICKET CODE: 1238689 DATE: 10/20/20	
DRIVER INSTRUCTION: CARPENTER & JOSEPH CAMPAU // NORTH OF CANIFF // EAST OF I-75						MAP PAGE: 		TIME: 8:42	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	116	WILLIE WEST	2403	33.01	10.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		10.00	yd	MDOT P1 535 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-AGM	CRH CEMENT MISSISSAUGA		MISSISSAUGA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-AGD	SLAG CEMENT ST MARYS CEMENT		DETROIT	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) 				
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003	COLLECTED (circle one) CHECK CASH CREDIT				
FINE AGG:									
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2403	WIWEST	user1	1238689	1238689	8:42	10/20/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
10.00 yd	P1-SW				W2	326607

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	13905 lb	13860 lb	-0.32%	3.00% M	48 gl	
CMT1-AGM	342 lb	3420 lb	3410 lb	-0.29%			
CMGS-AGD	184 lb	1840 lb	1830 lb	< -0.54%			
OWRA-PR	16 oz	158 oz	158 oz	0.13%			
WAT1	28.4 gl	215.5 gl	216.0 gl	0.25%		216.0 gl	
OAE-BA	5 oz	110 oz	111 oz	0.04%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	38719 lb	Design W/C: 0.451	Water/Cement: 0.452	T	Design	284.0 gl	Actual	264.4 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-2.0 gl / yd	To Add: 19.6 gl



DRIESENKA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>WestSide Concrete</u>	D&A PROJECT NO.: <u>2020SDS.4A</u>	DATE: <u>10-20-2020</u>
PROJECT: <u>Detroit MI - 7015</u>	INSPECTOR: <u>Patrick Driesenga</u>	
CONTRACTOR: <u>WestSide Concrete</u>	CONTROL SECTION/MDOT JOB NO.: _____	
CONCRETE SUPPLIER & CITY: <u>Hickory Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: <u>Clear</u>	TIME ARRIVED: _____	
A.M. <u>9:15</u>	SCHEDULED ARRIVAL TIME: _____	
P.M. _____	TIME LEFT SITE: _____	
AGGREGATE CORRECTION FACTOR: <u>0.02</u>		

Pour Description: C-2 concrete from Michigan to Gallagher St - Various Locations

Mix Design: 1-30 Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: 1 Batch Quantity (yd³): 22 Pour Start: 9:15 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2403	1735684	9:42	9:15		3 7/8	45	60	7.0	144.4	.993	4 SEC1

REMARKS

* Pour of HSP at 2 of High Slump

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 CARPENTER DDA 1550 HRS + 360L H2O				TICKET CODE 1238914 DATE 10/21/20	
DRIVER INSTRUCTION: CARPENTER & JOSEPH CAMPAN // NORTH OF CANIFF // EAST OF I-75							MAP PAGE DT4273B3	TIME 15:16	
P.O. NO.	ORDER NO.	DRIVER NAME	TRUCK NO.	QTY. ORDERED	QTY. DELIVERED	DESIGN SLUMP	DESIGNED AIR	PLANT NO.	
	113	DANIEL MCCARTHY	3709	29.50	29.50	3.00 in	6.50	1	
ITEM NAME		QUANTITY	UOM	DESCRIPTION			UNIT PRICE	EXTENDED	
P1-SW		10.50	yd	MDOT P1 S35 WRA					
MDOT 1188 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH: COARSE AGG: INTERM AGG: FINE AGG:	CMT1-AGM CMGS-AGD L6AA-PIN 2NS-SMR	CRH CEMENT MISSISSAUGA SLAG CEMENT ST MARYS CEMENT 6AA - PORT INLAND 2NS SPRING MILL RECLAMATION	MISSISSAUGA DETROIT 75-005 47-003	MDOT PLANT NO. GRADE OF CONC. M-11 COMPANY REPRESENTATIVE (signature) <i>Kelley J. Thompson</i>	COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP	WATER ADDED	REQUESTED BY	FINAL SLUMP	TESTED AIR	REVOLUTIONS	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT	ARRIVE AT JOB	START POUR	FINISH POUR	LEAVE JOB	ARRIVE PLANT	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
3709	DAMCCARTHY	user1	1238914	1238914	15:16	10/21/20	
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
10.50 yd	P1-SW				W2	326832	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	18890 lb	18680 lb	-0.05%			
2NS-SMR	1350 lb	14742 lb	14680 lb	-0.42%	4.00% M	68 gl	
CMT1-AGM	342 lb	3591 lb	3580 lb	-0.31%			
CMGS-AGD	184 lb	1932 lb	1930 lb	-0.10%			
OWRA-PR	18 oz	166 oz	165 oz	-0.42%			
WAT1	28.4 gl	214.5 gl	214.0 gl	-0.24%		214.0 gl	
QAE-BA	5 oz	118 oz	116 oz	0.01%			
HWATER	% #	gl	gl				

Actual		Num Batches: 1					
Load	40673 lb	Design W/C:	0.451	Water/Cement:	0.452	T	
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	
		Design	298.2 gl	Actual	281.7 gl	To Add:	16.5 gl
					-1.5 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 CARPENTER</i> <i>DDA;</i> <i>1230 hrs</i>				TICKET CODE: 1238872 DATE: 10/21/20	
DRIVER INSTRUCTION: CARPENTER & JOSEPH CAMPAU // NORTH OF CANIFF // EAST OF I-75							MAP PAGE: DT4273B3	TIME: 12:09	
RO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	JONATHAN STURD	4817	33.01	19.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		9.00	yd	MDOT P1 S35 WRA					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGGFS: FLY ASH:	CMT1-AGM CMGS-AGD	CRH CEMENT MISSISSAUGA SLAG CEMENT ST MARYS CEMENT		MISSISSAUGA DETROIT	MDOT PLANT NO. M-11	GRADE OF CONC.			
COARSE AGG INTERM AGG FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) <i>Kelley J. [Signature]</i> X		COLLECTED (circle one) CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp	Ticket	Num	Ticket ID	Time	Date
4817	JOSTURDIVA	user1	1238872			1238872	12:09	10/21/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID		
9.00 yd	P1-SW				W2	326790		

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	18020 lb	18020 lb	0.00%			
2NS-SMR	1350 lb	12838 lb	12580 lb	-0.44%	4.00% M		58 gl
CMT1-AGM	342 lb	3078 lb	3120 lb	> 1.36%			
CMGS-AGD	184 lb	1856 lb	1650 lb	-0.36%			
OWRA-PR	16 oz	142 oz	142 oz	-0.01%			
WAT1	28.4 gl	179.4 gl	179.0 gl	-0.20%		179.0 gl	
OAE-BA	5 oz	99 oz	100 oz	0.09%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	34879 lb	Design W/C: 0.451	Water/Cement: 0.447	T	Design	255.6 gl	Actual	237.0 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	-2.0 gl / yd	To Add: 18.6 gl

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 CARPENTER ADA 0853 PRS				TICKET CODE: 1238821 DATE: 10/21/20	
DRIVER INSTRUCTION: CARPENTER & JOSEPH CAMPAU // NORTH OF CANIFF // EAST OF I-75							MAP PAGE: 	TIME: 8:32	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	113	ANTHONY TAYLOR	2445	33.01	10.00	3.00 in	6.50	1	
ITEM NAME	QUANTITY	LSM	DESCRIPTION				UNIT PRICE	EXTENDED	
P1-SW	10.00	yd	MDOT P1 S35 WRA						
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGBFS: FLY ASH: COARSE AGG: INTERM AGG: FINE AGG:	CMT1-AGM CMGS-AGD L6AA-PIN 2NS-SMR	CRH CEMENT MISSISSAUGA SLAG CEMENT ST MARYS CEMENT 6AA - PORT INLAND 2NS SPRING MILL RECLAMATION	MISSISSAUGA DETROIT 75-005 47-003	MDOT PLANT NO. M-11 COMPANY REPRESENTATIVE (signature) Kelsey Thompson X	GRADE OF CONC. COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS: 				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START HOUR:	FINISH HOUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
2445	ANTAYLOR	user1		1238821	1238821	8:32	10/21/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
10.00 yd	P1-SW				W2	326741	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	17800 lb	17800 lb	0.00%			
2NS-SMR	1350 lb	14040 lb	14000 lb	-0.28%	4.00% M	65 gl	
CMT1-AGM	342 lb	3420 lb	3450 lb	> 0.88%			
CMGS-AGD	184 lb	1840 lb	1840 lb	0.00%			
OWRA-PR	18 oz	158 oz	157 oz	-0.51%			
WAT1	28.4 gl	199.3 gl	199.0 gl	-0.15%		199.0 gl	
OAE-BA	5 oz	110 oz	111 oz	0.04%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	38787 lb	Design W/C: 0.451	Water/Cement: 0.448	T	Design	284.0 gl	Actual 263.5 gl To Add: 20.5 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water: 0.0 gl / Load		Trim Water:	-2.0 gl / yd	



DRIESINGA & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>10-21-2020</u>
PROJECT: <u>Detroit PLU-7018</u>	INSPECTOR: <u>Patrick Drumm</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.: _____	
CONCRETE SUPPLIER & CITY: <u>McCaig - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: <u>Cloudy</u> A.M. <u>59</u> P.M.	TIME ARRIVED: SCHEDULED ARRIVAL TIME: TIME LEFT SITE:	
AGGREGATE CORRECTION FACTOR: <u>0.2</u>		

Pour Description: Carle D. Schmitt - 1st to McCall - 1st to Carpenter St

Mix Design: P1-SW Quantity Placed (yd³): _____ Lot Number: _____ Sublot: _____
Grade of Concrete: P1 Batch Quantity (yd³): 33 Pour Start: 9:05 Pour End: _____

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2445	123821	8:32	9:05		7.5		65	73	144.8	.991	4 (2C1)

REMARKS

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #3 TIREMAN ADA'S 1455 HRS <i>(Signature)</i>				TICKET CODE: 1239640 DATE: 10/29/20	
DRIVER INSTRUCTION: TIREMAN JUST EAST OF SOUTHFIELD						MAP PAGE: DT4342A3		TIME: 14:22	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	108	CHRISTOPHER ML	2446	24.00	24.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		8.00	yd	MDOT P1 S35 WRA					
MDOT 1100 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) <i>Kelley Thompson</i>		COLLECTED (circle one) ☐		
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003			CHECK CASH CREDIT		
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time Date
2446	CHMURFF	user1	1239640	1239640	14:22 10/29/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq Load ID
8.00 yd	P1-SW			W2	327565

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11288 lb	11280 lb	-0.23%	4.50% M	58 gl	
CMT1-LAA	342 lb	2738 lb	2730 lb	-0.22%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
OWRA-PR	18 oz	128 oz	128 oz	-0.18%			
WAT1	28.4 gl	159.0 gl	159.0 gl	0.02%		159.0 gl	
QAE-BA	5 oz	93 oz	93 oz	-0.08%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1							
Load	31041 lb	Design W/C: 0.451	Water/Cement: 0.451 T	Design	227.2 gl	Actual	217.1 gl	To Add: 10.1 gl
Slump:	3.00 in	Water in Truck: 0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.3 gl / yd		

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 231B WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #2 TIREMAN ADA'S 1230 HRS 				TICKET CODE: 1239608 DATE: 10/29/20		
DRIVER INSTRUCTION: TIREMAN JUST EAST OF SOUTHFIELD						MAP PAGE: DT4342B3		TIME: 11:57		
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:		
	108	JONATHAN STURD	4817	33.01	16.00	3.00 in	6.50	1		
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:		
P1-SW		8.00	yd	MDOT P1 S35 WRA						
MDOT 1158 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.										
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.				
GGGFS:	CHSS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11					
FLY ASH:										
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) 					
INTERM AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003						
FINE AGG:										
					X	COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. CUSTOMER SIGNATURE ☒				
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:					
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.										

Truck	Driver	User	Disp	Ticket Num	Ticket ID	Time	Date
4817	JOSTURDIVA	user1	1239608	1239608	1239608	11:57	10/29/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID	
8.00 yd	P1-SW				W2	327533	

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11286 lb	11240 lb	-0.41%	4.50% M		58 gl
CMT1-LAA	342 lb	2736 lb	2730 lb	-0.22%			
CMGS-LA	184 lb	1472 lb	1450 lb	-1.48%			
OWRA-PR	16 oz	128 oz	125 oz	-0.98%			
WAT1	28.4 gl	159.0 gl	159.0 gl	0.02%			159.0 gl
OAE-BA	5 oz	93 oz	93 oz	-0.08%			
HWATER	% #	gl	gl				

Actual Load	31000 lb	Design W/C:	0.451	Water/Cement:	0.454 T	Design	227.2 gl	Actual	217.0 gl	To Add:	10.2 gl
Slump:	3.00 in	Water in Truck:	0.0 gl	Adjust Water:	0.0 gl / Load	Trim Water:	-1.3 gl / yd				

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PM-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#1 TIREMAN ADDS</i> <i>0910/1/25</i> 				TICKET CODE: 1239577 DATE: 10/29/20	
DRIVER INSTRUCTION: TIREMAN JUST EAST OF SOUTHFIELD						MAP PAGE: DT4342B3		TIME: 8:33	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	108	CHRISTOPHER ML	2446	33.01	8.00	3.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SW		8.00	yd	MDOT P1 S35 WRA					
MDOT 1100 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.		
GGGFS:		CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11			
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT			
INTERM AGG:									
FINE AGG:		2NS-SMR	2NS SPRING HILL RECLAMATION		47-003				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. ☒			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2446	CHMURFF	user1	1239577	1239577	8:33	10/29/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.00 yd	P1-SW				W2	327502

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11288 lb	11260 lb	-0.23%	4.50% M		58 gl
CMT1-LAA	342 lb	2736 lb	2740 lb	0.15%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
OWRA-PR	16 oz	126 oz	127 oz	0.80%			
WAT1	28.4 gl	161.0 gl	161.0 gl	0.02%			161.0 gl
OAE-BA	5 oz	93 oz	93 oz	0.46%			
HWATER	% #	gl	gl				

Actual	Num Batches: 1						
Load	31067 lb	Design W/C: 0.451	Water/Cement: 0.450 T	Design	227.2 gl	Actual	219.1 gl To Add: 8.1 gl
Slump:	3.00 in	Water In Truck: 0.0 gl	Adjust Water: 0.0 gl / Load	Trim Water:	-1.0 gl / yd		



DRIESEN & ASSOCIATES, INC.

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>Westside Concrete</u>	D&A PROJECT NO.: <u>2020535-A</u>	DATE: <u>10-29-20</u>
PROJECT: <u>Detroit PW: 7018</u>	INSPECTOR: <u>AC # 0167576</u> <u>Dennis Snyder</u>	
CONTRACTOR: <u>Westside Concrete</u>	CONTROL SECTION/MDOT JOB NO.:	
CONCRETE SUPPLIER & CITY: <u>McCoy - Detroit</u>	PROJECT ENGINEER: <u>City of Detroit</u>	
WEATHER: A.M. <u>4:01 Cloudy</u> P.M.	TAG NUMBERS: <u>111-11-8 2020</u>	

Pour Description: Sidewalk @ Terman & Ashlen

Mix Design: P1.50 Quantity Paid (yd³): _____ Lot Number: _____ Sublot: _____

Grade of Concrete: P1.50 Batch Quantity (yd³): 8.0 Pour Start: 9:15 Pour End: 9:45 am

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2446	1234567	8:33	9:15	9:45	4	40	60	5.5%	146.0	999	400

REMARKS

MCCOIG MATERIALS
1441 Springwells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#3 TIREMAX 401</i> <i>1611 HRS</i> 				TICKET CODE: 2210216 DATE: 10/30/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF SOUTHFIELD							MAP PAGE: DT4341E3	TIME: 15:30	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	106	JIM TARHANICH	3712	24.00	24.00	5.00 in	6.50	2	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
PI-SM		8.00	yd	MDOT PI S35 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:		CMT1-LHSG	CEMENT T1 LAFARGE ST GENEVI		Alpena		MDOT PLANT NO.	GRADE OF CONC.	
GGGFS:		CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. Chicago				
FLY ASH:									
COARSE AGG:		L6AA-PIN	6AA - PORT INLAND		71-003		COMPANY REPRESENTATIVE (signature) COLLECTED (circle one) CHECK CASH CREDIT		
INTERM AGG:		2NS-WLB	2NS - WATERLAND BURMEISTER 0		01-093				
DRIVERS COMMENTS:							Customer Requested Ticket Before Discharge Completed		
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
5									
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	CUSTOMER SIGNATURE X			
3:39	4:17	4:22							
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

Truck 3712	Driver JITARHANICH	User user	Disp Ticket Num 2210216	Ticket ID 2210216	Time 15:30	Date 10/30/20
Load Size 8.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age	Seq 2W	Load ID 231938

Material Batch:	Design Qty	Start	SSD	Adj.T End:	Required	Batched Time (hh:mm:ss)	% Var	%Moisture	Actual Wat	Trim
L6AA-PIN	1780 lb	15:30:18	1780		14240 lb	14160 lb	-0.58%			
2NS-WLB	1350 lb		1350		11340 lb	11240 lb	-0.88%	5.00%	64 gl	
CMT1-LHSG	342.0 lb		342.0		2736.0 lb	2750.0 lb	0.51%			
CMGS-LA	184.0 lb		184.0		1472.0 lb	1470.0 lb	-0.14%			
WAT1	28.4 gl		28.4	-25.0	129.2 gl	128.7 gl	-0.38%		128.7 gl	-1.0 gl
OAE-BA	5.26 oz		5.26		44.18 oz	44.00 oz	-0.42%			105.00 %
OMRLI-PR	26 oz		26		210 oz	208 oz	-1.14%			

Actual Load	30710 lb	Design W/C:	0.451	Water/Cement:	0.449	A	Design	227.2 gl	Actual	192.8 gl	To Add:	34.4 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:	-25.0	gl / Load	Trim Water:	-1.0	gl / yd	Note:	Manual feed occurred	

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PM-7018 MAJOR ROADS VARIOUS LOCATIONS <i>#2 TIREMAN ADD:</i> <i>1228 JUNE</i> 				TICKET CODE: 1239735 DATE: 10/30/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF SOUTHFIELD						MAP PAGE: DT4342A3 TIME: 11:54			
PO. NO.:	ORDER NO.: 106	DRIVER NAME:	TRUCK NO.: 2900	QTY. ORDERED: 33.01	QTY. DELIVERED: 16.00	DESIGN SLUMP: 5.00 in	DESIGNED AIR: 6.50	PLANT NO.: 1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		8.00	yd	MDOT P1 S35 MR					
MDOT 1188 STATEMENT: I hereby certify the concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT: GGDFS: FLY ASH:	CMT1-LAA CMGS-LA	CEMENT T1 LAFARGE ALPENA LAFARGE NORTH AMERICA GGDF		ALPENA S. CHICAGO	MDOT PLANT NO.: M-11	GRADE OF CONC.:			
COARSE AGG: INTERM AGG: FINE AGG:	L6AA-PIN 2NS-SMR	6AA - PORT INLAND 2NS SPRING MILL RECLAMATION		75-005 47-003	COMPANY REPRESENTATIVE (signature) COLLECTED (circle one) ☒ CHECK ☐ CASH ☐ CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. 			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

Truck 2900	Driver	User user1	Disp Ticket Num 1239735	Ticket ID 1239735	Time Date 11:54 10/30/20
Load Size 8.00 yd	Mix Code P1-SM	Returned	Qty	Mix Age W2	Seq Load ID 327661

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14280 lb	0.14%			
2NS-SMR	1350 lb	11340 lb	11320 lb	-0.18%	5.00% M	65 gl	
CMT1-LAA	342 lb	2738 lb	2740 lb	0.15%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
WAT1	28.4 gl	158.5 gl	168.0 gl	-0.31%		158.0 gl	
QAE-BA	5 oz	78 oz	78 oz	-0.32%			
OMRLI-PR	28 oz	210 oz	218 oz	2.66%			
HWATER	% #	gl	gl				

Actual Load	31127 lb	Design W/C:	0.451	Water/Cement:	0.450 T	Design	227.2 gl	Actual	222.6 gl	To Add:	4.6 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	-0.5 gl / yd			

MCCOIG MATERIALS
500 E. Seven Mile Rd. Detroit, MI 48203
PHONE: (313) 368-1133

1 - White (Office)
 2 - Yellow (Customer)
 3 - Pink (Misc.)

(A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES)

SOLD TO: 2318 WESTSIDE CONCRETE CO. P.O. BOX 183368				SHIP TO: V49792 PW-7018 MAJOR ROADS VARIOUS LOCATIONS #1 TIREMAN 4043 K5/10				TICKET CODE: 1239696 DATE: 10/30/20	
DRIVER INSTRUCTION: ON TIREMEN WEST OF SOUTHFIELD						MAP PAGE: DT4342A3		TIME: 8:24	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	106	TAMIKO LEE	2350	33.01	8.00	5.00 in	6.50	1	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		8.00	yd	MDOT P1 935 MR					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
CEMENT:	CMT1-LAA	CEMENT T1 LAFARGE ALPENA		ALPENA	MDOT PLANT NO.	GRADE OF CONC.			
GGBFS:	CMGS-LA	LAFARGE NORTH AMERICA GGBF		S. CHICAGO	M-11				
FLY ASH:									
COARSE AGG:	L6AA-PIN	6AA - PORT INLAND		75-005	COMPANY REPRESENTATIVE (signature) <i>Releaz Smith</i>		COLLECTED (circle one) ☐		
INTERM AGG:									
FINE AGG:	2NS-SMR	2NS SPRING MILL RECLAMATION		47-003				CHECK CASH CREDIT	
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. X			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
						CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

Truck	Driver	User	Disp Ticket Num	Ticket ID	Time	Date
2350	TALEE	user1	1239696	1239696	8:24	10/30/20
Load Size	Mix Code	Returned	Qty	Mix Age	Seq	Load ID
8.00 yd	P1-SM				W2	327621

Material	Design Qty	Required	Batched	% Var	% Moisture	Actual	Wat
L6AA-PIN	1780 lb	14240 lb	14240 lb	0.00%			
2NS-SMR	1350 lb	11286 lb	11260 lb	-0.23%	4.50% M	58 gl	
CMT1-LAA	342 lb	2736 lb	2730 lb	-0.22%			
CMGS-LA	184 lb	1472 lb	1470 lb	-0.14%			
WAT1	28.4 gl	165.0 gl	165.0 gl	0.02%		165.0 gl	
OAE-BA	5 oz	76 oz	76 oz	-0.32%			
OMRLI-PR	26 oz	210 oz	208 oz	-1.14%			
HWATER	% #	gl	gl				

Actual Load	31095 lb	Design W/C:	0.451	Water/Cement:	0.451 T	Design	227.2 gl	Actual	223.1 gl	To Add:	4.1 gl
Slump:	5.00 in	Water in Truck:	0.0 gl	Adjust Water:		0.0 gl / Load	Trim Water:	-0.5 gl / yd			



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: Westside Concrete	D&A PROJECT NO.: 2020525.4A	DATE: 10/30/20
PROJECT: PW-7019 City of Detroit Major Roads	INSPECTOR: Matthew Magee	
CONTRACTOR: Westside Concrete	CONTROL SECTION/MDOT JOB NO.: _____	
CONCRETE SUPPLIER & CITY: McCaig Materials - Detroit	PROJECT ENGINEER: City of Detroit	
WEATHER: A.M. Overcast P.M.	TIME ARRIVED: 8:15 am SCHEDULED ARRIVAL TIME: 9:00 am TIME LEFT SITE: 10:00 am	
AGGREGATE CORRECTION FACTOR: 0.2%		

Pour Description: Curb and sidewalk sections on Tireman Ave between Ashton Ave and Brace St

Mix Design: PI-SM **Quantity Placed (yd³):** 8 **Lot Number:** _____ **Sublot:** _____
Grade of Concrete: PI **Batch Quantity (yd³):** 8 **Pour Start:** 9:18 **Pour End:** 9:55

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2350	1239696	8:24	9:18	9:55	4.5	39	54	5.7	145.6	.988	4 GCI

REMARKS

Mix contains a MBWR