



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side Concrete</u>
PROJECT: <u>PM-7018 City of Detroit</u>
CONTRACTOR: <u>West Side Concrete</u>
CONCRETE SUPPLIER & CITY: <u>SRM Concrete, Plan/17820</u>
WEATHER: A.M. ☒ P.M. <u>Sunny</u>
AGGREGATE CORRECTION FACTOR: <u>0.20</u>

D&A PROJECT NO.: <u>2020525-4A</u>	DATE: <u>10/13/21</u>
INSPECTOR: <u>Michael Bogue</u>	
CONTROL SECTION/MDOT JOB NO.: <u>City of Detroit</u>	
PROJECT ENGINEER: <u>City of Detroit</u>	
TIME ARRIVED: <u>11:15</u>	
SCHEDULED ARRIVAL TIME: <u>12:30</u>	
TIME LEFT SITE: <u>1:45</u>	

Pour Description: West Bound Lane (Clark Street and
Porter Street.

Mix Design: PI-SM Quantity Placed (yd³): 30.0 Lot Number: Sublot:
Grade of Concrete: PI Batch Quantity (yd³): 30.0 Pour Start: 1:00 Pour End: 1:43

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
2306	82010153	12:13	1:00	1:28	5 1/4	73	84	6.6	144.7	0.946	40C1

REMARKS

The concrete mix contained MR!!

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010153 DATE: 10/13/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF SOUTH OF VERNOR, TO PORTER ST							TIME: 12:13:58		
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 140	JRCHAM, STEV	AI 2306	30.10	10.00	5.00	6.5	820	
ITEM NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESCRIPTION:	UNIT PRICE:	EXT. PRICE:	TAX:	TOTAL:	REMARKS:	
P1-SM 1015	10.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU	0.00 0	0.00 0		0.00 0		
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS	47-003	MDOT PLANT NO.	GRADE OF CONC.	COLLECTED (circle one) ☐ CHECK ☐ CASH ☐ CREDIT			
Rock	L6AA-PIN	PORT INLAND - 6AA	75-005	M-40					
Cementitious	CMGS-LA	LAFARGE-SLAG-GRADE 100	CHICAGO	COMPANY REPRESENTATIVE (signature) 					
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA	ALPENA						
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☒					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT SITE:	TIME OF DELIVERY:	TIME OF DISCHARGE:	TIME OF RETURN:	TIME OF UNLOAD:	X			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.						UNLOAD PROMPTLY: Excess time will be charged to the buyer.			

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER
LAFARGE-SLAG-GRADE 100	184.00 lb	1840.00 lb	2000.00 lb	8.7	0.00	40.4 gal
SPRING MILL - 2NS	1350.00 lb	13840.00 lb	13820.00 lb	-0.1	2.50	
LAFARGE-I-II LA-APLENA	342.00 lb	3420.00 lb	3525.00 lb	3.1	0.00	
PORT INLAND - 6AA	1780.00 lb	17800.00 lb	17720.00 lb	-0.4	0.00	
WAT1	28.40 gal	238.45 gal	238.93 gal	0.2	0.00	
MB AE 200	1.46 oz	77.00 oz	76.50 oz	-0.6	0.00	
PCA OPTIFLO MR	36.80 oz	368.00 oz	372.00 oz	1.1	0.00	

End of Load Time 12:15 PM

Trim Water:

Water to Add:

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location	Detroit		Date	10/13/2021	
Contractor	WESTSIDE		Time Batched	12:25	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:			Truck No.	306	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780
Sand	Springmill	Gradation	2NS	Lbs	1350
Cement	Lafarge	Type	I	Lbs	342
Slag	Lafarge			Lbs	184
Air Entraining Agent	BASF Micro Air			Ozs.	5.26
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3
Other Concrete Admixture				Ozs.	
Transit Mix Concrete Producer	McCoig Concrete	Water - Gals	28.4		
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)			

(Producer Not To Sign Below)

(2.77) (REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010155	
DRIVER INSTRUCTION: CLARK SOUTH OFF SOUTH OF VERNOR, TO PORTER ST								DATE: 10/13/2021	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 140	YDRAS, MCARTHI	3724	30.10	20.00	5.00	6.5	820	
PROD. NO.:	QTY. TO:	QTY. TO:	QTY. TO:	QTY. TO:	QTY. TO:	QTY. TO:	QTY. TO:	QTY. TO:	
P1-SM 1015	10.00 1.00								
				MDOT P1 S35 MR ENVIRONMENTAL SU					
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS	47-003	MDOT PLANT NO.	GRADE OF CONC.				
Rock	L6AA-PIN	PORT INLAND - 6AA	75-005	M-40					
Cementitious	CMGS-LA	LAFARGE-SLAG-GRADE 100	CHICAGO	COMPANY REPRESENTATIVE (signature) <i>[Signature]</i>					
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA	ALPENA						
				COLLECTED (circle one) ☐ CHECK ☐ CASH ☐ CREDIT					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
WATER ADDED:	WATER ADDED:	WATER ADDED:	WATER ADDED:	WATER ADDED:	WATER ADDED:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER
LAFARGE-SLAG-GRADE 100	184.00 lb	1840.00 lb	1895.00 lb	3.0	0.00	40.3 gal
SPRING MILL - 2NS	1350.00 lb	13840.00 lb	13800.00 lb	-0.3	2.50	
LAFARGE-I-II LA-APLENA	342.00 lb	3420.00 lb	3405.00 lb	-0.4	0.00	
PORT INLAND - 6AA	1780.00 lb	17800.00 lb	17820.00 lb	0.1	0.00	
WAT1	28.40 gal	238.45 gal	240.61 gal	0.9	0.00	
MB AE 200	1.46 oz	77.00 oz	76.50 oz	-0.6	0.00	
PCA OPTIFLO MR	36.80 oz	368.00 oz	360.00 oz	-2.2	0.00	

End of Load Time 12:50 PM

Trim Water:

Water to Add:

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location		Detroit		Date	10/13/2021	
Contractor		WESTSIDE		Time Batched	13:02	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:				Truck No.	724	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780	10
Sand	Springmill	Gradation	2NS	Lbs	1350	
Cement	Lafarge	Type	I	Lbs	342	
Slag	Lafarge			Lbs	184	
Air Entraining Agent	BASF Micro Air			Ozs.	5.26	
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3	
Other Concrete Admixture				Ozs.		
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4	
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)				

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MA DETROIT,				TICKET CODE: 82010156 DATE: 10/13/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PRICE:	TIME: 13:40:35	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 140	SANDOVAL, RICO	3712	42.10	31.00	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UNIT:	ITEM NAME:	QUANTITY:	UNIT:	ITEM NAME:	QUANTITY:	UNIT:	
P1-SM 1015	11.00 1.00		MDOT P1 535 MR ENVIRONMENTAL SU	0.00 0			0.00 0		
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand Rock	2NS-5MR L6AA-PIN	SPRING MILL - 2NS PORT INLAND - 6AA	47-003 75-005	MDOT PLANT NO. M-40	GRADE OF CONC.				
Cementitious Cementitious	CMGS-LA CMT1-LAA	LAFARGE-SLAG-GRADE 100 LAFARGE-I-II LA-APLENA	CHICAGO ALPENA	COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one)			
						CHECK CASH CREDIT			
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LOOSE PAV.	SPRINKLING	WATER ADDED	FINAL SLUMP	TESTED AIR	REVOLUTIONS				
X						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFARGE-SLAG-GRADE 100	184.00 lb	2025.00 lb	2030.00 lb	0.2	0.00	44.4 gal	End of Load Time 1:42 PM
SPRING MILL - 2NS	1350.00 lb	15220.00 lb	15200.00 lb	-0.1	2.50		
LAFARGE-I-II LA-APLENA	342.00 lb	3760.00 lb	3740.00 lb	-0.5	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	19580.00 lb	19540.00 lb	-0.2	0.00		Water to Add:
WAT1	28.40 gal	242.29 gal	243.97 gal	0.7	0.00		
MB AE 200	1.46 oz	85.00 oz	84.50 oz	-0.6	0.00		
PCA OPTIFLO MR	36.80 oz	408.00 oz	408.00 oz	0.0	0.00		

Job Location	Detroit		Date	10/13/2021	
Contractor	WESTSIDE		Time Batched	13:40	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:			Truck No.	712	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780
Sand	Springmill	Gradation	2NS	Lbs	1350
Cement	Lafarge	Type	I	Lbs	342
Slag	Lafarge			Lbs	184
Air Entraining Agent	BASF Micro Air			Ozs.	5.26
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3
Other Concrete Admixture				Ozs.	
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)			

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)


SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MA DETROIT,				TICKET CODE: 82010158 DATE: 10/13/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAD PRICE: TIME: 13:51:08		
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 140	SMITH, ADDISON	4821	42.10	41.00	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UNIT:	PRICE:	EXTENDED:	UNIT PRICE:	EXTENDED:			
P1-SM 1015'	10.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU	0.00 0		0.00 0			
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS	47-003	MDOT PLANT NO.	GRADE OF CONC.	COLLECTED (circle one) CHECK CASH CREDIT			
Rock	LGAA-PIN	PORT INLAND - 6AA	75-005	M-40					
Cementitious	CMGS-LA	LAFARGE-SLAG-GRADE 100	CHICAGO	COMPANY REPRESENTATIVE (signature)		X			
Cementitious	CMT1-LAA NA	LAFARGE-I-II LA-APLENA CEMENT SCALE	ALPENA CEMENT						
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START TIME:	FINISH TIME:	LOAD TIME:	UNLOAD TIME:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFARGE-SLAG-GRADE 100	184.00 lb	1840.00 lb	1835.00 lb	-0.3	0.00	40.9 gal	End of Load Time 1:57 PM
SPRING MILL - 2NS	1350.00 lb	13840.00 lb	13980.00 lb	1.0	2.50		
LAFARGE-I-II LA-APLENA	342.00 lb	3420.00 lb	3425.00 lb	0.1	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	17800.00 lb	17740.00 lb	-0.3	0.00		Water to Add:
WAT1	28.40 gal	238.45 gal	238.22 gal	-0.1	0.00		
MB AE 200	1.46 oz	77.00 oz	77.00 oz	0.0	0.00		
PCA OPTIFLO MR	36.80 oz	368.00 oz	364.00 oz	-1.1	0.00		
CEMENT SCALE	0.00 lb	0.00 lb	55.00 lb	1.0	0.00		

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location	Detroit		Date	10/13/2021	
Contractor	WESTSIDE		Time Batched	14:02	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:			Truck No.	821	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780
Sand	Springmill	Gradation	2NS	Lbs	1350
Cement	Lafarge	Type	I	Lbs	342
Slag	Lafarge			Lbs	184
Air Entraining Agent	BASF Micro Air			Ozs.	5.26
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3
Other Concrete Admixture				Ozs.	
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)			

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010161 DATE: 10/13/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAY PAGE	TIME 15:17:14	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 140	HAMBERS, ERNEST	2315	52.10	51.00	5.00	6.5	820	
P1-SM 1015		10.00 1.00	MDOT P1 S35 MR ENVIRONMENTAL SU			0.00 0	0.00 0		
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand Rock	2NS-SMR L6AA-PIN	SPRING MILL - 2NS PORT INLAND - 6AA		47-003 75-005	MDOT PLANT NO. M-40	GRADE OF CONC.			
Cementitious Cementitious	CMGS-LA CMT1-LAA	LAFA-SLAG-GRADE 100 LAFARGE-I-II LA-APLENA		CHICAGO ALPENA	COMPANY REPRESENTATIVE (signature) 			COLLECTED (circle one) CHECK CASH CREDIT	
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☒				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
						X			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.						UNLOAD PROMPTLY: Excess time will be charged to the buyer.			

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFARGE-SLAG-GRADE 100	184.00 lb	1840.00 lb	1850.00 lb	0.5	0.00	40.3 gal	End of Load Time 3:19 PM
SPRING MILL - 2NS	1350.00 lb	13840.00 lb	13800.00 lb	-0.3	2.50		
LAFARGE-I-II LA-APLENA	342.00 lb	3420.00 lb	3430.00 lb	0.3	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	17800.00 lb	17760.00 lb	-0.2	0.00		
WAT1	28.40 gal	238.45 gal	238.93 gal	0.2	0.00		Water to Add:
MB AE 200	1.46 oz	77.00 oz	77.50 oz	0.6	0.00		
PCA OPTIFLO MR	36.80 oz	368.00 oz	368.00 oz	0.0	0.00		

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location		Detroit		Date	10/13/2021	
Contractor		WESTSIDE		Time Batched	15:17	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:				Truck No.	315	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780	11
Sand	Springmill	Gradation	2NS	Lbs	1350	
Cement	Lafarge	Type	I	Lbs	342	
Slag	Lafarge			Lbs	184	
Air Entraining Agent	BASF Micro Air			Ozs.	5.26	
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3	
Other Concrete Admixture				Ozs.		
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4	
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)				

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010162 DATE: 10/13/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							WAPASE:	TIME: 16:12:28	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 140	SANDOVAL, RICO	3712	57.50	57.50	5.00	6.5	820	
P1-SM 1015		6.50 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU			0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS		47-003	MDOT PLANT NO.		GRADE OF CONC.		
Rock	L6AA-PIN	PORT INLAND - 6AA		75-005	M-40				
Cementitious	CMGS-LA	LAFA-SLAG-GRADE 100		CHICAGO	COMPANY REPRESENTATIVE (signature)				
Cementitious	CMT1-LAA	LAFARGE-I-I LA-APLENA		ALPENA	COLLECTED (circle one)				
					CHECK CASH CREDIT				
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LAFARGE PLANT	LAFARGE PLANT	LAFARGE PLANT	LAFARGE PLANT	LAFARGE PLANT	LAFARGE PLANT	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFA-SLAG-GRADE 100	184.00 lb	1195.00 lb	1255.00 lb	5.0	0.00	26.19 gal	End of Load Time 4:14 PM
SPRING MILL - 2NS	1350.00 lb	9000.00 lb	8960.00 lb	-0.4	2.50		
LAFARGE-I-I LA-APLENA	342.00 lb	2225.00 lb	2180.00 lb	-2.0	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	11560.00 lb	11520.00 lb	-0.3	0.00		Water to Add:
WAT1	28.40 gal	155.06 gal	156.73 gal	1.1	0.00		
MB AE 200	1.46 oz	50.00 oz	50.00 oz	0.0	0.00		
PCA OPTIFLO MR	36.80 oz	240.00 oz	244.00 oz	1.7	0.00		

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location		Detroit		Date	10/13/2021	
Contractor		WESTSIDE		Time Batched	14:03	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:				Truck No.	712	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780	11
Sand	Springmill	Gradation	2NS	Lbs	1350	
Cement	Lafarge	Type	1	Lbs	342	
Slag	Lafarge			Lbs	184	
Air Entraining Agent	BASF Micro Air			Ozs.	5.26	
Other Concrete Admixture	Premiere Optifo MR			Ozs.	26.3	
Other Concrete Admixture				Ozs.		
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4	
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)				

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: Westside Concrete	D&A PROJECT NO.: 20225254A	DATE: 10/11/21
PROJECT: DPW 1318 - Major Roadway	INSPECTOR: A. J. [Signature]	
CONTRACTOR: Westside Concrete	CONTROL SECTION/MDOT JOB NO.: DPW 101E	
CONCRETE SUPPLIER & CITY: KVI Concrete	PROJECT ENGINEER: [Signature]	
WEATHER: A.M. 50, Windy P.M. 50, Windy	TIME ARRIVED: 11:30 am	
AGGREGATE CORRECTION FACTOR: 0%	SCHEDULED ARRIVAL TIME: 11:30 am	
	TIME LEFT SITE: 11:30 pm	

Pour Description: Roadway at Parker & Clark St

Mix Design: P55MR Quantity Placed (yd³): 4 Lot Number: 7 Sublot: 7
Grade of Concrete: P5.0 Batch Quantity (yd³): 4 Pour Start: 12:00 pm Pour End: 12:15 pm

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
374	501000	1/50	12:15	12:45	5	75	7	6.8	146	0.99	14.5

REMARKS

AIR present

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010202 DATE: 10/14/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE:	TIME: 11:50:19	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	YDRAS, MCART	HI 3724	44.10	11.00	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-5M 1015	11.00 1.00		MDOT P1 535 MR ENVIRONMENTAL SU				0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-5MR	SPRING MILL - 2NS		47-003	MDOT PLANT NO.		GRADE OF CONC.		
Rock	L6AA-PIN	PORT INLAND - 6AA		75-005	M-40				
Cementitious	CMGS-LA	LAFA-SLAG-GRADE 100		CHICAGO	COMPANY REPRESENTATIVE (signature)				
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA		ALPENA	 COLLECTED (circle one)				
					CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			

SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFA-SLAG-GRADE 100	184.00	lb 2025.00	lb 2045.00	lb 1.0	0.00	66.5 gal	End of Load Time 11:51 AM
SPRING MILL - 2NS	1350.00	lb 15400.00	lb 15360.00	lb -0.3	3.75		
LAFARGE-I-II LA-APLENA	342.00	lb 3760.00	lb 3775.00	lb 0.4	0.00		Trim Water:
PORT INLAND - 6AA	1780.00	lb 19580.00	lb 19580.00	lb 0.0	0.00		Water to Add:
WAT1	28.40	gal 234.62	gal 236.78	gal 0.9	0.00		
MB AE 200	1.41	oz 82.00	oz 82.00	oz 0.0	0.00		
PCA OPTIFLO MR	36.80	oz 408.00	oz 408.00	oz 0.0	0.00		

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MA DETROIT,				TICKET CODE: 82010203 DATE: 10/14/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE: TIME: 12:00:47		
RO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	SANDOVAL, RICO	3712	44.10	22.00	5.00	6.5	820/	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM 1015		11.00 1.00		MDOT P1 535 MR ENVIRONMENTAL SU			0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certify that the concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS		47-003	MDOT PLANT NO.		GRADE OF CONC.		
Rock	L6AA-PIN	PORT INLAND - 6AA		75-005	M-40				
Cementitious	CMGS-LA	LAFA-SLAG-GRADE 100		CHICAGO	COMPANY REPRESENTATIVE (signature) <i>[Signature]</i>		COLLECTED (circle one)		
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA		ALPENA					
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER
LAFA-SLAG-GRADE 100	184.00	lb 2025.00	lb 2085.00	lb 3.0	0.00	66.4 gal
SPRING MILL - 2NS	1350.00	lb 15400.00	lb 15340.00	lb -0.4	3.75	End of Load Time 12:02 PM
LAFARGE-I-II LA-APLENA	342.00	lb 3760.00	lb 3770.00	lb 0.3	0.00	Trim Water:
PORT INLAND - 6AA	1780.00	lb 19580.00	lb 19520.00	lb -0.3	0.00	Water to Add:
WAT1	28.40	gal 234.62	gal 235.82	gal 0.5	0.00	
MB AE 200	1.41	oz 82.00	oz 82.00	oz 0.0	0.00	
PCA OPTIFLO MR	36.80	oz 408.00	oz 404.00	oz -1.0	0.00	

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010213 DATE: 10/14/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE:	TIME: 13:40:07	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	SMITH, ADDISON	4821	44.10	33.00	5.00	6.5	820	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM 1015		11.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU			0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand Rock	2NS-SMR L6AA-PIN	SPRING MILL - 2NS PORT INLAND - 6AA		47-003 75-005	MDOT PLANT NO. M-40	GRADE OF CONC.			
Cementitious Cementitious	CMGS-LA CMT1-LAA	LAFA-SLAG-GRADE 100 LAFARGE-I-II LA-APLENA		CHICAGO ALPENA	COMPANY REPRESENTATIVE (signature) 			COLLECTED (circle one) CHECK CASH CREDIT	
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket. 			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER
LAFA-SLAG-GRADE 100	184.00 lb	2025.00 lb	2040.00 lb	0.7	0.00	53.2 gal
SPRING MILL - 2NS	1350.00 lb	15300.00 lb	15240.00 lb	-0.4	3.00	
LAFARGE-I-II LA-APLENA	342.00 lb	3760.00 lb	3725.00 lb	-0.9	0.00	
PORT INLAND - 6AA	1780.00 lb	19580.00 lb	19520.00 lb	-0.3	0.00	
WAT1	28.40 gal	248.04 gal	249.24 gal	0.5	0.00	
MB AE 200	1.41 oz	82.00 oz	81.50 oz	-0.6	0.00	
PCA OPTIFLO MR	36.80 oz	408.00 oz	412.00 oz	1.0	0.00	

End of Load Time 1:42 PM

Trim Water:

Water to Add:

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010222	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST								MAP PAGE:	TIME: 14:38:03
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	SANDOVAL, RICO	3712	44.10	44.00	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM 1015	11.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU				0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS	47-003	MDOT PLANT NO.	GRADE OF CONC.				
Rock	L6AA-PIN	PORT INLAND - 6AA	75-005	M-40					
Cementitious	CMGS-LA	LAFAG-SLAG-GRADE 100	CHICAGO	COMPANY REPRESENTATIVE (signature)		COLLECTED (circle one) CHECK CASH CREDIT			
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA	ALPENA	X					
DRIVERS COMMENTS:						Customer Requested Ticket Before Discharge Completed ☐			
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFAG-SLAG-GRADE 100	184.00 lb	2025.00 lb	2060.00 lb	1.7	0.00	48.9 gal	End of Load Time 2:40 PM
SPRING MILL - 2NS	1350.00 lb	15260.00 lb	15240.00 lb	-0.1	2.75		
LAFARGE-I-II LA-APLENA	342.00 lb	3760.00 lb	3755.00 lb	-0.1	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	19580.00 lb	19580.00 lb	0.0	0.00		Water to Add:
WAT1	28.40 gal	255.23 gal	256.91 gal	0.7	0.00		
MB AE 200	1.41 oz	82.00 oz	82.00 oz	0.0	0.00		
PCA OPTIFLO MR	36.80 oz	408.00 oz	400.00 oz	-2.0	0.00		

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MA DETROIT,				TICKET CODE: 82010225 DATE: 10/14/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE:	TIME: 15:06:31	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	JORDON, DELANC	2437	55.10	55.00	5.00	6.5	820	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM		11.00		MDOT P1 S35 MR			0.00	0.00	
1015		1.00		ENVIRONMENTAL SU			0	0	
MDOT 1185 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS		47-003	MDOT PLANT NO.		GRADE OF CONC.		
Rock	L6AA-PIN	PORT INLAND - 6AA		75-005	M-40				
Cementitious	CMGS-LA	LAFA-SLAG-GRADE 100		CHICAGO	COMPANY REPRESENTATIVE (signature)				
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA		ALPENA	 X				
						COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFA-SLAG-GRADE 100	184.00	lb 2025.00	lb 2060.00	lb 1.7	0.00	48.8 gal	End of Load Time 3:08 PM
SPRING MILL - 2NS	1350.00	lb 15260.00	lb 15220.00	lb -0.3	2.75		
LAFARGE-I-II LA-APLENA	342.00	lb 3760.00	lb 3770.00	lb 0.3	0.00		Trim Water:
PORT INLAND - 6AA	1780.00	lb 19580.00	lb 19500.00	lb -0.4	0.00		Water to Add:
WAT1	28.40	gal 255.23	gal 255.71	gal 0.2	0.00		
MB AE 200	1.41	oz 82.00	oz 82.50	oz 0.6	0.00		
PCA OPTIFLO MR	36.80	oz 408.00	oz 400.00	oz -2.0	0.00		

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010227 DATE: 10/14/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE:	TIME: 15:56:36	
P.O. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	YDRAS, MCARTH	4819	66.10	66.00	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM 1015	11.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU				0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand Rock	2NS-SMR L6AA-PIN	SPRING MILL - 2NS PORT INLAND - 6AA	47-003 75-005	MDOT PLANT NO. M-40	GRADE OF CONC.		COLLECTED (circle one) CHECK CASH CREDIT		
Cementitious Cementitious	CMGS-LA CMT1-LAA	LAFARGE-SLAG-GRADE 100 LAFARGE-I-II LA-APLENA	CHICAGO ALPENA	COMPANY REPRESENTATIVE (signature) <i>Joseph Yelich</i>					
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
5									
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
4:10									
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFARGE-SLAG-GRADE 100	184.00 lb	2025.00 lb	2045.00 lb	1.0	0.00	48.9 gal	End of Load Time 4:00 PM
SPRING MILL - 2NS	1350.00 lb	15260.00 lb	15240.00 lb	-0.1	2.75		
LAFARGE-I-II LA-APLENA	342.00 lb	3760.00 lb	3785.00 lb	0.7	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	19580.00 lb	19560.00 lb	-0.1	0.00		Water to Add:
WAT1	28.40 gal	255.23 gal	256.43 gal	0.5	0.00		
MB AE 200	1.41 oz	82.00 oz	81.50 oz	-0.6	0.00		
PCA OPTIFLO MR	36.80 oz	408.00 oz	412.00 oz	1.0	0.00		

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES




SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010229 DATE: 10/14/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE:	TIME: 16:19:12	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 85	ARHANICH, JAME	2305	77.10	77.00	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM 1015	11.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU				0.00 0	0.00 0	
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand Rock	2NS-SMR L6AA-PIN	SPRING MILL - 2NS PORT INLAND - 6AA	47-003 75-005	MDOT PLANT NO. M-40	GRADE OF CONC.				
Cementitious Cementitious	CMGS-LA CMT1-LAA	LAFA-SLAG-GRADE 100 LAFARGE-I-II LA-APLENA	CHICAGO ALPENA	COMPANY REPRESENTATIVE (signature) 				COLLECTED (circle one) CHECK CASH CREDIT	
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
5						X CUSTOMER SIGNATURE			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:				
4:33	4:45	5:40							
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete. UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFA-SLAG-GRADE 100	184.00 lb	2025.00 lb	2040.00 lb	0.7	0.00	48.8 gal	End of Load Time 4:20 PM
SPRING MILL - 2NS	1350.00 lb	15260.00 lb	15220.00 lb	-0.3	2.75		
LAFARGE-I-II LA-APLENA	342.00 lb	3760.00 lb	3750.00 lb	-0.3	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	19580.00 lb	19560.00 lb	-0.1	0.00		Water to Add:
WAT1	28.40 gal	255.23 gal	257.15 gal	0.8	0.00		
MB AE 200	1.41 oz	82.00 oz	82.00 oz	0.0	0.00		
PCA OPTIFLO MR	36.80 oz	408.00 oz	404.00 oz	-1.0	0.00		

Job Location	Detroit		Date	10/14/2021	
Contractor	WESTSIDE		Time Batched	14:38	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:			Truck No.	712	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780
Sand	Springmill	Gradation	2NS	Lbs	1350
Cement	Lafarge	Type	I	Lbs	342
Slag	Lafarge			Lbs	184
Air Entraining Agent	BASF Micro Air			Ozs.	5.26
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3
Other Concrete Admixture				Ozs.	
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)			

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the


City Inspector (Signature)

Time Truck Discharged

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location		Detroit		Date	10/14/2021	
Contractor		WESTSIDE		Time Batched	13:41	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:				Truck No.	821	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780	11
Sand	Springmill	Gradation	2NS	Lbs	1350	
Cement	Lafarge	Type	I	Lbs	342	
Slag	Lafarge			Lbs	184	
Air Entraining Agent	BASF Micro Air			Ozs.	5.26	
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3	
Other Concrete Admixture				Ozs.		
Transit Mix Concrete Producer	McCoig Concrete			Water - Gals	28.4	
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)				

(Producer Not To Sign Below)

(2.77)

(REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the


City Inspector (Signature)

Time Truck Discharged

City Of Detroit

TRANSIT MIX CONCRETE PRODUCER'S CERTIFICATE

City Engineering Dept.

Job Location	Detroit		Date	10/14/2021	
Contractor	WESTSIDE		Time Batched	15:12	
This certifies that the concrete carried by this transit mix truck is composed of the following materials and in the amounts shown below:			Truck No.	437	CUBIC YARDS
Coarse Aggregate	Port Inland	Gradation	6AA	Lbs	1780
Sand	Springmill	Gradation	2NS	Lbs	1350
Cement	Lafarge	Type	I	Lbs	342
Slag	Lafarge			Lbs	184
Air Entraining Agent	BASF Micro Air			Ozs.	5.26
Other Concrete Admixture	Premiere Optiflo MR			Ozs.	26.3
Other Concrete Admixture				Ozs.	
Transit Mix Concrete Producer	McCoig Concrete		Water - Gals	28.4	
Yard	1441 Springwells Ct, Detroit	Authorized Agent (Signature)			

(Producer Not To Sign Below)

(2.77) (REV. 08/07)

Additional Remarks Stated on The Back of This Certificate

Water Added at the

City Inspector (Signature)

Time Truck Discharged

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MA DETROIT,				TICKET CODE: 82010294 DATE: 10/18/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE: TIME: 11:31:46		
PO NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 237	SANDOVAL, RICO	3712	30.10	10.50	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:	UNIT PRICE:	EXTENDED:				
P1-SM 1015	10.50 1.00		MDOT P1 535 MR ENVIRONMENTAL SU	\$0.00	0.00 0				
MDOT 1155 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand Rock	2NS-SMR L6AA-PIN	SPRING MILL - 2NS PORT INLAND - 6AA	47-003 75-005	MDOT PLANT NO. M-40	GRADE OF CONC.				
Cementitious Cementitious	CMGS-LA CMT1-LAA	LAFARGE-SLAG-GRADE 100 LAFARGE-I-II LA-APLENA	CHICAGO ALPENA	COMPANY REPRESENTATIVE (signature) <i>Joseph Y...</i>		COLLECTED (circle one) CHECK CASH CREDIT			
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X			
						CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER
LAFARGE-SLAG-GRADE 100	184.00 lb	1930.00 lb	1975.00 lb	2.3	0.00	67.7 gal
SPRING MILL - 2NS	1350.00 lb	14740.00 lb	14680.00 lb	-0.4	4.00	
LAFARGE-I-II LA-APLENA	342.00 lb	3590.00 lb	3670.00 lb	2.2	0.00	
PORT INLAND - 6AA	1780.00 lb	18680.00 lb	18680.00 lb	0.0	0.00	
WAT1	28.40 gal	225.03 gal	226.47 gal	0.6	0.00	
MB AE 200	1.41 oz	78.00 oz	78.50 oz	0.6	0.00	
PCA OPTIFLO MR	36.80 oz	384.00 oz	392.00 oz	2.1	0.00	

End of Load Time 11:33 AM
Trim Water:
Water to Add:

UNLOAD PROMPTLY: Excess time will be charged to the buyer.

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

- 1 - White (Office)
- 2 - Yellow (Customer)
- 3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MA DETROIT,				TICKET CODE: 82010314 DATE: 10/18/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE: TIME: 14:12:41		
PO NO:	ORDER NO:	DRIVER NAME:	TRUCK NO:	QTY ORDERED:	QTY DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO:	
	N 237	SANDOVAL, RICO	3712	20.50	20.50	5.00	6.5	820	
ITEM NAME:	QUANTITY:	UOM:	DESCRIPTION:				UNIT PRICE:	EXTENDED:	
P1-SM 1015	10.00 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU				0.00 0	0.00 0	
MDOT 1188 STATEMENT: I hereby certified this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS	47-003	MDOT PLANT NO.	GRADE OF CONC.				
Rock	L6AA-PIN	PORT INLAND - 6AA	75-005	M-40					
Cementitious	CMGS-LA	LAFARGE-SLAG-GRADE 100	CHICAGO	COMPANY REPRESENTATIVE (signature) <i>Joseph J. Kelly</i>					
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA	ALPENA						
					COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:				Customer Requested Ticket Before Discharge Completed ☐					
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFARGE-SLAG-GRADE 100	184.00 lb	1840.00 lb	1875.00 lb	1.9	0.00	64.4 gal	End of Load Time 2:17 PM
SPRING MILL - 2NS	1350.00 lb	14040.00 lb	13980.00 lb	-0.4	4.00		
LAFARGE-I-II LA-APLENA	342.00 lb	3420.00 lb	3405.00 lb	-0.4	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	17800.00 lb	17820.00 lb	0.1	0.00		Water to Add:
WAT1	28.40 gal	214.25 gal	215.21 gal	0.4	0.00		
MB AE 200	1.41 oz	74.00 oz	74.00 oz	0.0	0.00		
PCA OPTIFLO MR	36.80 oz	368.00 oz	368.00 oz	0.0	0.00		

A MINIMUM NOTICE OF 48 HOURS IS REQUIRED FOR ALL CONCRETE DELIVERIES



SRM Concrete
1441 SpringWells Ct. Detroit, MI 48209
PHONE: (734) 357-2124

1 - White (Office)
2 - Yellow (Customer)
3 - Pink (Misc.)

SOLD TO: 83276 WESTSIDE CONCRETE CO. SHELBY TOWNSHIP, MI 48318-3368,				SHIP TO: PW 7018 CITY OF DETROIT MI DETROIT,				TICKET CODE: 82010324 DATE: 10/18/2021	
DRIVER INSTRUCTION: CLARK SOUTH OFF VERNOR, TO PORT ER ST							MAP PAGE:	TIME: 15:46:01	
PO. NO.:	ORDER NO.:	DRIVER NAME:	TRUCK NO.:	QTY. ORDERED:	QTY. DELIVERED:	DESIGN SLUMP:	DESIGNED AIR:	PLANT NO.:	
	N 237	HYDRAS, MCARTH	HI 4819	26.00	26.00	5.00	6.5	820	
ITEM NAME:		QUANTITY:	UOM:	DESCRIPTION:			UNIT PRICE:	EXTENDED:	
P1-SM 1015		5.50 1.00		MDOT P1 S35 MR ENVIRONMENTAL SU			0.00 0	0.00 0	
MDOT 1100 STATEMENT: I hereby certify this concrete meets MDOT specifications, materials are approved sources, tested, certified to MDOT.									
Sand	2NS-SMR	SPRING MILL - 2NS		47-003	MDOT PLANT NO.	GRADE OF CONC.			
Rock	L6AA-PIN	PORT INLAND - 6AA		75-005	M-40				
Cementitious	CMGS-LA	LAFARGE-SLAG-GRADE 100		CHICAGO	COMPANY REPRESENTATIVE (signature)				
Cementitious	CMT1-LAA	LAFARGE-I-II LA-APLENA		ALPENA	X <i>[Signature]</i>				
					COLLECTED (circle one) CHECK CASH CREDIT				
DRIVERS COMMENTS:					Customer Requested Ticket Before Discharge Completed ☐				
INITIAL SLUMP:	WATER ADDED:	REQUESTED BY:	FINAL SLUMP:	TESTED AIR:	REVOLUTIONS:	I've read and agreed to the terms on the back side of this delivery ticket.			
5			5						
LEAVE PLANT:	ARRIVE AT JOB:	START POUR:	FINISH POUR:	LEAVE JOB:	ARRIVE PLANT:	X <i>[Signature]</i>			
3:58	4:12					CUSTOMER SIGNATURE			
SAFETY CAUTION: Fresh concrete can cause severe chemical burns to skin and eyes. Keep fresh concrete off skin. When working use rubber work-boots, gloves, protective eyeglasses, clothing and knee-boards. Do not let concrete or other cement products soak into your skin. Wash your skin promptly after contact with fresh concrete with clean water. If fresh concrete gets into your eyes, flush immediately and repeatedly with water and consult a doctor immediately. Keep children away from dry cement powder and all freshly mixed concrete.									
UNLOAD PROMPTLY: Excess time will be charged to the buyer.									

MATERIAL	DESIGN	TARGET	BATCHED	% VAR	MOISTURE	FREE WATER	
LAFARGE-SLAG-GRADE 100	184.00 lb	1010.00 lb	1035.00 lb	2.5	0.00	33.35 gal	End of Load Time 3:48 PM
SPRING MILL - 2NS	1350.00 lb	7700.00 lb	7700.00 lb	0.0	3.75		
LAFARGE-I-II LA-APLENA	342.00 lb	1880.00 lb	1885.00 lb	0.3	0.00		Trim Water:
PORT INLAND - 6AA	1780.00 lb	9780.00 lb	9780.00 lb	0.0	0.00		Water to Add:
WAT1	28.40 gal	100.17 gal	101.61 gal	1.4	0.00		
MB AE 200	1.41 oz	41.00 oz	40.50 oz	-1.2	0.00		
PCA OPTIFLO MR	36.80 oz	200.00 oz	208.00 oz	4.0	0.00		



**DRIESENKA &
ASSOCIATES, INC.**

Engineering • Surveying • Testing

CONCRETE FIELD TEST REPORT

CLIENT: <u>West Side</u>	D&A PROJECT NO.: <u>2020525.4A</u>	DATE: <u>10-18-21</u>
PROJECT: <u>Detroit PW 7018</u>	INSPECTOR: <u>Jon Morris 61293676</u>	
CONTRACTOR: <u>West Side</u>	CONTROL SECTION/MDOT JOB NO.: <u>Detroit PW 7018</u>	
CONCRETE SUPPLIER & CITY: <u>SRM - Detroit</u>	PROJECT ENGINEER: <u>[Signature]</u>	
WEATHER: A.M. <u>Sunny</u> P.M. <u>Sunny</u>	TIME ARRIVED: <u>11:00AM</u> SCHEDULED ARRIVAL TIME: <u>11:00AM</u> TIME LEFT SITE: <u>1:00PM</u>	
AGGREGATE CORRECTION FACTOR: <u>2%</u>		

Pour Description: Sidewalk + ADA Ramps at Clark St and Porter St

Mix Design: p1-5m Quantity Placed (yd³): 30 Lot Number: _____ Sublot: _____
Grade of Concrete: p1 Batch Quantity (yd³): 30 Pour Start: 12:00 Pour End: 1:00PM

FIELD TEST RESULTS

Truck No.	Ticket #	Batch Time	Start	Empty	Slump (in)	Air Temp. (°F)	Conc. Temp. (°F)	Air Content (%)	Unit Wt. (pcf)	Yield	No. of Cylinders
3712	82010294	11:33	12:00	12:30	5 1/2	55	69	6.1	144.8	0.996	4 DCI

REMARKS

Mix p1-5m contained MB AE 200 and pCA opt 5lb MR Admixtures.