

To: City Engineering Division, DPW
900 Cadillac Tower Building,
65 Cadillac Square,
Detroit, Michigan -48226-2873
Survey Bureau: 313-224-3970
FAX: 313-224-3471

The Proposed Change in property (referred to on the other side of this sheet) would affect our services as follows:

- Not Involved.
- Involved; but withholding action on petition is requested until further notification.
- Involved; but have no objections to the change provided that an easement of the full width of the alley/street is reserved.
- Involved; nature of the services and estimated cost of removing and/or rerouting such services are:

Petition X—2629

The Public Lighting Department has following comments for the requested easement on Adams Ave bounded by Elizabeth, Cass , Grand river. PLD has underground high voltage line running in the area where petitioner request for an easement.

No Structure or barricades can be build over PLD installations or on existing utility easement areas. As per PLD requirements, any structure proposed to build shall maintain 10' horizontal clearance from the overhead PLD lines and installations also any structure proposed to be built shall maintain a minimum of 3' horizontal clearance and 12" vertical clearance from the PLD conduit bank and manholes. The contractor should take necessary precautions not to damage PLD utilities, if they plan to use heavy earth moving equipments. The contractor will be liable for any damages to any PLD underground facilities. We need unrestricted easement rights with 24 hrs heavy vehicles access to the areas request for encroachment area to maintain our facilities.

PUBLIC LIGHTING DEPARTMENT
(Utility or City Department)

By: Dinesh Witanachchi
Title: Assist Electrical Eng.
Date: October 10, 2013

