



City of Detroit
Inter-Departmental Communication

TO: Richard Doherty, City Engineer
City Engineering/Department of Public Works

FROM: Debra Singleton, Manager II
Detroit Water and Sewerage Department

DATE: April 8, 2013

RE: Petition No. 2718
Requested Encroachment Across St. Antoine
With a Tunnel 22 Feet Below Grade, 140 Feet South of South Line of Gratiot

We have reviewed the above Petition received by this office on March 26, 2013. With regard to DWSD's interests, our comment is as follows:

Our records indicate that there is a 6-inch water main and two 4-foot sewers in St. Antoine. DWSD has no objection to the requested encroachment provided that the attached Provisions for Encroachment are strictly followed. Also attached are water and sewer section maps, sewer drawings, 30-inch water main relocation drawings, and preliminary tunnel drawings for the area.

DWSD had preliminary discussions with the contractors who will build the tunnel and will need to review the design plans in advance of planned construction as soon as possible. However, this should not hold up the approval of this petition.

If you have any questions, please call me at (313) 267-8309.

Sincerely,

Debra Singleton
Manager II
Claims and Permits

DES/GS/gl

Attachments

CC: Mohamad Farhat, CSF
Gang Song, MOB
Hana A. Lewis, FSB-FE
Pei Boayue, CSF