

TO: City Engineering Division, DPW
900 Cadillac Tower Building
65 Cadillac Square
Detroit, Michigan 48226-2873
Survey Bureau: 313-224-3970
Fax: 313-224-3471

Ref. No. 201312035
Petition No. 2991

- () Involved; but asking you to hold action on this petition until further notice.
- () Involved; but no objections to the property change – provided an easement of the full width of the public right-of-way (street, alley or other public place) is reserved.
- () Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- (x) Involved; **have objection** to the request for encroachment into St Antoine St. 50 feet wide (with stair and ramp) as shown in drawing X2991.dgn, dated 12/13/2013, since the proposed layout for the encroachment does not allow the necessary minimum clear sidewalk of 5 ft for pedestrian traffic. It is suggested that the petitioner submit, for Traffic Engineering Division's review and approval, a revised layout for the stairs and ramp so as to allow a minimum of 5 ft clear sidewalk.

Traffic Engineering Division - DPW
(Utility or City Department)

for
By Ashok Patel

Jitendra Chavhan

Head Transportation Engineer
Title

February 5, 2014
Date

313-224-1610
Area code-Telephone number

MA/ma

RECEIVED FEB 06 2014

CITY ENGINEERING DIVISION - DPW
900 CADILLAC TOWER
DETROIT, MICHIGAN 48226-2873