



DTE Energy \ MichCon Gas
Data Integrity and technology
One Energy Plaza - WCB1836
Detroit, MI 48226

February 6, 2014

Richard Doherty, CED DPW, Head Engineer
City of Detroit Engineering Division, DPW
65 Cadillac Square, Suite 900
City of Detroit, Michigan 48226 - 2873

Re: Petition No. X 3024 Dated: 02/03/2014

Not involved.

Involved: but asking you to hold action on this petition until further notice.

Involved but have no objection to the property change - - provided that an easement of the full width of the public right-of-way (street, alley or other public place) is reserved. **See Remarks!**

Involved: the nature of our services, and the estimated costs of removing, rerouting or abandonment of such all gas mains and/or services

REMARKS:

Involved but have no objections to the property change, provided that the proposed encroachment into Lafayette St. 7" of decorative columns will remain as is (as 7") and will not go more than that. Reason being, MichCon Gas Co. has an existing gas main line (3" - PLA / 6" CI - 10# 1974) running along Lafayette St. from 19' EW Beaubien St., Due Westward at 4', 5' & 6' NS Lafayette St.. Otherwise, Contact MichCon Gas Co. Public Improvement Dept. (Supervisor: Jay F. Williams @ Tel. # 313-389-7303 and / or Gas Planner Laura Forester @ Tel #313-389-7261) for the estimated cost of our services in abandoning/removing/relocating and /or rerouting, including the survey, design and drawing of our utilities. See enclosed strip print for your use and information.

Please abide by Public Act 53, three (3) working days before you dig, dial toll free MISS DIG at: 1 - 800 - 482 - 7171.

Michcon Gas Leak Emergency Phone Number: 1- 800 - 947 - 5000.

Sincerely,

/s/ Thomas B Dereszewski

Thomas B. Dereszewski
Drafter
DTE Energy - MichCon Gas Co.
Data Integrity and Technology
One Energy Plaza WCB _ 1836
City of Detroit, Mi 48226

TBD/

Enclosure