


TO: City Engineering Division, DPW
900 Cadillac Tower Building
65 Cadillac Square
Detroit, Michigan 48226-2873
Survey Bureau: 313-224-3970
Fax: 313-224-3471

Ref. No. 201407048
Petition No. 330

- () Involved; but asking you to hold action on this petition until further notice.
- () Involved; but no objections to the property change – provided an easement of the full width of the public right-of-way (street, alley or other public place) is reserved.
- () Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- (x) Involved; have no objection to the request for aerial encroachment (with a 5ft wide overhead canopy) over John R St. in the block bound by Mack and Woodward Ave, Martin Place and John R St. as shown in drawing X330, dated 07/17/2014, provided that a minimum vertical underclearance of 11' 3" shall be maintained above the sidewalk at all times.

Traffic Engineering Division - DPW
(Utility or City Department)

for Ashok Patel 
By

Head Transportation Engineer
Title

August 1, 2014

313-224-1610
Area code-Telephone number

MA/ma