

City of Detroit Inter-Departmental Communication

TO:

Richard Doherty, City Engineer

City Engineering/Department of Publ c Works

FROM:

Debra Singleton, Manager II

Detroit Water and Sewerage Departr ent

DATE:

October 8, 2014

RE:

Petition No. 410

Request to Outright Vacate a Portion of the North/South Alley in the Block Bound

by Clay, Cameron, Euclid, and the Carysler Freeway

We have reviewed the above Petition received b / this office on September 20, 2014. With regard to DWSD's interests, our comment is as follows:

 Our records indicate that there is a sewer in the alley. DWSD objects to the outright vacation of a portion of the alley. However, DWSD has no objections if the petitioner agrees to relocate the sewers in accordance with the attached provisions for relocation at no cost to DWSD.

If you have any questions, please call me at (313) 267-8309.

Sincerely,

Debra Singleton

Manager II

Claims and Permits

DES/gI Attachments

CC:

Cheryl Porter, WBB Mohamad Farhat, CSF

City of Detroit City Engineering Division, Department of Public Works Survey Bureau

NOTICE OF PROPOSED CHANGE IN PROPERTY

		Date:	09/19/2014
		Petition:	x410
AT&T Telecommunication			
Cable Television (CATV)	X	Vacation	
Detroit Edison (DTE)			
Michigan Consolidated Gas (DTE)		Conversion	to Easement
Fire Department		Dedication	
Planning & Development Department			
Public Lighting Authority		Encroachm	ent
Public Lighting Dept Communication Division			
Public Lighting Dept Overhead Line Division			
Public Lighting Dept Underground Division		Temporary	Closing
Police Department			
Recreation Department		Berm Use	
Sanitation Division, DPW			
Street Design Bureau, DPW			
Street Maintenance Division, DPW			
Street and Traffic Division, DPW			
Water and Sewerage Dept Sewer Design			
Water and Sewerage Dept Water Design			

A petition drawing is attached. Property shown on the attached print is proposed to be changed as indicated.

Kindly report (using the back of this sheet) the nature of your services If any) affected by the proposed change and the estimated costs of removing and rerouting such services (if necessary).

Please return one copy to City Engineering Division, DPW. Retain one copy and print for you file.

Ron Brundidge, Director, Department of Public Works

By: Richard Doherty, CED DPW City Engineer

TO: City Engineering Division, DPW 65 Cadillac Square, Suite 900 Detroit, Michigan 48226-2873 Survey Bureau: 313-224-3970

The proposed change in property (referred to on the other side of this sheet) would affect our services as follows:			
	Not Involved		
	Involved; but asking you to hold action on this petition until further notice.		
	Involved; but no objections to the property change.		

Involved; the nature of our services and the estimated costs of removing and/or rerouting such services are:

of the public right-of-way (street, alley or other public place) is reserved.

Involved; but no objections to the property change...provided as easement of the full width


(Utility or City Department)	
Ву	
Title	
Date	
	_
Area code – Telephone number	

PETITION NO. 410 MICHIGAN HUMANE SOCIETY C/O TAKTIX SOLUTIONS, LLC DETROIT, MICHIGAN 48226

DETROIT, MICHIGAN 48226 EUCLID AVE. 50 FT. WD.

C/O MICHELLE GILBERT PHONE NO. 313 961-9446

CAMERON AVE. 66 FT. WD.





CLAY AVE. 66 FT. WD.



- OUTRIGHT VACATE SEWER

(FOR OFFICE USE ONLY)

CARTO 41 C

	\mathbb{B}							
	A							
Ì		DESCRI	PTION	DRWN	CHKD	APPD	DATE	
	REVISIONS				A			
	DRAWN BY WLW			CHECKED				
	09-19-14			APPRO	OVED			

REQUEST TO OUTRIGHT VACATE SEWER A PORTION OF THE NORTH/SOUTH PUBLIC ALLEY 19.25 FT. WD. IN THE BLOCK BOUND BY CLAY, CAMERON, EUCLID AVE. AND CHRYSLER FREEWAY CITY OF DETROIT
CITY ENGINEERING DEPARTMENT
SURVEY BUREAU

	CORT DONALLO
JOB NO.	01-01
DRWG. NO.	X 410

Detroit Water & Sewerage Department Requirements and Provisions for Petition 410

Provided that the petitioner (Petition 410) shall design and construct proposed lateral sewer and make the connections to the existing public sewers as required by the Detroit Water and Sewerage Department (DWSD) prior to construction of the proposed sewers;

Provided, that the plans for the lateral sewers shall be prepared by a registered engineer; and further

Provided, that DWSD be and is hereby authorized to review the drawings for the proposed lateral sewers and to issue permits for the construction of the lateral sewers, and further;


Provided, that the entire work is to be performed in accordance with DWSD specifications and constructed under the inspection and approval of DWSD; and further;


Provided that the entire cost of the proposed lateral sewer construction, including inspection, survey and engineering shall be borne by the petitioner; and further;

Provided that the petitioner shall provide DWSD with as -built drawings on the proposed lateral sewers and further;

Provided that the petitioner shall provide a one (1) year warranty for the proposed lateral sewer; and further

Provided that upon satisfactory completion the lateral sewers shall become city property, and part of the City system.





JAH