

TO: City Engineering Division, DPW
900 Cadillac Tower Building
65 Cadillac Square
Detroit, Michigan 48226-2873
Survey Bureau: 313-224-3970
Fax: 313-224-3471

Ref. No. 201503033
Petition No. 565

The proposed change in property (referred to above) would affect our services as follows:

- () Not Involved.
- () Involved; but asking you to hold action on this petition until further notice.
- () Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- (X) Involved; **have objection** to the requested encroachment into Civic Center Dr. and Woodbridge St. at 151 W. Jefferson Ave. (with parking deck, bridge and ramp) for the UAW Ford National Programs Center (Veteran's Memorial Building) as shown on drawing no. x565 dated 03/25/2015 since the proposed encroachment does not provide the required minimum clear sidewalk width. It is suggested that the petitioner submit a revised plan for review of Traffic Engineering Division, so as to provide a minimum sidewalk width of 6 ft. to allow for 2 ft for street furniture and 4 ft of clear, unobstructed sidewalk for pedestrian use.

Traffic Engineering Division - DPW
(Utility or City Department)

Ashok Patel *Ashok Patel*

By

Head Transportation Engineer

Title

April 10, 2015

Date

313 224-1610

Area code-Telephone number

MA/ma

201503033


City of Detroit
City Engineering Division, Department of Public Works
Survey Bureau

NOTICE OF PROPOSED CHANGE IN PROPERTY

Date: 03/25/2015

Petition: x565

- AT&T Telecommunication
- Cable Television (CATV)
- Detroit Edison (DTE)
- Michigan Consolidated Gas (DTE)
- Fire Department
- Planning & Development Department
- Public Lighting Authority
- Public Lighting Dept. - Communication Division
- Public Lighting Dept. - Overhead Line Division
- Public Lighting Dept. - Underground Division
- Police Department
- Recreation Department
- Sanitation Division, DPW
- Street Design Bureau, DPW
- Street Maintenance Division, DPW
- Street and Traffic Division, DPW
- Water and Sewerage Dept. - Sewer Design
- Water and Sewerage Dept. - Water Design
- Vacation
- Conversion to Easement
- Dedication
- Encroachment
- Temporary Closing
- Berm Use



A petition drawing is attached. Property shown on the attached print is proposed to be changed as indicated.

Kindly report (using the back of this sheet) the nature of your services If any) affected by the proposed change and the estimated costs of removing and rerouting such services (if necessary).

Please return one copy to City Engineering Division, DPW. Retain one copy and print for you file.

Ron Brundidge, Director, Department of Public Works

By: Richard Doherty, CED DPW
City Engineer

