

**City of Detroit
City Engineering Division, Department of Public Works
Survey Bureau**

NOTICE OF PROPOSED CHANGE IN PROPERTY

Date: 06/04/2015

Petition: x702

- | | |
|--|---|
| ☐ AT&T Telecommunication | |
| ☐ Cable Television (CATV) | ☒ Vacation |
| ☐ Detroit Edison (DTE) | |
| ☐ Michigan Consolidated Gas (DTE) | ☐ Conversion to Easement |
| ☐ Fire Department | ☐ Dedication |
| ☐ Planning & Development Department | |
| ☐ Public Lighting Authority | ☐ Encroachment |
| ☒ Public Lighting Dept. - Communication Division | |
| ☒ Public Lighting Dept. - Overhead Line Division | |
| ☒ Public Lighting Dept. - Underground Division | ☐ Temporary Closing |
| ☐ Police Department | |
| ☐ Recreation Department | ☐ Berm Use |
| ☐ Sanitation Division, DPW | |
| ☐ Street Design Bureau, DPW | |
| ☐ Street Maintenance Division, DPW | |
| ☐ Street and Traffic Division, DPW | |
| ☐ Water and Sewerage Dept. - Sewer Design | |
| ☐ Water and Sewerage Dept. - Water Design | |

A petition drawing is attached. Property shown on the attached print is proposed to be changed as indicated.

Kindly report (using the back of this sheet) the nature of your services if any) affected by the proposed change and the estimated costs of removing and rerouting such services (if necessary).

Please return one copy to City Engineering Division, DPW. Retain one copy and print for you file.

Ron Brundidge, Director, Department of Public Works

By: Richard Doherty, CED DPW
City Engineer

9/18/2014 clr

**TO: City Engineering Division, DPW
65 Cadillac Square, Suite 900
Detroit, Michigan 48226-2873
Survey Bureau: 313-224-3970**

x702

The proposed change in property (referred to on the other side of this sheet) would affect our services as follows:

- ☐ Not Involved
- ☐ Involved; but asking you to hold action on this petition until further notice.
- ☐ Involved; but no objections to the property change.
- ☐ Involved; but no objections to the property change...provided as easement of the full width of the public right-of-way (street, alley or other public place) is reserved.
- ☒ Involved; the nature of our services and the estimated costs of removing and/or rerouting such services are:

PLD has a overhead circuit through these alleys. Status of the circuit would have to be checked, and relocation would be needed depending upon the status. Additionally, a local street light feed would have to be relocated. There are lines owned by other utilities in these alleys. PLD relocations could be done in conjunction with the others. All costs would be borne by the project.

Public Lighting Department (PLD)
(Utility or City Department)

Denise Williams
By

Senior Assistant Mechanical Engineer
Title

June 25, 2015
Date

313-267-7216
Area code – Telephone number