


TO: City Engineering Division, DPW
900 Cadillac Tower Building
65 Cadillac Square
Detroit, Michigan 48226-2873
Survey Bureau: 313-224-3970
Fax: 313-224-3471

Ref. No. 201508009
Petition No. 753

- () Involved; but asking you to hold action on this petition until further notice.
- () Involved; but no objections to the property change – provided an easement of the full width of the public right-of-way (street, alley or other public place) is reserved.
- () Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- (x) Involved; have no objection to the request for encroachment into Woodward at 1515 Woodward Ave., for bicycle rack installation as shown in attachments dated 8/15/2015, provided that the following conditions are met with:
 - The bicycle racks with the bicycles mounted thereon shall leave a minimum 6 ft wide clear sidewalk for pedestrian traffic.
 - Petitioner shall seek permission of the abutting property owner before installing the bicycle racks.
 - Petitioner/ abutting property owner shall be responsible for maintaining/cleaning the sidewalk surface around the encroachment.
 - Petitioner shall bear all cost associated with the installation and maintenance of the bicycle racks and ensure that the sidewalk adjacent to the encroachment is not damaged due to the bicycle rack installation.

Traffic Engineering Division - DPW
(Utility or City Department)

for Ashok Patel 
By _____

Head Transportation Engineer
Title

September 22, 2015
Date

313-224-1610
Area code-Telephone number

JL/jl