



October 6, 2016

City Engineering Division DPW
Real Estate Group
2 Woodward Ave., Suite 642
Detroit, MI 48226-3462

Attention: Richard Doherty CED DPW,
City Engineer

**RE: Petition Number X931 REVISED
Request to Outright Vacate A Portion of Bayside Avenue and
Dumfries Avenue, Various Public Alleys, 20-ft wide. In the
Blocks Bound by Oakwood Boulevard, Sanders Avenue,
Dunkirk Avenue and Wabash RR
JOB Number: 01-01 / Drawing Number: X931 REVISED
Detroit, MI**

GLWA GPET 1620

This is in response to your notice dated October 6, 2016 and received by our office on the same by email.

A review of the above plans with our department records indicates a conflict with Great Lakes Water Authority (GLWA):

✓ **10-foot sewer interceptor in Bayside Avenue between Wabash RR and Sanders Avenue**

Great Lakes Water Authority (GLWA) will not give up the rights to repair this sewer if needed. Please note that Great Lakes Water Authority (GLWA) prohibit the use of heavy construction equipment (bulldozers, backhoes, extremely large rollers, etc.) and/or storage of building material **directly over or near our facilities**. GLWA also prohibits the use of cranes and balls or hydraulic rams for pavement removal where the GLWA facilities are involved. If the water main or sewer facilities are broken or damaged as a result of any action on the part of the contractor, then the contractor shall be liable for all costs incidental to the repair of such broken or damaged water mains / sewer facilities and appurtenances. The contractor shall wave all claims for damages under such circumstances.

Please be advised that you will have to contact Detroit Water and Sewerage Department (DWSD) for the Easement information for this 10-foot sewer interceptor.



Page 02
October 6, 2016
GLWA GPET 1620

For locations regarding water and sewer facilities owned and operated by communities other than Great Lakes Water Authority (GLWA), **contact the local community/authority or private concern involved for updated information:**

- ✓ Detroit Water and Sewerage Department (DWSD)

If you have questions regarding the above, please call (313) 267-4857 or email: dale.echols@glwater.org
Please send plans and correspondence to:

Dale Echols ET CADD
DWSD / GLWA FIELD ENGINEERING
North Administration Building - CSF
6425 Huber Street, 1st Floor
Detroit, MI 48211-1677

Very Truly Yours,

Dale Echols ET CADD

DE/dle/Letters PET
cc: PETITIONS