



November 22, 2016

City Engineering Division DPW  
Real Estate Group  
2 Woodward Ave., Suite 642  
Detroit, MI 48226-3462

**Attention:** Richard Doherty CED DPW,  
City Engineer

**RE: Petition Number X931 REVISED  
Request to Outright Vacate Dumfries Avenue 60-ft wide  
Various Public Alleys, 20-ft wide. Conversion to Easement  
Bayside Avenue 60-ft wide In the Area Bound by Oakwood  
Boulevard, Sanders Avenue, Dunkirk Avenue and Wabash RR  
JOB Number: 01-01 / Drawing Number: X931 REVISED  
Detroit, MI**

**GLWA GPET 1620 REVISED**

This is in response to your notice dated November 10, 2016 and received by our office on the same by email.

A review of the above plans with our department records indicates a conflict with Great Lakes Water Authority (GLWA):

✓ **10-foot sewer interceptor in Bayside Avenue between Wabash RR and Sanders Avenue**

Great Lakes Water Authority (GLWA) will not give up the rights to repair this sewer if needed. Please note that Great Lakes Water Authority (GLWA) prohibit the use of heavy construction equipment (bulldozers, backhoes, extremely large rollers, etc.) and/or storage of building material **directly over or near our facilities**. GLWA also prohibits the use of cranes and balls or hydraulic rams for pavement removal where the GLWA facilities are involved. If the water main or sewer facilities are broken or damaged as a result of any action on the part of the contractor, then the contractor shall be liable for all costs incidental to the repair of such broken or damaged water mains / sewer facilities and appurtenances. The contractor shall wave all claims for damages under such circumstances.

**Please be advised that you will have to contact Detroit Water and Sewerage Department (DWSD) for the Easement information for this 10-foot sewer interceptor.**



Page 02

November 22, 2016

**GLWA GPET 1620 REVISED**

For locations regarding water and sewer facilities owned and operated by communities other than Great Lakes Water Authority (GLWA), **contact the local community/authority or private concern involved for updated information:**

- ✓ Detroit Water and Sewerage Department (DWSD)

If you have questions regarding the above, please call (313) 267-4857 or email: [dale.echols@glwater.org](mailto:dale.echols@glwater.org)

Please send plans and correspondence to:

**Dale Echols ET CADD**

**DWSD / GLWA FIELD ENGINEERING**

**North Administration Building - CSF**

**6425 Huber Street, 1<sup>st</sup> Floor**

**Detroit, MI 48211-1677**

Very Truly Yours,

---

Dale Echols ET CADD

DE/dle/Letters PET  
cc: PETITIONS