

**Walter Williams - Fwd: Petition #1761**

---

**From:** Keith McCrary  
**To:** Walter Williams  
**Date:** 5/10/2018 8:48 AM  
**Subject:** Fwd: Petition #1761

---

Keep for our records. To be included in the resolution.

Keith McCrary  
Supervisor of Maps and Records  
Survey Bureau  
City Engineering Division  
Department of Public Works  
[313-224-3970](tel:313-224-3970)  
[mccraryk@detroitmi.gov](mailto:mccraryk@detroitmi.gov)

**Mike Duggan, Mayor**

>>> Keith Hewlett 5/7/2018 11:49 AM >>>  
Good morning Mr. Siddique.

I have approved Petition # 1761 with the following stipulations:

- Maintain fire department vehicle access route at all times
- Maintain fire hydrant on private property / keep free and clear of any obstructions
- Provide fire department with knox-box, and manual gate key

These are the conditions that must be adhered to for approval of this petition.

If you have any additional questions please contact me.

Thank you.

Keith A. Hewlett  
Chief, Plans Exam Section  
Detroit Fire Department  
Fire Marshal Division  
2 Woodward Ave.  
C.A.Y.M.C. - Ste 411  
Detroit, MI 48226  
[\(313\) 224-1311](tel:(313)224-1311)-Direct  
[\(313\) 224-1908](tel:(313)224-1908)-fax  
[hewlettk@detroitmi.gov](mailto:hewlettk@detroitmi.gov)

Mike Duggan. Mayor

**IMPORTANT NOTICE:** This email transmission is intended only for the person named above, and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If you are not the intended recipient, or the person responsible for delivering the message to the intended recipient, you are hereby notified that any dissemination, distribution, or copying of the document transmitted is strictly prohibited. If you have received this communication in error, please notify me immediately. Thank you.

---