

TO: City Engineering Division, DPW  
900 Cadillac Tower Building  
65 Cadillac Square  
Detroit, Michigan 48226-2873  
Survey Bureau: 313-224-3970  
Fax: 313-224-3471

Petition No. 1770

The proposed change in property (referred to above) would affect our services as follows:

- Not Involved.
- Involved; but asking you to hold action on this petition until further notice.
- Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- Involved; have no objection to requested encroachment on Griswold St. and W. Grand River Ave. (For Various Architectural Elements) as shown on drawing no. x1770 dated 02/06/2018 and on proposed plans attached herewith, provided that;
  - (1) The encroachment shall be completely cantilevered and shall not have any support on the grade level.
  - (2) A minimum of 8ft. clear height/under clearance shall be maintained at the ground level.

Traffic Engineering Division - DPW  
(Utility or City Department)

Ashok Patel  
By

*Sunny Jacob*

City Traffic Engineer  
Title

June 11, 2018  
Date

313 224-1610  
Area code-Telephone number

JL/jl



PETITION NO. 1770  
 GRAND RIVER LLC  
 C/O GIFFELS WEBSTER  
 28 W. ADAMS, SUITE 1200  
 DETROIT, MICHIGAN 48226  
 C/O MICHAEL MARKS P.E.  
 PHONE NO. 313 980-1469

**"REVISED"**



**W. GRAND RIVER AVE. 60 FT. WD.**


DETAILS OF ENCROACHMENT SHOWN ON NEXT SHEET



**GRISWOLD ST. 60 FT. WD.**

**WOODWARD AVE. 120 FT. WD.**

**STATE ST. 60 FT. WD.**



- REQUEST ENCROACHMENT  
 (With Exterior Architectural Elements from  
 8 Feet Above Grade to 78 Feet Above Grade)

(FOR OFFICE USE ONLY)

CARTO 28 B

<b>B</b>					
<b>A</b>	REMOVING SIDEWALK CARE AT GRADE	JK	KSM	KSM	5/9/18
	DESCRIPTION	DRWN	CHKD	APPD	DATE
REVISIONS					
	DRAWN BY	CHECKED			
	JK	KSM			
	DATE	APPROVED			
	02-06-18				

**REQUEST ENCROACHMENT  
 ON GRISWOLD ST. AND W. GRAND RIVER AVE.  
 (For Various Architectural Elements)**

<b>CITY OF DETROIT    CITY ENGINEERING DEPARTMENT    SURVEY BUREAU</b>	
JOB NO.	01-01
DRWG. NO.	X 1770