TO:

City Engineering Division, DPW 2 Woodward Ave., Suite 642

Detroit, MI 48226-3462

Survey Bureau: 313-224-3970

Petition No. 1778

The proposed change in property (referred to above) would affect our services as follows:

- () Not Involved.
- () Involved; but asking you to hold action on this petition until further notice.
- ( ) Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- (X) Involved, have no objection to the request to encroachment a portion of the north/south public alley (with balcony) as shown on drawing no. x1778 dated 10/06/2017. However, we **have objection** to the request for encroachment into Library and Gd. River Ave. at 1274 Library (with Outdoor Seating) as shown on drawing no. x1778 dated 10/06/2017 since the proposed outdoor seating does not allow for the required 6 ft wide clear unobstructed sidewalk for pedestrian traffic in front of the outdoor seating area and an additional 2.5 ft of sidewalk width required for accommodating street furniture. The petitioner may revise the proposed layout to address the above deficiencies and resubmit the revised request for review and approval by Traffic Engineering Division.

<u>Traffic Engineering Division - DPW</u>
(Utility or City Department)

Ashok Patel Sunny Scients
By

City Traffic Engineer

Title

January 4, 2018 Date

313 224-1610

Area code-Telephone number

MA/ma

PETITION NO. 1778
BEDROCK REAL ESTATE SERVICES, LLC
C/O GIFFELS WEBSTER
1092 WOODWARD AVE. DETROIT, MICHIGAN 48226 C/O MICHAEL MARKS PHONE NO. 313 962-4442 GD. RIVER AVE. 60 FT. WD. 117' CURB SIDEWALK LIBRARY AVE. 71 FT. WD **~**-P2 17.5'  $\bigcirc$  $\bigcirc$ SIDEWALK 48.3 ENCROACHMENT 15' ABOVE GRADE TO 94'  $\bigcirc$ ()16 17' 6 GD. RIVER AVE. 60 FT. WD. 23' 100 100 65.65 65.65 62 JBRARY AVE. 71 FT. WD 10 SEC PLAN = ~ 60 8 6 58 65 65 5 57 .65 - REQUEST ENCROACHMENT (With Balcony) .65 100 100 GRATIOT AVE. 60 FT. WD. - REQUEST ENCROACHMENT (With Outdoor Seating) CARTO 28 A (FOR OFFICE USE ONLY) REQUEST ENCROACHMENT В CITY OF DETROIT A PORTION OF THE NORTH/SOUTH PUBLIC ALLEY A CITY ENGINEERING DEPARTMENT (With Balcony) DRWN CHED APPD DATE DESCRIPTION SURVEY BUREAU REVISIONS AND INTO LIBRARY AND GD. RIVER AVE. CHECKED JOB NO. 01-01 WLW AT 1274 LIBRARY APPROVED DRWG. NO. X 1778 10-06-17 (With Outdoor Seating)