

TO: City Engineering Division, DPW  
2 Woodward Ave., Suite 642  
Detroit, Michigan 48226-3462  
Survey Bureau: 313-224-3970

Petition: x429

The proposed change in property (referred to on the other side of this sheet) would affect our services as follows:

- ☐ Not Involved
- ☐ Involved; but asking you to hold action on this petition until further notice.
- ☐ Involved; but no objections to the property change.
- ☒ Involved; objection to the property change.  
*The drawings provided do not accurately depict current site conditions. Add all site features such as the stop light, ADA ramps, cross walk signal, manhole covers, etc. and dimensions between these features and the proposed outdoor seating.*
- ☐ Involved; but no objections to the property change...provided as easement of the full width of the public right-of-way (street, alley or other public place) is reserved.
- ☐ Involved; the nature of our services and the estimated costs of removing and/or rerouting such services are:

DPW/CED, Street Design Bureau  
(Utility or City Department)

Pamela Lemme, PE  
By



Senior Associate Civil Engineer  
Title

August 31, 2018  
Date

313-224-3947  
Area code – Telephone number

