

TO: City Engineering Division, DPW  
2 Woodward Ave., Suite 642  
Detroit, MI 48226-3462  
Survey Bureau: 313-224-3970


Petition No. 734

The proposed change in property (referred to above) would affect our services as follows:

- ( ) Not Involved.
- ( ) Involved; but asking you to hold action on this petition until further notice.
- ( ) Involved; the nature of our services, and the estimated costs of removing and/or rerouting such services are:
- (X) Involved; **have objection** to request for encroachment to install universally accessible ramp/stairs at 1551 Winder Street as shown on drawing no. X 734 dated 03/12/2019 because sidewalk is not meeting the minimum required width. A minimum width of 6 feet clear sidewalk is required after the proposed encroachment.

Traffic Engineering Division - DPW  
(Utility or City Department)

Ashok Patel  
By



City Traffic Engineer  
Title

May 9, 2019  
Date

313 224-1610  
Area code-Telephone number


SJ/aa

PETITION NO. 734  
 E&B BREWERY LOFTS  
 1551 WINDER ST.  
 DETROIT, MI 48207  
 JAMES J. PELLERITO  
 PHONE NO. (313) 782-4993




ADELAIDE ST. 50 FT.WD.

RIOPELLE ST. 39 FT.WD.




WINDER ST. 50FT.WD.



FISHER FREEWAY

ORLEANS ST. 50FT.WD.



- REQUEST ENCROACHMENT

(FOR OFFICE USE ONLY)

CARTO 39 D

B					
A					
DESCRIPTION		DRWN	CHKD	APPD	DATE
REVISIONS					
DRAWN BY	SA	CHECKED	KSM		
DATE	03-12-19	APPROVED			

REQUEST ENCROACHMENT  
 TO INSTALL UNIVERSALLY ACCESSIBLE  
 RAMP/STAIRS AT 1551 WINDER STREET.

CITY OF DETROIT  
 CITY ENGINEERING DIVISION  
 SURVEY BUREAU

JOB NO. 01-01

DRWG. NO. X 734