


# Location C/D



2'9" is based on measurement from east edge of DTE manhole to west edge of PMW-22R/PSG-5 . The 2'9" measurement should be increased to 5' for DTE to approve.

\*If different location is identified, DTE will need to re-evaluate.

Prepared by: DTE Electric

8/1/2025

MAP-24-65 City of Detroit Petition DTE Electric Dimensions